No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1	711002	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The door has less than 32" clear width.	Second Floor East 200 Pod Cells Typical	ADA	$4,673.05	$4,673.05
2	710983	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Accessible Route	1	The interior accessible route has less than 36" clear width.	Second Floor Medical Cell M3	ADA	$179.73	$179.73
3	711053	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Public Visitor Side Floors 3-8 Typical	California Accessibility Code	$6,319.40	$6,319.40
4	710059	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The door has less than 32" clear width.	Court Holding Cell 8 (Accessible)	ADA	$4,673.05	$4,673.05
5	764893	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Detention/Correctional Facilities	Secured Area	1	Interview and visitor rooms are not accessible.	Floors 3 to 8	ADA	$2,068,789.90	$2,068,789.90
6	710975	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor Medical Nurses Station Psych Side	ADA	$539.20	$539.20
7	710949	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor Women's Restroom and Locker Room	ADA	$2,246.66	$2,246.66
8	710974	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Second Floor Medical Psychiatric Side	ADA	$2,616.91	$2,616.91
9	710969	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor Medical Staff Office Doors	ADA	$539.20	$539.20
10	710982	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor Medical Area Doors	ADA	$1,078.40	$1,078.40
11	710990	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Second Floor East 100 Accessible Pod Entrance Door	ADA	$0.00	$0.00
12	710996	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor East 100 Accessible Pod Cell 5	ADA	$14,378.62	$14,378.62
13	711013	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Access Route	1	The width of the accessible route is less than 36".	Second Floor East Exam Room	IBC	$179.73	$179.73
14	711017	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Second Floor East Inmate Side Visitor Room Door	ADA	$658.54	$658.54
15	710980	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Accessible Route	1	Clear widths are less than 36" minimum, including protruding objects.	Second Floor Medical Nurses Station Psych Side	ADA	$179.73	$179.73
16	710988	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Second Floor East 100 Accessible Pod Entrance Door	California Accessibility Code	$0.00	$0.00
17	711015	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor East Inmate Side Visitor Room Door	ADA	$14,378.62	$14,378.62
18	711019	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Second Floor Line Up Viewing Room Public Side Door	ADA	$657.82	$657.82
19	710987	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Accessible Route	1	Clear widths are less than 36" minimum, including protruding objects.	Second Floor Medical Stand-Up X-Ray	ADA	$179.73	$179.73
20	710991	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Second Floor East 100 Accessible Pods Typical	ADA	$658.54	$658.54
21	711001	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Second Floor East 200 Pod Cells Typical	ADA	$658.54	$658.54
22	711014	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor East Exam Room	ADA	$179.73	$179.73
23	710989	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Second Floor East 100 Accessible Pod Entrance Door	ADA	$0.00	$0.00
24	711016	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Second Floor East Inmate Side Visitor Room Door	California Accessibility Code	$526.62	$526.62
25	711020	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor East Visiting Room Public Side Door	ADA	$14,378.62	$14,378.62
26	711030	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	3rd Floor West Public Visitor Side J Booth	ADA	$658.54	$658.54
27	711035	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	3rd Floor West Public Visitor Side R Booth	ADA	$658.54	$658.54
28	711056	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Accessible Route	1	Vertical level changes between 1/4" and 1/2" high are not beveled or vertical level changes greater than 1/2" high are not ramped.	7th Floor Mezzanine Elevator D	ADA	$306.55	$306.55
29	711021	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Second Floor East Visiting Room Public Side Door	ADA	$657.82	$657.82
30	711037	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	3rd Floor East Public Visitor Side	ADA	$657.82	$657.82
31	711049	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Public Visitor Side Floors 3-8 Typical	ADA	$7,893.86	$7,893.86
32	711023	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	3rd Floor West Public Visitor Side Door	ADA	$658.54	$658.54
33	711028	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	3rd Floor West Public Visitor Side J Booth	ADA	$14,378.62	$14,378.62
34	711039	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	3rd Floor East Public Visitor Side	California Accessibility Code	$526.62	$526.62
35	711050	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Public Visitor Side Floors 3-8 Typical	ADA	$7,902.49	$7,902.49
36	711024	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	3rd Floor West Public Visitor Side Doors	California Accessibility Code	$1,053.23	$1,053.23
37	711029	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	3rd Floor West Public Visitor Side J Booth	ADA	$657.82	$657.82
38	711034	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	3rd Floor West Public Visitor Side R Booth	ADA	$657.82	$657.82
39	711055	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Elevator	1	The clearance between the car platform sill and the edge of the hoistway landing is greater than 1-1/4".	Elevator Car P1	ADA	$5,456.69	$5,456.69
40	711155	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Platform Lift	1	A platform lift is required but not provided.	Department Courtrooms 60-63	ADA	$161,939.20	$161,939.20
41	708863	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Door D-2	ADA	$657.82	$657.82
42	711561	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Indoor Rec Areas Floors 3-8 Typical	ADA	$15,701.45	$15,701.45

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
43	708860	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Door D-1	ADA	$657.82	$657.82
44	708867	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Floor B & G, 1st & 2nd Floors	ADA	$898.66	$898.66
45	708894	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Treads, including top and bottom treads, of the interior stair flight do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	First Floor Lobby Stair ST-1	California Accessibility Code	$1,708.18	$1,708.18
46	708903	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Basement Interview Room 3	ADA	$14,378.62	$14,378.62
47	708897	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	First Floor Security Officers Storage Room	ADA	$14,378.62	$14,378.62
48	708895	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	Handrails are not compliant.	First Floor Lobby Stair ST-1	ADA	$41,015.01	$41,015.01
49	708898	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	First Floor Mail Room at Security Office.	ADA	$14,378.62	$14,378.62
50	708923	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Floor B & G, 1st & 2nd Floors	ADA	$46,047.53	$46,047.53
51	708940	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Accessible Route	1	Clear widths are less than 36" minimum, including protruding objects.	Basement Jail Support Unit Room	ADA	$718.93	$718.93
52	708926	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Basement Corridor	ADA	$898.66	$898.66
53	708939	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Basement Mechanical Room Corridor	ADA	$179.73	$179.73
54	708919	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Common Areas Floors B & G, 1st & 2nd	ADA	$46,097.85	$46,097.85
55	708961	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Ramp	1	Handrail heights are not compliant.	Courtrooms 60, 61 & 62 Ramps	ADA	$12,319.60	$12,319.60
56	708977	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Treads, including top and bottom treads, of the interior stair flight do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Stair ST-3	California Accessibility Code	$1,708.18	$1,708.18
57	708960	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Ramp	1	The ramp running slope exceeds 1:12 (8.33%).	Courtrooms 60, 61 & 62 Ramps	ADA	$28,573.19	$28,573.19
58	708976	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Stair ST-2	California Accessibility Code	$29,296.44	$29,296.44
59	708959	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	Handrails are not compliant.	Courtrooms 60, 61, 62 & 63 Judges' Bench Access Stair	ADA	$11,718.57	$11,718.57
60	708975	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Treads, including top and bottom treads, of the interior stair flight do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Stair ST-2	California Accessibility Code	$1,644.91	$1,644.91
61	708958	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Accessible Route	1	Clear widths are less than 36" minimum, including protruding objects.	Floor 1 Main Access to the Courtrooms	ADA	$179.73	$179.73
62	708962	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Employee Work Areas	Interior Ramp	1	The clear width of the ramp is less than 36"	Courtrooms 60, 61 & 62	ADA	$179.73	$179.73
63	708978	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Stair ST-3	California Accessibility Code	$29,296.44	$29,296.44
64	708994	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Basement Level Attorney Interview Offices	ADA	$28,757.24	$28,757.24
65	708993	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The threshold at the accessible door is greater than ½" in height.	Basement Level Attorney Interview Offices	ADA	$1,932.49	$1,932.49
66	709004	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Accessible Route	1	Clear widths are less than 36" minimum, including protruding objects.	Clerk's Office for Department 62 and 63	ADA	$359.47	$359.47
67	709003	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Accessible Route	1	Clear widths are less than 36" minimum, including protruding objects.	Clerk's Office for Department 60 and 61	ADA	$359.47	$359.47
68	709063	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Accessible Route	1	Clear widths are less than 36" minimum, including protruding objects.	Courtroom Security Office	ADA	$718.93	$718.93
69	709084	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Accessible Parking	Parking Space-Van	1	CALIFORNIA: A van space and adjacent van aisle are not provided.	Parking Garage	California Accessibility Code	$1,509.76	$1,509.76
70	709060	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Access Route	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	First Floor Courtroom Security Office	ADA	$2,616.91	$2,616.91
71	709087	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp run does not have a compliant detectable warning.	Booking Intake Area Curb Ramp CR-1	California Accessibility Code	$1,207.80	$1,207.80
72	709970	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Booking Intake Area	California Accessibility Code	$1,781.51	$1,781.51
73	709974	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Booking Intake Area	ADA	$359.47	$359.47
74	709081	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Egress Stairs Facility (Typical Finding)	California Accessibility Code	$117,185.75	$117,185.75
75	709086	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp has non-compliant slopes.	Booking Intake Area Curb Ramp CR-1	California Accessibility Code	$3,145.32	$3,145.32
76	709969	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Access Route	1	The interior accessible route has non-compliant slopes.	Booking Intake Area	ADA	$3,420.50	$3,420.50
77	709085	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Stair ST-5 Garage Area	California Accessibility Code	$4,101.50	$4,101.50
78	709089	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Access Route	1	The interior accessible route has non-compliant slopes.	Booking Intake Area	ADA	$6,841.00	$6,841.00
79	709972	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Access Route	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Booking Intake Area	ADA	$2,616.91	$2,616.91
80	709088	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp landing is not level. The slope of the curb ramp landing exceeds the maximum allowable 1:48 (2.08%).	Booking Intake Area Curb Ramp CR-1	California Accessibility Code	$2,316.76	$2,316.76
81	709984	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Access Route	1	CALIFORNIA: The width of the aisle is not compliant.	Booking Intake Room 2	California Accessibility Code	$179.73	$179.73
82	710024	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Inner Loop Seargent's Watch Office	ADA	$14,378.62	$14,378.62
83	710005	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Inner loop Circulation Path	ADA	$1,308.45	$1,308.45
84	710019	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Inner Loop Interior Doors	ADA	$179.73	$179.73
85	710027	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Access Route	1	CALIFORNIA: The width of the aisle is not compliant.	Male Release Area	California Accessibility Code	$179.73	$179.73
86	710033	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Inner Loop Stair ST-6	California Accessibility Code	$24,609.01	$24,609.01
87	710025	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Inner Loop Interior Doors	ADA	$179.73	$179.73
88	710029	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Male Release Area	ADA	$14,378.62	$14,378.62

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
89	710017	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Booking Manager's Office	ADA	$28,757.24	$28,757.24
90	710037	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The door has less than 32" clear width.	Second Floor Admin Unisex Restroom RR-1	ADA	$4,673.05	$4,673.05
91	710034	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Treads, including top and bottom treads, of the interior stair flight do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Inner Loop Stair ST-6	California Accessibility Code	$1,708.18	$1,708.18
92	710084	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Laundry Room Office	ADA	$179.73	$179.73
93	710102	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Fire Extinguishes Throughout the Facility	ADA	$1,078.40	$1,078.40
94	710115	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Second Floor Conference Room	ADA	$657.82	$657.82
95	710104	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Fiscal Office	ADA	$359.47	$359.47
96	710108	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Access Route	1	CALIFORNIA: The width of the aisle is not compliant.	Kitchen Exit Hallway	California Accessibility Code	$179.73	$179.73
97	710113	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Second Floor Admin Corridor	ADA	$3,925.36	$3,925.36
98	710106	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Fitness	Exercise Equipment	1	Clear floor space is not provided at the transfer point to the exercise equipment.	Employee Gym	IBC	$359.47	$359.47
99	710116	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Second Floor Conference Room	ADA	$658.54	$658.54
100	710146	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Interior Access Route	1	CALIFORNIA: The width of the aisle is not compliant.	Admin Office 2nd Floor	California Accessibility Code	$179.73	$179.73
101	726058	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Basement to Courtrooms Stair ST-A	California Accessibility Code	$29,296.44	$29,296.44
102	726060	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Basement to Courtrooms Stair ST-B	California Accessibility Code	$29,296.44	$29,296.44
103	711031	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Common Areas	Counter	2	The visiting area counter does not have 30" minimum by 48" minimum clear floor space for a parallel approach.	3rd Floor West Public Visitor Side J Booth	ADA	$359.47	$359.47
104	711032	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Common Areas	Counter	2	The visiting area counter does not have 30" minimum by 48" minimum clear floor space for a parallel approach.	3rd Floor West Public Visitor	ADA	$359.47	$359.47
105	764892	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Accessible Route	Accessible Route	2	CALIFORNIA: There is no accessible route to the prisoner interview or visitor rooms.	Each floor 3 to 8	California Accessibility Code	$1,407,878.42	$1,407,878.42
106	710963	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	Second Floor Women's Restroom and Locker Room	ADA	$1,471.45	$1,471.45
107	710967	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Reach Range	2	Items requiring an unobstructed forward reach motion are higher than 48" maximum or lower than 15" minimum height above finish floor.	Second Floor Women's Restroom and Locker Room	ADA	$1,797.33	$1,797.33
108	710973	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Second Floor Medical Area Doors	ADA	$4,673.05	$4,673.05
109	711018	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Second Floor Line Up Viewing Room Public Side Door	ADA	$359.47	$359.47
110	710981	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Second Floor Medical Area Doors	ADA	$718.93	$718.93
111	711048	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Public Visitor Side Floors 3-8 Typical	ADA	$4,313.59	$4,313.59
112	711026	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Signage	2	The interior signage does not have compliant visual and tactile characters, with raised or indented characters or symbols.	3rd Floor West Public Visitor Side	ADA	$98.85	$98.85
113	711040	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Signage	2	The interior signage does not have compliant visual and tactile characters, with raised or indented characters or symbols.	Public Visitor Side Floors 3-8 Typical	ADA	$1,186.24	$1,186.24
114	711051	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Public Visitor Side Floors 3-8 Typical	ADA	$56,076.62	$56,076.62
115	713546	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Kitchen	Kitchen-Residential And Employee-Only Counter	2	The height of the counter is greater than 34".	Courtroom Security Office	ADA	$3,569.49	$3,569.49
116	708865	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Common Areas	Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Front Security Counter	State of California	$3,235.19	$3,235.19
117	712465	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Kitchen	Kitchen-Residential And Employee-Only Counter	2	The height of the counter is greater than 34".	Clerk's Office for Department 62 and 63	ADA	$3,569.49	$3,569.49
118	708866	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Common Areas	Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Information Counter	State of California	$3,235.19	$3,235.19
119	711558	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Common Areas	Sink	2	The accessible sink is not installed with the front of the higher of the rim or counter surface 34" maximum above finished floor.	3rd Floor Transportation Office	ADA	$1,294.08	$1,294.08
120	712464	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Kitchen	Kitchen-Residential And Employee-Only Counter	2	The height of the counter is greater than 34".	Clerk's Office for Department 60 and 61	ADA	$3,569.49	$3,569.49
121	708901	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" maximum.	Floor B & G, 1st & 2nd Floors	ADA	$18,692.21	$18,692.21
122	708891	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Protruding Object	2	The restroom circulation path is not free of objects protruding more than 4" from wall in the space between 27" and 80" height above finish floor.	First Floor - Women's Restroom RR-2	ADA	$647.04	$647.04
123	708900	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Common Areas	Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	First Floor Cashiers Counter	State of California	$3,235.19	$3,235.19
124	708893	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Signage	2	Tactile means of egress signage is not provided at the latch side of the door. (Applies to designated egress stairways, exit doors, areas of refuge)	Facility Wide Stair Tactile Signage	ADA	$988.53	$988.53

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
125	708917	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Common Areas	Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Basement Court Control Attorney Access Counter	State of California	$3,235.19	$3,235.19
126	708925	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Basement Corridor	ADA	$898.66	$898.66
127	708950	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	2	CALIFORNIA: The baby changing table is not compliant.	Basement Level Men's Restroom RR-3 Lower Lobby	State of California	$1,427.08	$1,427.08
128	708985	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	2	CALIFORNIA: The baby changing table is not compliant.	Basement Level Women's Restroom RR-3 Lower Lobby	State of California	$1,427.08	$1,427.08
129	708995	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Attorney Interview Offices	ADA	$2,875.72	$2,875.72
130	709022	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Clerk's Office for Department 62 and 63	ADA	$1,294.08	$1,294.08
131	709021	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Clerk's Office for Department 60 and 61	ADA	$1,294.08	$1,294.08
132	709061	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Courtroom Security Office	ADA	$1,294.08	$1,294.08
133	709055	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Protruding Object	2	The restroom circulation path is not free of objects protruding more than 4" from wall in the space between 27" and 80" height above finish floor.	First Floor Courtroom Employee Women's Restroom RR-4	ADA	$718.93	$718.93
134	709989	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Employee Work Areas	Work Surface	2	The work surface is not compliant.	Inner Loop Male Side Employee Counter	ADA	$3,704.31	$3,704.31
135	709077	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Protruding Object	2	The restroom circulation path is not free of objects protruding more than 4" from wall in the space between 27" and 80" height above finish floor.	Courtroom Security Office Unisex Restroom	ADA	$359.47	$359.47
136	709973	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Signage	2	The interior signage does not have compliant visual and tactile characters, with raised or indented characters or symbols.	Booking Intake Area	ADA	$395.41	$395.41
137	709985	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Booking Intake Area	ADA	$1,437.86	$1,437.86
138	710003	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Protruding Object	2	The restroom circulation path is not free of objects protruding more than 4" from wall in the space between 27" and 80" height above finish floor.	Inner Loop Women's Restroom RR-7	ADA	$359.47	$359.47
139	710023	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Inner Loop Common Area	ADA	$1,797.33	$1,797.33
140	710026	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Female Property Conveyor Controls	ADA	$1,797.33	$1,797.33
141	710030	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Male Release Area	ADA	$359.47	$359.47
142	710028	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Male Property Conveyor	ADA	$334.30	$334.30
143	710072	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Kitchen	Kitchen	2	Less than minimum one of each type of operable part is within reach range.	Kitchen	ADA	$2,156.79	$2,156.79
144	710110	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Cafeteria	ADA	$1,294.08	$1,294.08
145	710100	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Protruding Object	2	The restroom circulation path is not free of objects protruding more than 4" from wall in the space between 27" and 80" height above finish floor.	Basement Corridor Women's Restroom RR-5	ADA	$358.03	$358.03
146	710114	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" maximum.	Second Floor Conference Room	ADA	$9,346.10	$9,346.10
147	710103	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Facility Wide.	ADA	$1,797.33	$1,797.33
148	710117	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Common Areas	Assembly Area	2	The assistive listening device is not compliant or is not provided.	Second Floor Conference Room	ADA	$449.33	$449.33
149	710112	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Cafeteria	ADA	$718.93	$718.93
150	710138	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Floor Space	2	The slope of the floor surface is greater than 2% cross or 5% running	Second Floor Men's Restroom and Locker Room	ADA	$980.97	$980.97
151	710992	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Detention/Correctional Facilities	Detention Cell	3	The toilet facilities within the cell are not accessible.	Second Floor East 100 Accessible Pod Typical	ADA	$21,567.93	$21,567.93
152	711011	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Second Floor East Indoor Rec Area Inmate Restroom	ADA	$2,020.20	$2,020.20
153	710997	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	Second Floor East 100 Accessible Pod Drinking Fountain	California Accessibility Code	$4,503.38	$4,503.38
154	711003	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Detention/Correctional Facilities	Detention Cell	3	The toilet facilities within the cell are not accessible.	Holding Cells Floor 2	ADA	$21,567.93	$21,567.93
155	711012	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Second Floor East Indoor Rec Area Inmate Restroom	ADA	$21,567.93	$21,567.93
156	711054	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	Visiting Areas Floors 3-8 Typical	California Accessibility Code	$161,759.47	$161,759.47
157	711066	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Medical Facility	Accessible Route	3	CALIFORNIA - Compliant clearances are not provided in the exam room.	3rd Floor Medical Exam Room	California Accessibility Code	$179.73	$179.73
158	711081	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Indoor Rec Restrooms Floors 3-8 Typical	ADA	$15,528,908.86	$15,528,908.86
159	711537	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	Visiting Areas on Mezzanines	California Accessibility Code	$80,879.73	$80,879.73
160	711072	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Detention/Correctional Facilities	Detention Cell	3	Less than 3% of the detention cells are mobility cells.	Housing Cells Floors 3-8	ADA	$15,528,908.86	$15,528,908.86
161	711079	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Indoor Rec Restrooms Floors 3-8 Typical	ADA	$2,020.20	$2,020.20
162	708902	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	Basement Interview Room 3	California Accessibility Code	$13,479.96	$13,479.96

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
163	708924	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	Basement Interview Rooms, 1-8 Public Side	California Accessibility Code	$13,479.96	$13,479.96
164	708941	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	Basement Drinking Fountain DF-3	California Accessibility Code	$4,503.38	$4,503.38
165	709979	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Booking Intake Area Arrestee Unisex Restroom RR-5	ADA	$638.41	$638.41
166	709983	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Booking Intake Area Arrestee Unisex Restroom RR-5	California Accessibility Code	$359.47	$359.47
167	709978	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Booking Intake Area Arrestee Unisex Restroom RR-5	California Accessibility Code	$1,977.06	$1,977.06
168	709982	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	Booking Intake Area Arrestee Unisex Restroom RR-5	California Accessibility Code	$5,391.98	$5,391.98
169	709977	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Booking Intake Area Arrestee Unisex Restroom RR-5	ADA	$1,132.32	$1,132.32
170	709981	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Booking Intake Area Arrestee Unisex Restroom RR-5	California Accessibility Code	$0.00	$0.00
171	709980	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	Controls on dispensers are not compliant.	Booking Intake Area Arrestee Unisex Restroom RR-5	ADA	$898.66	$898.66
172	710061	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	Court Holding Cell 8 (Accessible)	California Accessibility Code	$13,479.96	$13,479.96
173	710060	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Detention/Correctional Facilities	Detention Cell	3	The toilet facilities within the cell are not accessible.	Court Holding Cell 8 (Accessible)	ADA	$21,567.93	$21,567.93
174	710076	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Kitchen Inmate Restroom RR-2	ADA	$21,567.93	$21,567.93
175	710081	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	Laundry room	California Accessibility Code	$4,503.38	$4,503.38
176	710079	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The drinking fountain is not located completely within alcoves, positioned completely between wing walls, or otherwise positioned so as not to encroach into pedestrian ways.	Laundry room	California Accessibility Code	$6,755.08	$6,755.08
177	710083	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Laundry Room Inmate Restroom RR-1, 2 & 3	ADA	$64,703.79	$64,703.79
178	710077	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Kitchen Inmate Restroom RR-2	ADA	$21,567.93	$21,567.93
179	710107	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Signage	3	Means of egress signage is not provided.	Facility Wide	ADA	$1,581.65	$1,581.65
180	726062	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Elevator	3	CALIFORNIA: An elevator is required but not provided.	Basement Holding Cells to First Floor Courtrooms	California Accessibility Code	$143,786.19	$143,786.19
181	735752	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Detention/Correctional Facilities	Detention Cell	3	CALIFORNIA: Less than 2% of the detention cells are communication cells.	Facility Wide	California Accessibility Code	$69,646.44	$69,646.44
182	726190	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: A shower seat is not provided or is not compliant.	Second Floor Shower in POD 100 (Accessible)	California Accessibility Code	$1,086.48	$1,086.48
183	736898	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The controls, faucets, and shower spray unit are not compliant.	Second Floor Shower in POD 100 (Accessible)	California Accessibility Code	$1,168.98	$1,168.98
184	726192	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Elevator	3	CALIFORNIA: An elevator is required but not provided.	Floors 3-8 Main Floor to Mezzanine Visitor Rooms	California Accessibility Code	$143,786.19	$143,786.19
185	710943	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The push side of the door does not have the required maneuvering clearances.	Second Floor Women's Restroom and Locker Room	ADA	$179.73	$179.73
186	710947	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The wheelchair stall door is not self closing.	Second Floor Women's Restroom and Locker Room	ADA	$526.26	$526.26
187	710951	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$898.66	$898.66
188	710955	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	The lavatory is mounted higher than 34" to the higher of the rim or counter.	Second Floor Women's Restroom and Locker Room	ADA	$1,294.08	$1,294.08
189	710959	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: The controls, faucets, and shower spray unit are not compliant.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$1,168.98	$1,168.98
190	710972	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Second Floor Medical Staff Unisex Restroom	California Accessibility Code	$197.71	$197.71
191	710976	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Second Floor Medical Psychiatric Staff Unisex Restroom	California Accessibility Code	$197.71	$197.71
192	710942	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Second Floor Women's Restroom and Locker Room	ADA	$657.82	$657.82
193	710946	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Second Floor Women's Restroom and Locker Room	ADA	$657.82	$657.82
194	710950	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a wheelchair stall in a multi-stall restroom does not have the required clearance.	Second Floor Women's Restroom and Locker Room	ADA	$2,458.74	$2,458.74
195	710954	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$718.93	$718.93
196	710958	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Second Floor Women's Restroom and Locker Room	ADA	$116.83	$116.83
197	710962	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Coat Hook	3	The coat hook is not within an allowable reach range.	Second Floor Women's Restroom and Locker Room	ADA	$359.47	$359.47
198	710966	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	CALIFORNIA: The accessible route from the restroom entry to accessible compartments is not compliant.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$862.72	$862.72
199	710971	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Second Floor Medical Staff Unisex Restroom	California Accessibility Code	$197.71	$197.71
200	710941	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Second Floor Women's Restroom and Locker Room	ADA	$657.82	$657.82
201	710945	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Second Floor Women's Restroom and Locker Room	ADA	$657.82	$657.82
202	710953	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Toilet Stall	3	The rear grab bar in the wheelchair stall is not compliant.	Second Floor Women's Restroom and Locker Room	ADA	$638.05	$638.05

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
203	710957	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Second Floor Women's Restroom and Locker Room	ADA	$359.47	$359.47
204	710961	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	CALIFORNIA: A transfer shower stall is provided instead of a standard roll-in shower or alternate roll-in shower stall.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$12,906.61	$12,906.61
205	710965	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Locker and Dressing Rooms	Locker and Dressing Rooms	3	The locker room does not have accessible lockers.	Second Floor Women's Restroom and Locker Room	ADA	$4,748.40	$4,748.40
206	710970	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Second Floor Medical Staff Unisex Restroom	ADA	$21,567.93	$21,567.93
207	710939	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$197.71	$197.71
208	710944	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor Women's Restroom and Locker Room	ADA	$179.73	$179.73
209	710948	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The hardware at the wheelchair stall door is not compliant.	Second Floor Women's Restroom and Locker Room	ADA	$526.26	$526.26
210	710952	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$503.25	$503.25
211	710956	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$1,294.08	$1,294.08
212	710960	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: A shower seat is not provided or is not compliant.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$1,086.48	$1,086.48
213	710964	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	CALIFORNIA: The accessible route from the restroom entry to accessible compartments is not compliant.	Second Floor Women's Restroom and Locker Room	California Accessibility Code	$862.72	$862.72
214	710978	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Second Floor Medical Psychiatric Staff Unisex Restroom	ADA	$2,020.20	$2,020.20
215	710986	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Second Floor Medical Nurses Station Medical Side	ADA	$21,567.93	$21,567.93
216	711000	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Second Floor East Control Unisex Restroom	ADA	$21,567.93	$21,567.93
217	710984	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Second Floor Medical Nurses Station Medical Side Unisex Restroom	California Accessibility Code	$197.71	$197.71
218	710998	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Second Floor East Control Unisex Restroom	California Accessibility Code	$197.71	$197.71
219	710979	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Second Floor Medical Psychiatric Staff Unisex Restroom	ADA	$21,567.93	$21,567.93
220	711010	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Signage	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	Second Floor East Indoor Rec Area Inmate Restroom	California Accessibility Code	$198.42	$198.42
221	710977	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Second Floor Medical Psychiatric Staff Unisex Restroom	California Accessibility Code	$197.71	$197.71
222	710985	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Second Floor Medical Nurses Station Medical Side Unisex Restroom	ADA	$2,020.20	$2,020.20
223	710999	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Second Floor East Control Unisex Restroom	ADA	$2,020.20	$2,020.20
224	711060	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	3rd Floor ISU Restroom	ADA	$638.41	$638.41
225	711064	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	3rd Floor ISU Restroom	California Accessibility Code	$1,078.40	$1,078.40
226	711057	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	3rd Floor ISU Restroom	California Accessibility Code	$197.71	$197.71
227	711061	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	3rd Floor ISU Restroom	ADA	$638.41	$638.41
228	711065	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	3rd Floor ISU Restroom	ADA	$359.47	$359.47
229	711058	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	3rd Floor ISU Restroom	California Accessibility Code	$179.73	$179.73
230	711062	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	The lavatory does not have the required clear floor space of minimum 30" by minimum 48".	3rd Floor ISU Restroom	ADA	$179.73	$179.73
231	711059	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	3rd Floor ISU Restroom	ADA	$1,132.32	$1,132.32
232	711063	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	3rd Floor ISU Restroom	California Accessibility Code	$1,294.08	$1,294.08
233	711067	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	3rd Floor Medical Exam Room	ADA	$21,567.93	$21,567.93
234	711077	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Indoor Rec Restrooms Floors 3-8 Typical	California Accessibility Code	$3,163.30	$3,163.30
235	711548	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	3rd Floor Psych Services Unisex Restroom	ADA	$179.73	$179.73
236	711552	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	3rd Floor Psych Services Unisex Restroom	ADA	$638.41	$638.41
237	711556	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Clear floor space is not provided.	3rd Floor Psych Services Unisex Restroom	ADA	$179.73	$179.73
238	711560	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	3rd Floor Elevator Lobby Unisex Restroom	ADA	$21,567.93	$21,567.93
239	708869	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	First Floor - Men's Restroom RR-1	ADA	$657.82	$657.82
240	711547	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	3rd Floor Psych Services Unisex Restroom	California Accessibility Code	$197.71	$197.71
241	711551	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	3rd Floor Psych Services Unisex Restroom	California Accessibility Code	$503.25	$503.25
242	711555	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	The lavatory does not have the required knee clearance.	3rd Floor Psych Services Unisex Restroom	ADA	$1,294.08	$1,294.08

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
243	711559	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	3rd Floor Elevator Lobby Unisex Restroom	California Accessibility Code	$197.71	$197.71
244	708868	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	First Floor - Men's Restroom RR-1	ADA	$98.85	$98.85
245	711540	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Control Staff Restrooms Floors 3-8 Typical	California Accessibility Code	$593.12	$593.12
246	711549	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	3rd Floor Psych Services Unisex Restroom	California Accessibility Code	$2,458.74	$2,458.74
247	711553	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	3rd Floor Psych Services Unisex Restroom	ADA	$638.41	$638.41
248	711557	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	3rd Floor Psych Services Unisex Restroom	ADA	$359.47	$359.47
249	711541	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Control Staff Restrooms Floors 3-8 Typical	ADA	$129,407.57	$129,407.57
250	711550	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	3rd Floor Psych Services Unisex Restroom	California Accessibility Code	$1,078.40	$1,078.40
251	711554	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	3rd Floor Psych Services Unisex Restroom	ADA	$2,458.74	$2,458.74
252	708862	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Exterior Access Route	Signage	3	Means of egress signage is not provided.	Door D-3 & D-4	ADA	$98.85	$98.85
253	708871	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	The lavatory is mounted higher than 34" to the higher of the rim or counter.	First Floor - Men's Restroom RR-1	ADA	$1,294.08	$1,294.08
254	708875	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	First Floor - Men's Restroom RR-1	California Accessibility Code	$503.25	$503.25
255	708870	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	First Floor - Men's Restroom RR-1	ADA	$657.82	$657.82
256	708874	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Urinal	3	The urinal dimensions are not compliant.	First Floor - Men's Restroom RR-1	ADA	$1,680.86	$1,680.86
257	708878	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	First Floor - Men's Restroom RR-1	California Accessibility Code	$1,797.33	$1,797.33
258	708882	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	First Floor - Women's Restroom RR-2	ADA	$657.82	$657.82
259	708886	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	First Floor - Women's Restroom RR-2	ADA	$562.56	$562.56
260	708890	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	First Floor - Women's Restroom RR-2	California Accessibility Code	$718.93	$718.93
261	708899	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Signage	3	Means of egress signage is not provided.	Door Exit to Lobby Area	ADA	$98.85	$98.85
262	708872	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	First Floor - Men's Restroom RR-1	California Accessibility Code	$1,294.08	$1,294.08
263	708876	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	First Floor - Men's Restroom RR-1	ADA	$638.41	$638.41
264	708880	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	First Floor - Women's Restroom RR-2	ADA	$98.85	$98.85
265	708884	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	First Floor - Women's Restroom RR-2	ADA	$116.83	$116.83
266	708888	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	First Floor - Women's Restroom RR-2	ADA	$638.41	$638.41
267	708892	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	First Floor - Women's Restroom RR-2	ADA	$359.47	$359.47
268	708907	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Basement Maintenance Restroom RR-1	ADA	$657.82	$657.82
269	708879	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	First Floor - Men's Restroom RR-1	California Accessibility Code	$359.47	$359.47
270	708883	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	The lavatory is mounted higher than 34" to the higher of the rim or counter.	First Floor - Women's Restroom RR-2	ADA	$1,294.08	$1,294.08
271	708887	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	First Floor - Women's Restroom RR-2	ADA	$638.41	$638.41
272	708905	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Basement Maintenance Restroom RR-1	California Accessibility Code	$197.71	$197.71
273	708910	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Urinal	3	The urinal dimensions are not compliant.	Basement Maintenance Restroom RR-1	ADA	$1,680.86	$1,680.86
274	708914	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	CALIFORNIA: A transfer shower stall is provided instead of a standard roll-in shower or alternate roll-in shower stall.	Basement Maintenance Restroom RR-1	California Accessibility Code	$12,906.61	$12,906.61
275	708873	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	First Floor - Men's Restroom RR-1	ADA	$116.83	$116.83
276	708877	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	First Floor - Men's Restroom RR-1	ADA	$638.41	$638.41
277	708881	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	First Floor - Women's Restroom RR-2	ADA	$657.82	$657.82
278	708885	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	First Floor - Women's Restroom RR-2	California Accessibility Code	$1,977.06	$1,977.06
279	708889	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	First Floor - Women's Restroom RR-2	California Accessibility Code	$1,797.33	$1,797.33
280	708908	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Basement Maintenance Restroom RR-1	ADA	$657.82	$657.82
281	708909	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Toilet Stall	3	A wheelchair stall is not provided in a multi-user restroom.	Basement Maintenance Restroom RR-1	ADA	$4,942.65	$4,942.65

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
282	708913	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Basement Maintenance Restroom RR-1	ADA	$359.47	$359.47
283	708927	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Basement Court Intake Room Unisex Restroom RR-2	California Accessibility Code	$197.71	$197.71
284	708932	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Basement Court Intake Room Unisex Restroom RR-2	California Accessibility Code	$503.25	$503.25
285	708936	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	Basement Court Intake Room Unisex Restroom RR-2	California Accessibility Code	$5,391.98	$5,391.98
286	708911	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Basement Maintenance Restroom RR-1	California Accessibility Code	$359.47	$359.47
287	708915	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Locker and Dressing Rooms	Bench	3	CALIFORNIA - The bench is not compliant in the locker room or dressing room.	Basement Maintenance Locker Room	California Accessibility Code	$809.52	$809.52
288	708930	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Basement Court Intake Room Unisex Restroom RR-2	ADA	$657.82	$657.82
289	708934	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Basement Court Intake Room Unisex Restroom RR-2	California Accessibility Code	$1,797.33	$1,797.33
290	708938	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Basement Court Intake Room Unisex Restroom RR-2	ADA	$116.83	$116.83
291	708943	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	Basement Level Men's Restroom RR-3 Lower Lobby	California Accessibility Code	$198.42	$198.42
292	708947	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Basement Level Men's Restroom RR-3 Lower Lobby	California Accessibility Code	$1,797.33	$1,797.33
293	708912	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Lavatory	3	Pipes are not insulated.	Basement Maintenance Restroom RR-1	ADA	$116.83	$116.83
294	708916	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Employee Work Areas	Locker Rooms	3	The locker room does not have accessible lockers.	Basement Maintenance Locker Room	ADA	$593.55	$593.55
295	708922	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Signage	3	Means of egress signage is not provided.	Basement	ADA	$988.53	$988.53
296	708931	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Basement Court Intake Room Unisex Restroom RR-2	California Accessibility Code	$179.73	$179.73
297	708935	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Basement Court Intake Room Unisex Restroom RR-2	California Accessibility Code	$359.47	$359.47
298	708944	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Basement Level Men's Restroom RR-3 Lower Lobby	ADA	$657.82	$657.82
299	708948	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Basement Level Men's Restroom RR-3 Lower Lobby	California Accessibility Code	$359.47	$359.47
300	708929	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Basement Court Intake Room Unisex Restroom RR-2	ADA	$657.82	$657.82
301	708933	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The push side of the door does not have the required maneuvering clearances.	Basement Court Intake Room Unisex Restroom RR-2	ADA	$179.73	$179.73
302	708937	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Basement Court Intake Room Unisex Restroom RR-2	ADA	$359.47	$359.47
303	708946	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Basement Level Men's Restroom RR-3 Lower Lobby	ADA	$116.83	$116.83
304	708954	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a wheelchair stall in a multi-stall restroom does not have the required clearance.	Basement Level Men's Restroom RR-3 Lower Lobby	ADA	$2,458.74	$2,458.74
305	708945	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	The lavatory is mounted higher than 34" to the higher of the rim or counter.	Basement Level Men's Restroom RR-3 Lower Lobby	ADA	$1,294.08	$1,294.08
306	708949	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Basement Level Men's Restroom RR-3 Lower Lobby	ADA	$359.47	$359.47
307	708953	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The toilet stall door is not compliant.	Basement Level Men's Restroom RR-3 Lower Lobby	California Accessibility Code	$1,977.06	$1,977.06
308	708957	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Basement Level Men's Restroom RR-3 Lower Lobby	ADA	$638.41	$638.41
309	708981	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	The lavatory is mounted higher than 34" to the higher of the rim or counter.	Basement Level Women's Restroom RR-3 Lower Lobby	ADA	$1,294.08	$1,294.08
310	708989	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a wheelchair stall in a multi-stall restroom does not have the required clearance.	Basement Level Women's Restroom RR-3 Lower Lobby	ADA	$2,458.74	$2,458.74
311	708952	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	Basement Level Men's Restroom RR-3 Lower Lobby	California Accessibility Code	$526.62	$526.62
312	708956	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Basement Level Men's Restroom RR-3 Lower Lobby	California Accessibility Code	$503.25	$503.25
313	708980	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Basement Level Women's Restroom RR-3 Lower Lobby	ADA	$657.82	$657.82
314	708984	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Basement Level Women's Restroom RR-3 Lower Lobby	ADA	$359.47	$359.47
315	708988	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The toilet stall door is not compliant.	Basement Level Women's Restroom RR-3 Lower Lobby	California Accessibility Code	$1,977.06	$1,977.06
316	708992	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Basement Level Women's Restroom RR-3 Lower Lobby	ADA	$638.41	$638.41
317	708998	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Judges' Chambers Department 60 Unisex Restroom	California Accessibility Code	$197.71	$197.71
318	708951	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Toilet Stall	3	The wheelchair stall door is not self closing.	Basement Level Men's Restroom RR-3 Lower Lobby	ADA	$526.26	$526.26
319	708955	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The coat hook is not within an allowable reach range.	Basement Level Men's Restroom RR-3 Lower Lobby	ADA	$206.69	$206.69
320	708979	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Basement Level Women's Restroom RR-3 Lower Lobby	ADA	$657.82	$657.82

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
321	708983	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Basement Level Women's Restroom RR-3 Lower Lobby	California Accessibility Code	$359.47	$359.47
322	708987	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The hardware at the wheelchair stall door is not compliant.	Basement Level Women's Restroom RR-3 Lower Lobby	ADA	$526.26	$526.26
323	708991	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Basement Level Women's Restroom RR-3 Lower Lobby	California Accessibility Code	$503.25	$503.25
324	708982	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Basement Level Women's Restroom RR-3 Lower Lobby	California Accessibility Code	$1,797.33	$1,797.33
325	708986	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Toilet Stall	3	The wheelchair stall door is not self closing.	Basement Level Women's Restroom RR-3 Lower Lobby	ADA	$526.26	$526.26
326	708990	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Basement Level Women's Restroom RR-3 Lower Lobby	California Accessibility Code	$2,458.74	$2,458.74
327	709001	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Judges' Chambers Department 60 Unisex Restroom	ADA	$638.41	$638.41
328	709005	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Judge's Chambers Department 62 Restroom	California Accessibility Code	$197.71	$197.71
329	709000	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Judges' Chambers Department 60 Unisex Restroom	ADA	$657.82	$657.82
330	709009	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Judge's Chambers Department 62 Restroom	ADA	$562.56	$562.56
331	709013	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Judge's Chambers Department 62 Restroom	California Accessibility Code	$503.25	$503.25
332	709018	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Judge's Chambers Department 61 Restroom	ADA	$638.41	$638.41
333	709027	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Judge's Chambers Department 63 Restroom	ADA	$638.41	$638.41
334	709032	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	First Floor Courtroom Employee Men's Restroom RR-3	ADA	$657.82	$657.82
335	709008	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Judge's Chambers Department 62 Restroom	California Accessibility Code	$2,458.74	$2,458.74
336	709012	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Judge's Chambers Department 62 Restroom	ADA	$116.83	$116.83
337	709017	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Judge's Chambers Department 61 Restroom	ADA	$657.82	$657.82
338	709026	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Judge's Chambers Department 63 Restroom	ADA	$657.82	$657.82
339	709030	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	First Floor Courtroom Employee Men's Restroom RR-3	California Accessibility Code	$198.42	$198.42
340	709035	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	First Floor Courtroom Employee Men's Restroom RR-3	ADA	$2,458.74	$2,458.74
341	709039	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	First Floor Courtroom Employee Men's Restroom RR-3	California Accessibility Code	$359.47	$359.47
342	709002	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Judges' Chambers Department 60 Unisex Restroom	California Accessibility Code	$359.47	$359.47
343	709007	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Judge's Chambers Department 62 Restroom	ADA	$657.82	$657.82
344	709011	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Judge's Chambers Department 62 Restroom	California Accessibility Code	$1,078.40	$1,078.40
345	709015	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Judge's Chambers Department 61 Restroom	California Accessibility Code	$197.71	$197.71
346	709020	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Judge's Chambers Department 61 Restroom	ADA	$116.83	$116.83
347	709025	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Judge's Chambers Department 63 Restroom	ADA	$657.82	$657.82
348	709029	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Judge's Chambers Department 63 Restroom	ADA	$116.83	$116.83
349	709034	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The threshold at the accessible door is greater than ½" in height.	First Floor Courtroom Employee Men's Restroom RR-3	ADA	$321.72	$321.72
350	709038	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	First Floor Courtroom Employee Men's Restroom RR-3	California Accessibility Code	$1,797.33	$1,797.33
351	709036	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	First Floor Courtroom Employee Men's Restroom RR-3	ADA	$638.41	$638.41
352	709040	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	First Floor Courtroom Employee Men's Restroom RR-3	ADA	$359.47	$359.47
353	709046	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	First Floor Courtroom Employee Women's Restroom RR-4	ADA	$657.82	$657.82
354	709050	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	First Floor Courtroom Employee Women's Restroom RR-4	ADA	$638.41	$638.41
355	709054	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	First Floor Courtroom Employee Women's Restroom RR-4	California Accessibility Code	$718.93	$718.93
356	709058	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	First Floor Courtroom Employee Women's Restroom RR-4	California Accessibility Code	$1,294.08	$1,294.08
357	709062	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Employee Work Areas	Locker Rooms	3	The locker room does not have accessible lockers.	Courtroom Security Office	ADA	$593.55	$593.55
358	709066	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	Courtroom Security Office Unisex Restroom	ADA	$98.85	$98.85

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
359	709070	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The threshold at the accessible door is greater than ½" in height.	Courtroom Security Office Unisex Restroom	ADA	$321.72	$321.72
360	709010	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Judge's Chambers Department 62 Restroom	ADA	$638.41	$638.41
361	709014	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Judge's Chambers Department 60 Restroom	ADA	$116.83	$116.83
362	709019	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Judge's Chambers Department 61 Restroom	California Accessibility Code	$359.47	$359.47
363	709023	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Judge's Chambers Department 63 Restroom	California Accessibility Code	$197.71	$197.71
364	709028	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Judge's Chambers Department 63 Restroom	California Accessibility Code	$359.47	$359.47
365	709033	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	First Floor Courtroom Employee Men's Restroom RR-3	ADA	$657.82	$657.82
366	709037	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	First Floor Courtroom Employee Men's Restroom RR-3	ADA	$638.41	$638.41
367	709041	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	First Floor Courtroom Employee Men's Restroom RR-3	California Accessibility Code	$1,294.08	$1,294.08
368	709047	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	First Floor Courtroom Employee Women's Restroom RR-4	ADA	$657.82	$657.82
369	709044	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	First Floor Courtroom Employee Women's Restroom RR-4	California Accessibility Code	$197.71	$197.71
370	709049	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	First Floor Courtroom Employee Women's Restroom RR-4	ADA	$2,458.74	$2,458.74
371	709053	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	First Floor Courtroom Employee Women's Restroom RR-4	California Accessibility Code	$1,797.33	$1,797.33
372	709057	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	First Floor Courtroom Employee Women's Restroom RR-4	California Accessibility Code	$5,391.98	$5,391.98
373	709065	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Courtroom Security Office Unisex Restroom	California Accessibility Code	$197.71	$197.71
374	709069	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Courtroom Security Office Unisex Restroom	ADA	$657.82	$657.82
375	709073	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Courtroom Security Office Unisex Restroom	ADA	$638.41	$638.41
376	709051	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	First Floor Courtroom Employee Women's Restroom RR-4	ADA	$638.41	$638.41
377	709059	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	First Floor Courtroom Employee Women's Restroom RR-4	ADA	$116.83	$116.83
378	709067	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Courtroom Security Office Unisex Restroom	ADA	$898.66	$898.66
379	709071	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	Courtroom Security Office Unisex Restroom	ADA	$2,458.74	$2,458.74
380	709075	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Courtroom Security Office Unisex Restroom	California Accessibility Code	$1,797.33	$1,797.33
381	709079	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Courtroom Security Office Unisex Restroom	ADA	$359.47	$359.47
382	709042	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	First Floor Courtroom Employee Men's Restroom RR-3	ADA	$116.83	$116.83
383	709048	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The threshold at the accessible door is greater than ½" in height.	First Floor Courtroom Employee Women's Restroom RR-4	ADA	$321.72	$321.72
384	709052	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	First Floor Courtroom Employee Women's Restroom RR-4	California Accessibility Code	$898.66	$898.66
385	709056	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	First Floor Courtroom Employee Women's Restroom RR-4	ADA	$359.47	$359.47
386	709064	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Common Areas	Locker Rooms	3	The locker room does not have a compliant bench.	Courtroom Security Office	ADA	$808.80	$808.80
387	709068	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Courtroom Security Office Unisex Restroom	ADA	$657.82	$657.82
388	709072	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Courtroom Security Office Unisex Restroom	ADA	$638.41	$638.41
389	709076	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Courtroom Security Office Unisex Restroom	California Accessibility Code	$718.93	$718.93
390	709074	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	Courtroom Security Office Unisex Restroom	California Accessibility Code	$898.66	$898.66
391	709078	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	Courtroom Security Office Unisex Restroom	California Accessibility Code	$5,391.98	$5,391.98
392	709082	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Platform Lift	3	CALIFORNIA: The platform lift is not compliant.	Parking Garage	California Accessibility Code	$40,484.80	$40,484.80
393	709986	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Booking Intake Room 3 Employee Restroom RR-6	ADA	$21,567.93	$21,567.93
394	709993	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Inner Loop Women's Restroom RR-7	ADA	$657.82	$657.82
395	709080	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Courtroom Security Office Unisex Restroom	ADA	$116.83	$116.83
396	709991	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Door	3	The door has less than 32" clear width.	Inner Loop Women's Restroom RR-7	ADA	$2,020.20	$2,020.20
397	709996	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Inner Loop Women's Restroom RR-7	ADA	$638.41	$638.41

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
398	710000	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Inner Loop Women's Restroom RR-7	California Accessibility Code	$1,294.08	$1,294.08
399	709971	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The drinking fountain is not located completely within alcoves, positioned completely between wing walls, or otherwise positioned so as not to encroach into pedestrian ways.	First Floor Inner Loop Drinking Fountain DF-3	California Accessibility Code	$6,755.08	$6,755.08
400	709975	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Booking Intake Area Arrestee Unisex Restroom RR-5	California Accessibility Code	$197.71	$197.71
401	709990	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	Inner Loop Women's Restroom RR-7	ADA	$98.85	$98.85
402	709995	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Inner Loop Women's Restroom RR-7	ADA	$562.56	$562.56
403	709999	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	Inner Loop Women's Restroom RR-7	California Accessibility Code	$5,391.98	$5,391.98
404	709994	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Inner Loop Women's Restroom RR-7	ADA	$179.73	$179.73
405	709998	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Inner Loop Women's Restroom RR-7	California Accessibility Code	$1,977.06	$1,977.06
406	710002	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Inner Loop Women's Restroom RR-7	California Accessibility Code	$1,437.86	$1,437.86
407	710006	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	Inner Loop Men's Restroom RR-8	ADA	$98.85	$98.85
408	710011	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Inner Loop Men's Restroom RR-8	California Accessibility Code	$2,458.74	$2,458.74
409	710015	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Inner Loop Men's Restroom RR-8	California Accessibility Code	$1,977.06	$1,977.06
410	710020	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Inner Loop Men's Restroom RR-8	ADA	$116.83	$116.83
411	709997	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Inner Loop Women's Restroom RR-7	ADA	$638.41	$638.41
412	710001	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Inner Loop Women's Restroom RR-7	ADA	$116.83	$116.83
413	710010	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Inner Loop Men's Restroom RR-8	ADA	$179.73	$179.73
414	710014	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Inner Loop Men's Restroom RR-8	ADA	$638.41	$638.41
415	710008	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Inner Loop Men's Restroom RR-8	ADA	$657.82	$657.82
416	710012	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Inner Loop Men's Restroom RR-8	ADA	$562.56	$562.56
417	710016	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Inner Loop Men's Restroom RR-8	California Accessibility Code	$1,294.08	$1,294.08
418	710021	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Inner Loop Men's Restroom RR-8	California Accessibility Code	$1,078.40	$1,078.40
419	710036	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	Second Floor Admin Unisex Restroom RR-1	ADA	$98.85	$98.85
420	710040	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor Admin Unisex Restroom RR-1	ADA	$2,246.66	$2,246.66
421	710045	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Second Floor Admin Unisex Restroom RR-1	ADA	$562.56	$562.56
422	710004	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Inner Loop Women's Restroom RR-7	ADA	$359.47	$359.47
423	710009	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Inner Loop Men's Restroom RR-8	ADA	$657.82	$657.82
424	710013	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Inner Loop Men's Restroom RR-8	ADA	$638.41	$638.41
425	710022	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Inner Loop Men's Restroom RR-8	ADA	$359.47	$359.47
426	710041	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Urinal	3	The urinal dimensions are not compliant.	Second Floor Admin Unisex Restroom RR-1	ADA	$1,680.86	$1,680.86
427	710046	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Second Floor Admin Unisex Restroom RR-1	California Accessibility Code	$1,294.08	$1,294.08
428	710039	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Second Floor Admin Unisex Restroom RR-1	ADA	$657.82	$657.82
429	710043	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Second Floor Admin Unisex Restroom RR-1	California Accessibility Code	$1,977.06	$1,977.06
430	710048	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Second Floor Admin Unisex Restroom RR-1	California Accessibility Code	$1,437.86	$1,437.86
431	710052	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor Admin Lactation Room	ADA	$179.73	$179.73
432	710056	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Second Floor Admin Lactation Room	California Accessibility Code	$359.47	$359.47
433	710038	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Second Floor Admin Unisex Restroom RR-1	ADA	$657.82	$657.82
434	710042	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Urinal	3	CALIFORNIA - Flush control is not compliant.	Second Floor Admin Unisex Restroom RR-1	California Accessibility Code	$999.31	$999.31
435	710047	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Second Floor Admin Unisex Restroom RR-1	ADA	$116.83	$116.83
436	710051	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Second Floor Admin Lactation Room	ADA	$657.82	$657.82

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
437	710055	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Second Floor Admin Lactation Room	ADA	$116.83	$116.83
438	710067	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Basement Level Court Control Unisex Restroom	ADA	$21,567.93	$21,567.93
439	710049	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Second Floor Admin Unisex Restroom RR-1	ADA	$359.47	$359.47
440	710053	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Floor Space	3	The required turning space within the restroom is not provided.	Second Floor Admin Lactation Room	ADA	$179.73	$179.73
441	710057	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Second Floor Admin Lactation Room	ADA	$359.47	$359.47
442	710065	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Basement Level Court Control Unisex Restroom	California Accessibility Code	$197.71	$197.71
443	710069	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Basement Level Court Control Unisex Restroom	ADA	$657.82	$657.82
444	710074	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Kitchen Staff Unisex Restroom	ADA	$21,567.93	$21,567.93
445	710087	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	Basement Corridor Women's Restroom RR-5	California Accessibility Code	$197.71	$197.71
446	710050	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	Second Floor Admin Lactation Room	ADA	$98.85	$98.85
447	710054	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Second Floor Admin Lactation Room	California Accessibility Code	$1,294.08	$1,294.08
448	710066	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Basement Level Court Control Unisex Restroom	ADA	$2,020.20	$2,020.20
449	710071	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Kitchen	Sink	3	CALIFORNIA: The sink does not have the required clear floor space of minimum 30" by minimum 48" for a forward approach with knee and toe clearance.	Kitchen	California Accessibility Code	$16,175.95	$16,175.95
450	710075	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	Kitchen Men's Restrooms	California Accessibility Code	$396.85	$396.85
451	710088	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Basement Corridor Women's Restroom RR-5	ADA	$657.82	$657.82
452	710068	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Basement Level Court Control Unisex Restroom	ADA	$657.82	$657.82
453	710073	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Kitchen Staff Unisex Restroom	California Accessibility Code	$197.71	$197.71
454	710082	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Laundry Room Inmate Restroom RR-1, 2 & 3	California Accessibility Code	$593.12	$593.12
455	710086	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Basement Corridor Men's Restroom RR-4	ADA	$21,567.93	$21,567.93
456	710090	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The push side of the door does not have the required maneuvering clearances.	Basement Corridor Women's Restroom RR-5	ADA	$14,378.62	$14,378.62
457	710094	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Basement Corridor Women's Restroom RR-5	California Accessibility Code	$503.25	$503.25
458	710098	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Basement Corridor Women's Restroom RR-5	ADA	$116.83	$116.83
459	710085	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	Basement Corridor Men's Restroom RR-4	California Accessibility Code	$198.42	$198.42
460	710089	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Basement Corridor Women's Restroom RR-5	ADA	$657.82	$657.82
461	710093	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Basement Corridor Women's Restroom RR-5	ADA	$562.56	$562.56
462	710097	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Basement Corridor Women's Restroom RR-5	California Accessibility Code	$1,078.40	$1,078.40
463	710101	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Basement Corridor Women's Restroom RR-5	ADA	$638.41	$638.41
464	710120	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$198.42	$198.42
465	710092	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Basement Corridor Women's Restroom RR-5	California Accessibility Code	$2,458.74	$2,458.74
466	710096	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Basement Corridor Women's Restroom RR-5	California Accessibility Code	$898.66	$898.66
467	710119	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Common Areas	Dining And Work Surface	3	CALIFORNIA: A compliant picnic table is not provided.	Second Floor Outdoor Courtyard	California Accessibility Code	$2,336.53	$2,336.53
468	710124	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The push side of the door does not have the required maneuvering clearances.	Second Floor Men's Restroom and Locker Room	ADA	$179.73	$179.73
469	710128	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor Men's Restroom and Locker Room	ADA	$2,246.66	$2,246.66
470	710091	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Basement Corridor Women's Restroom RR-5	California Accessibility Code	$1,977.06	$1,977.06
471	710095	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	Basement Corridor Women's Restroom RR-5	California Accessibility Code	$503.25	$503.25
472	710099	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Basement Corridor Women's Restroom RR-5	ADA	$359.47	$359.47
473	710123	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Second Floor Men's Restroom and Locker Room	ADA	$657.82	$657.82
474	710127	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Ambulatory Stall	3	The ambulatory stall size is not compliant, or an ambulatory stall is not provided.	Second Floor Men's Restroom and Locker Room	ADA	$2,458.74	$2,458.74

No.	Id	Facility	Barrier Group	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
475	710122	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Second Floor Men's Restroom and Locker Room	ADA	$179.73	$179.73
476	710126	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	CALIFORNIA: The accessible route from the restroom entry to accessible compartments is not compliant.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$862.72	$862.72
477	710130	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a wheelchair stall in a multi-stall restroom does not have the required clearance.	Second Floor Men's Restroom and Locker Room	ADA	$2,458.74	$2,458.74
478	710134	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$1,294.08	$1,294.08
479	710145	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom	3	CALIFORNIA: The accessible route from the restroom entry to accessible compartments is not compliant.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$1,078.40	$1,078.40
480	710131	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$898.66	$898.66
481	710135	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$359.47	$359.47
482	710139	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: The controls, faucets, and shower spray unit are not compliant.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$1,168.98	$1,168.98
483	739208	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	First Floor Inner Loop Drinking Fountain DF-3	California Accessibility Code	$4,503.38	$4,503.38
484	710132	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Second Floor Men's Restroom and Locker Room	ADA	$638.41	$638.41
485	710136	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Second Floor Men's Restroom and Locker Room	ADA	$116.83	$116.83
486	710142	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Locker and Dressing Rooms	Bench	3	CALIFORNIA - The bench is not compliant in the locker room or dressing room.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$809.52	$809.52
487	710125	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Second Floor Men's Restroom and Locker Room	ADA	$657.82	$657.82
488	710129	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Coat Hook	3	The coat hook is not within an allowable reach range.	Second Floor Men's Restroom and Locker Room	ADA	$206.69	$206.69
489	710133	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$526.62	$526.62
490	710137	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: A shower seat is not provided or is not compliant.	Second Floor Men's Restroom and Locker Room	California Accessibility Code	$1,086.48	$1,086.48
491	710143	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Locker and Dressing Rooms	Locker and Dressing Rooms	3	The locker room does not have accessible lockers.	Second Floor Men's Restroom and Locker Room	ADA	$9,496.79	$9,496.79
492	726191	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Restroom	Restroom/Bathroom-Coat Hook	3	The coat hook is not within an allowable reach range.	Second Floor Shower in POD 100 (Accessible)	ADA	$206.69	$206.69
493	711009	Sacramento County Main Jail	MAYS LAWSUIT BARRIERS	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Second Floor East 200 Pods Typical	California Accessibility Code	$4,493.32	$4,493.32
494	710995	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Second Floor East 100 Accessible Pods Typical	California Accessibility Code	$898.66	$898.66
495	711025	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	3rd Floor Public Visitor Side	California Accessibility Code	$3,594.65	$3,594.65
496	711052	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Public Visitor Side Floors 3-8 Typical	California Accessibility Code	$21,567.93	$21,567.93
497	708921	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Facility	California Accessibility Code	$269,599.11	$269,599.11
498	710080	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Drinking Fountain/Water Cooler	4	The location of the spout of the wheelchair height drinking fountain is not compliant.	Laundry room	ADA	$0.00	$0.00
499	710105	Sacramento County Main Jail	NON MAYS LAWSUIT BARRIERS	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Pharmacy Call Button	California Accessibility Code	$898.66	$898.66