No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1	713971	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Accessible Route to Engraving and South Side of Admin Building	ADA	$107.84	$107.84
2	713975	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Access to Ramp R-5	ADA	$142.52	$142.52
3	725564	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Dorm A & B Door D-1 & D-4	California Accessibility Code	$0.00	$0.00
4	720951	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Ramp To Culinary Arts Building	California Accessibility Code	$0.00	$0.00
5	722660	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Minimum Security Side East of Dorm H	ADA	$107.84	$107.84
6	730127	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Portable Restroom	Portable Restroom	1	An accessible route to the portable restroom has not been provided.	Greenhouse Portable Restroom	ADA	$1,610.41	$1,610.41
7	722778	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Dorm G, H, J & K Entrance Doors (Typical Findings)	California Accessibility Code	$0.00	$0.00
8	722787	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: A ramp is required but not provided.	Dorm G, H, J & K Rec Yard Doors (Typical Findings)	CBC	$23,796.61	$23,796.61
9	720948	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings are not compliant.	Ramp To Culinary Arts Building	California Accessibility Code	$17,577.86	$17,577.86
10	720952	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Ramp To Culinary Arts Building	ADA	$71.26	$71.26
11	720960	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	The threshold at the accessible door is greater than ½" in height.	Culinary Arts Building Door D-9	ADA	$322.08	$322.08
12	720941	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Accessible Route to SLF Classrooms 1 & 2	ADA	$570.08	$570.08
13	745737	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp at Classroom 1 Entrance	California Accessibility Code	$13,088.14	$13,088.14
14	720978	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Ramp at Classroom 2 Entrance	California Accessibility Code	$17,847.46	$17,847.46
15	745738	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings are not compliant.	Ramp at Classroom 1 Entrance	California Accessibility Code	$9,960.79	$9,960.79
16	720995	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Ramp at Classroom 1 Entrance	California Accessibility Code	$17,847.46	$17,847.46
17	717881	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Egress Route through SLF Kinya Dorm Courtyard	ADA	$106.89	$106.89
18	717929	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	SLF Door D-6	California Accessibility Code	$2,246.66	$2,246.66
19	717953	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	SLF Door D-8	ADA	$2,246.66	$2,246.66
20	717933	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	SLF Door D-7	ADA	$2,246.66	$2,246.66
21	717962	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Accessible Route Golden Poppy Rec to Psych Building	ADA	$213.78	$213.78
22	745739	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp at Classroom 2 Entrance	California Accessibility Code	$13,088.14	$13,088.14
23	745740	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings are not compliant.	Ramp at Classroom 2 Entrance	California Accessibility Code	$9,960.79	$9,960.79
24	717756	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Accessible Route to SLF from Asphalt Path	ADA	$213.78	$213.78
25	717900	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	SLF Kinya Dorm Door D-5	California Accessibility Code	$2,246.66	$2,246.66
26	717926	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Accessible Route to Rec Area Egress Route Golden Poppy	ADA	$213.78	$213.78
27	717951	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	The threshold at the accessible door is greater than 1/2 inch in height.	SLF Door D-8	IBC	$321.72	$321.72
28	725733	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Dorm M Door D-4	California Accessibility Code	$2,246.66	$2,246.66
29	725757	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Sports Fields	California Accessibility Code	$1,781.51	$1,781.51
30	725759	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has an unstable surface.	Accessible Route to Sports Fields	California Accessibility Code	$12,078.04	$12,078.04
31	716148	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	CBF Pod Cells	ADA	$14,019.15	$14,019.15
32	716259	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Head Room	1	The height of the interior accessible route is less than 80" AFF.	All Pods JKF KBF	ADA	$1,308.45	$1,308.45
33	716272	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Head Room	1	The height of the interior accessible route is less than 80" AFF.	All Pods SBF CBF	ADA	$5,233.82	$5,233.82
34	717787	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	SLF Lobby Visitor's Room	ADA	$4,673.05	$4,673.05

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
35	717810	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	CALIFORNIA: The width of the aisle is not compliant.	SLF Property Room	California Accessibility Code	$179.73	$179.73
36	717840	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Exercise Equipment	1	Clear floor space is not provided at the transfer point to the exercise equipment.	SLF Interior Spaces	ADA	$718.93	$718.93
37	717949	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The threshold at the accessible door is greater than ½" in height.	SLF Dorm Entry Doors at Golden Poppy, Kinya and Camellia Dorms	ADA	$966.24	$966.24
38	717956	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	SLF Ramona Cells Doors	ADA	$4,673.05	$4,673.05
39	737128	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Ramp	1	CALIFORNIA: The interior ramp railings are not compliant.	Medical Housing Unit Inmate Restroom RR-2	California Accessibility Code	$3,515.57	$3,515.57
40	725712	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	Medical Housing Unit Holding Cells	ADA	$4,673.05	$4,673.05
41	725747	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Ramp	1	The ramp running slope exceeds 1:12 (8.33%).	M Dorm Restroom RR-3	ADA	$7,143.30	$7,143.30
42	725748	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Ramp	1	CALIFORNIA: The interior ramp railings are not compliant.	M Dorm Restroom RR-3	California Accessibility Code	$3,515.57	$3,515.57
43	717789	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	SLF Lobby Professional Interview Room	ADA	$4,673.05	$4,673.05
44	717811	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	A compliant turning space is not provided at the change of direction.	SLF Property Room	ADA	$179.73	$179.73
45	717944	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The threshold at the accessible door is greater than ½" in height.	SLF Interior Doors in Golden Poppy and Camellia Dorms	ADA	$644.16	$644.16
46	725705	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	Medical Housing Unit	ADA	$37,384.41	$37,384.41
47	725725	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Ramp	1	The ramp running slope exceeds 1:12 (8.33%).	Medical Housing Unit Inmate Restroom RR-2	ADA	$7,143.30	$7,143.30
48	713826	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car stall slope is greater than 1:48 (2.08%).	Accessible Parking Space P1-A	California Accessibility Code	$11,323.16	$11,323.16
49	713830	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car stall slope is greater than 1:48 (2.08%).	Accessible Parking Space P1-B	California Accessibility Code	$11,323.16	$11,323.16
50	713834	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car parking stall markings are not compliant.	Accessible Parking Space P1-C	California Accessibility Code	$754.88	$754.88
51	713838	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-General	1	Accessible parking spaces are not at the nearest accessible entrance.	Parking Lot P1	ADA	$3,019.51	$3,019.51
52	713842	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp - Parallel	1	CALIFORNIA: The parallel curb ramp does not have a compliant detectable warning on the landing at the bottom of the curb ramp.	Curb Ramp CR-1	California Accessibility Code	$1,207.80	$1,207.80
53	713846	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The parallel curb ramp is not compliant, or is required but not provided.	Curb Ramp CR-2	California Accessibility Code	$3,145.32	$3,145.32
54	713850	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The parallel curb ramp is not compliant, or is required but not provided.	Curb Ramp CR-3	California Accessibility Code	$3,145.32	$3,145.32
55	713855	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp run does not have a compliant detectable warning.	Curb Ramp CR-4	California Accessibility Code	$1,207.80	$1,207.80
56	713859	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Gate House Door D-1	California Accessibility Code	$2,246.66	$2,246.66
57	713827	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car parking stall markings are not compliant.	Accessible Parking Space P1-A	California Accessibility Code	$754.88	$754.88
58	713831	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car parking stall markings are not compliant.	Accessible Parking Space P1-B	California Accessibility Code	$754.88	$754.88
59	713835	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car aisle markings are not compliant.	Accessible Parking Space P1-C	California Accessibility Code	$754.88	$754.88
60	713839	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Van	1	CALIFORNIA: A van space and adjacent van aisle are not provided.	Parking Lot P1	California Accessibility Code	$1,509.76	$1,509.76
61	713843	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Curb Ramp CR-1 to CR-2	California Accessibility Code	$9,406.38	$9,406.38
62	713847	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	The adjacent surfaces at transitions to adjoining walks, gutters and streets at the curb ramp are not at the same level.	Curb Ramp CR-2	ADA	$89.87	$89.87
63	713851	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Curb Ramp CR-3 to Gate House	ADA	$641.34	$641.34
64	713856	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp has non-compliant slopes.	Curb Ramp CR-4	California Accessibility Code	$3,145.32	$3,145.32
65	713828	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car parking aisle slope is greater than 1:48 (2.08%).	Accessible Parking Space P1-A	California Accessibility Code	$8,986.64	$8,986.64
66	713832	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car stall slope is greater than 1:48 (2.08%).	Accessible Parking Space P1-C	California Accessibility Code	$11,323.16	$11,323.16
67	713836	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car stall slope is greater than 1:48 (2.08%).	Accessible Parking Space P1-D	California Accessibility Code	$11,323.16	$11,323.16

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
68	713840	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Exterior Accessible Route	1	CALIFORNIA: The accessible route is located so that the disabled user is compelled to walk or wheel behind parked vehicles other than his or her own vehicle.	Parking Lot P1	California Accessibility Code	$3,019.51	$3,019.51
69	713844	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Curb Ramp CR-1 to CR-2	ADA	$641.34	$641.34
70	713848	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route from Curb Ramp CR-2 to Curb Ramp CR-3	California Accessibility Code	$898.66	$898.66
71	713852	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Curb Ramp CR-3 to Gate House	California Accessibility Code	$7,054.78	$7,054.78
72	713857	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Visitors Exiting Route at Gate House	California Accessibility Code	$7,482.35	$7,482.35
73	713829	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car aisle markings are not compliant.	Accessible Parking Space P1-A	California Accessibility Code	$754.88	$754.88
74	713833	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car parking aisle slope is greater than 1:48 (2.08%).	Accessible Parking Space P1-C	California Accessibility Code	$8,986.64	$8,986.64
75	713837	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car parking stall markings are not compliant.	Accessible Parking Space P1-D	California Accessibility Code	$754.88	$754.88
76	713841	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	From Accessible Parking Spaces in Parking Lot P1 to Curb Ramp CR-1	California Accessibility Code	$4,043.99	$4,043.99
77	713845	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp - Parallel	1	CALIFORNIA: The parallel curb ramp does not have a compliant detectable warning on the landing at the bottom of the curb ramp.	Curb Ramp CR-2	California Accessibility Code	$1,207.80	$1,207.80
78	713849	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp - Parallel	1	CALIFORNIA: The parallel curb ramp does not have a compliant detectable warning on the landing at the bottom of the curb ramp.	Curb Ramp CR-3	California Accessibility Code	$1,207.80	$1,207.80
79	713854	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Curb Ramp CR-3 to Gate House	California Accessibility Code	$9,620.16	$9,620.16
80	713860	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Gate House Door D-1	California Accessibility Code	$657.82	$657.82
81	713889	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Door D2 to Front of Gate House	California Accessibility Code	$7,054.78	$7,054.78
82	713909	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Gate House Door D-3	California Accessibility Code	$657.82	$657.82
83	713917	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the accessible route.	Accessible Route at North Side of Gate House	ADA	$1,308.45	$1,308.45
84	713922	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route from Door D-3 to Curb Ramp CR-6	ADA	$142.52	$142.52
85	713926	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp has non-compliant slopes.	Curb Ramp CR-7	California Accessibility Code	$3,145.32	$3,145.32
86	713930	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp is less than 48" wide.	Ramp R-1	California Accessibility Code	$9,518.65	$9,518.65
87	713910	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Gate House Door D-3	ADA	$657.82	$657.82
88	713914	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Gate House Gate G-2	ADA	$2,247.38	$2,247.38
89	713919	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Gate G-2	ADA	$2,247.38	$2,247.38
90	713923	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	The adjacent surfaces at transitions to adjoining walks, gutters and streets at the curb ramp are not at the same level.	Curb Ramp CR-6	ADA	$89.87	$89.87
91	713927	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route from Curb Ramp CR-7 to Admin Building	California Accessibility Code	$2,494.12	$2,494.12
92	713932	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Stair ST-1	California Accessibility Code	$253.06	$253.06
93	713936	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car aisle markings are not compliant.	Accessible Parking Space P2-A	California Accessibility Code	$754.88	$754.88
94	713940	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp is less than 48" wide.	Ramp R-2	California Accessibility Code	$22,606.78	$22,606.78
95	713945	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route on the North Side of the Admin Building	California Accessibility Code	$5,985.88	$5,985.88

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
96	713949	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Parking Lot P2 to Admin Building	California Accessibility Code	$1,207.80	$1,207.80
97	713953	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp R-3	California Accessibility Code	$808.80	$808.80
98	713958	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Accessible Route to Multi-Purpose Mod	ADA	$213.78	$213.78
99	713962	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Stair ST-3	California Accessibility Code	$316.33	$316.33
100	713966	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Ramp R-4	California Accessibility Code	$53,542.38	$53,542.38
101	713915	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route at North Side of Gate House	ADA	$855.13	$855.13
102	713920	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp run does not have a compliant detectable warning.	Curb Ramp CR-6	California Accessibility Code	$1,207.80	$1,207.80
103	713924	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	The adjacent surfaces at transitions to adjoining walks, gutters and streets at the curb ramp are not at the same level.	Curb Ramp CR-7	ADA	$89.87	$89.87
104	713928	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Access to Ramp R-1	California Accessibility Code	$1,207.80	$1,207.80
105	713912	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Gate House Door D-3	California Accessibility Code	$2,246.66	$2,246.66
106	713916	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route at North Side of Gate House	California Accessibility Code	$5,772.10	$5,772.10
107	713921	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp has non-compliant slopes.	Curb Ramp CR-6	California Accessibility Code	$3,145.32	$3,145.32
108	713925	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp - Parallel	1	CALIFORNIA: The parallel curb ramp does not have a compliant detectable warning on the landing at the bottom of the curb ramp.	Curb Ramp CR-7	California Accessibility Code	$1,207.80	$1,207.80
109	713929	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp R-1	California Accessibility Code	$7,138.98	$7,138.98
110	713934	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: Signage is not provided at the standard accessible space, or the existing signage is not compliant.	Accessible Parking Space P2-A & P2-B	California Accessibility Code	$1,006.50	$1,006.50
111	713938	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car parking stall markings are not compliant.	Accessible Parking Space P2-C	California Accessibility Code	$754.88	$754.88
112	713942	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route on the North Side of the Admin Building	California Accessibility Code	$2,137.81	$2,137.81
113	713947	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-General	1	Accessible parking spaces are not at the nearest accessible entrance.	Parking Lot P2	ADA	$4,529.27	$4,529.27
114	713951	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Stair ST-2	California Accessibility Code	$253.06	$253.06
115	713955	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	West Side of Admin Building Maintenance Vehicle Area	California Accessibility Code	$1,207.80	$1,207.80
116	713960	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Multi-Purpose Mod	California Accessibility Code	$2,137.81	$2,137.81
117	713972	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Accessible Route to Engraving and South Side of Admin Building	California Accessibility Code	$1,207.80	$1,207.80
118	713976	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Ramp R-5	California Accessibility Code	$35,694.92	$35,694.92
119	714004	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Multi-Purpose Mod JPS Door D-4	California Accessibility Code	$657.82	$657.82
120	713937	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car parking stall markings are not compliant.	Accessible Parking Space P2-B	California Accessibility Code	$754.88	$754.88
121	713941	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Ramp R-2	California Accessibility Code	$0.00	$0.00
122	713946	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: Signage is not provided at the standard accessible space, or the existing signage is not compliant.	Accessible Parking Space P2-C	California Accessibility Code	$503.25	$503.25
123	713950	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Parking Lot P2 to Admin Building	California Accessibility Code	$3,741.17	$3,741.17
124	713954	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp R-3	California Accessibility Code	$178.15	$178.15

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
125	713959	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Multi-Purpose Mod	California Accessibility Code	$1,282.69	$1,282.69
126	713968	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Route to Stair ST-5	California Accessibility Code	$1,207.80	$1,207.80
127	713964	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: A warning curb is not provided on a walkway where the walkway edge is more than 4" above the adjacent surface.	Accessible Route to Multi-Purpose Mod	California Accessibility Code	$1,725.43	$1,725.43
128	713969	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Stair ST-4	California Accessibility Code	$442.86	$442.86
129	713974	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp R-5	California Accessibility Code	$7,138.98	$7,138.98
130	713978	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Southeast Side of Admin Building at Door D-7	ADA	$356.30	$356.30
131	713992	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Multi-Purpose Mod Education Door D-3	ADA	$657.82	$657.82
132	713935	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: The car parking stall markings are not compliant.	Accessible Parking Space P2-A	California Accessibility Code	$754.88	$754.88
133	713939	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	An access aisle is not provided.	Accessible Parking Space P2-C	ADA	$754.88	$754.88
134	713943	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp R-2	California Accessibility Code	$5,949.15	$5,949.15
135	713948	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Parking Lot P2 to Admin Building	California Accessibility Code	$391.93	$391.93
136	713952	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Stair ST-2	California Accessibility Code	$6,445.22	$6,445.22
137	713957	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route on the West Side of the Admin Building	California Accessibility Code	$5,807.73	$5,807.73
138	713961	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Admin Building to Locker Rooms	California Accessibility Code	$2,246.66	$2,246.66
139	713965	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Multi-Purpose Mod	California Accessibility Code	$2,137.81	$2,137.81
140	714578	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Admin Building Door D-1	California Accessibility Code	$657.82	$657.82
141	714582	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Admin Building Door D-2	ADA	$427.56	$427.56
142	714586	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Admin Building Door D-2	ADA	$657.82	$657.82
143	714590	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Admin Building Door D-3	California Accessibility Code	$2,246.66	$2,246.66
144	713973	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to Engraving and South Side of Admin Building	ADA	$213.78	$213.78
145	713977	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to Engraving and South Side of Admin Building	ADA	$427.56	$427.56
146	714575	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Admin Building Door D-1	ADA	$570.08	$570.08
147	714576	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Admin Building Door D-1	California Accessibility Code	$4,493.32	$4,493.32
148	714592	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Admin Building Door D-3	ADA	$657.82	$657.82
149	714596	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Admin Building Door D-4	ADA	$106.89	$106.89
150	714600	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Admin Building Door D-4	ADA	$657.82	$657.82
151	713979	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Multi-Purpose Mod Door D-1	ADA	$657.82	$657.82
152	714003	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Multi-Purpose Mod JPS Door D-4	ADA	$657.82	$657.82
153	714577	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Admin Building Door D-1	ADA	$657.82	$657.82
154	714589	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Admin Building Door D-3	ADA	$106.89	$106.89
155	714593	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Admin Building Door D-3	California Accessibility Code	$657.82	$657.82

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
156	714597	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Admin Building Door D-4	California Accessibility Code	$2,246.66	$2,246.66
157	714601	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Admin Building Door D-4	California Accessibility Code	$657.82	$657.82
158	714583	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Admin Building Door D-2	California Accessibility Code	$2,246.66	$2,246.66
159	714587	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Admin Building Door D-2	California Accessibility Code	$657.82	$657.82
160	714714	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	South End of Passage Hallway Stair ST-6	California Accessibility Code	$1,202.05	$1,202.05
161	725561	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Booking Entrance Door D-6	California Accessibility Code	$657.82	$657.82
162	725565	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Dorm A & B Door D-1 & D-4	ADA	$657.82	$657.82
163	725558	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Booking Entrance Door D-6	California Accessibility Code	$3,145.32	$3,145.32
164	725562	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route is less than 48" wide.	Accessible Route to Dorm A & B	California Accessibility Code	$9,406.38	$9,406.38
165	725566	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Dorm A & B Door D-1 & D-4	California Accessibility Code	$0.00	$0.00
166	725605	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	RBF Door D-2	California Accessibility Code	$3,145.32	$3,145.32
167	725631	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	RBF Control Entry Door D-4	California Accessibility Code	$3,145.32	$3,145.32
168	725644	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$3,741.17	$3,741.17
169	725649	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$10,724.70	$10,724.70
170	725653	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Minimum Security Circulation Path	ADA	$962.02	$962.02
171	725606	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	RBF Door D-2	ADA	$657.82	$657.82
172	730011	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Gate to Honor Facility Classrooms	ADA	$2,247.38	$2,247.38
173	730015	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	Stairs have open risers.	Honor Facility Classrooms Stair ST-1	ADA	$1,509.76	$1,509.76
174	730019	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Honor Facility Classrooms Ramp R-1	California Accessibility Code	$71,389.84	$71,389.84
175	725632	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	RBF Control Entry Door D-4	ADA	$657.82	$657.82
176	725641	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Minimum Security Circulation Path Gate 41	ADA	$2,247.38	$2,247.38
177	725645	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Minimum Security Circulation Path	ADA	$356.30	$356.30
178	725650	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Booking Release Door D-7	California Accessibility Code	$3,145.32	$3,145.32
179	725654	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$4,703.19	$4,703.19
180	730012	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Gate to Honor Facility Classrooms	ADA	$2,247.38	$2,247.38
181	730016	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Honor Facility Classrooms Stair ST-1	California Accessibility Code	$316.33	$316.33
182	730020	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp is less than 48" wide.	Honor Facility Classrooms Ramp R-1	California Accessibility Code	$0.00	$0.00
183	730028	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Honor Facility Classroom Door D-2	ADA	$657.82	$657.82
184	730031	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Honor Facility Classroom Door-2	ADA	$2,246.66	$2,246.66
185	730062	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	In areas along the route there are level changes of 1/2" or greater that are not ramped.	Accessible Route to Honor Facility Back Classroom.	ADA	$997.65	$997.65
186	730066	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	BC Walkway From Gate 26 to Gate 9	ADA	$427.56	$427.56

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
187	725507	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	An accessible route does not connect accessible building or facility entrances with all accessible spaces and elements within the building or facility. At least one accessible route shall connect accessible elements that are on the same site.	Accessible Route from Admin Building to Gate 41 and Bookings	ADA	$7,189.31	$7,189.31
188	730065	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Honor Facility Back Classroom Ramp R-2	California Accessibility Code	$17,847.46	$17,847.46
189	730072	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Van	1	CALIFORNIA: A van space and adjacent van aisle are not provided.	Parking Lot P4	California Accessibility Code	$1,509.76	$1,509.76
190	730087	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	DGS Maintenance Shop Door D-2	California Accessibility Code	$3,145.32	$3,145.32
191	730100	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	DGS Plumbing Shop D-4	ADA	$657.82	$657.82
192	730104	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Pharmacy Packaging Entrance Door D-6	California Accessibility Code	$2,246.66	$2,246.66
193	730074	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	DGS Electrical Shop Door D-1	California Accessibility Code	$3,145.32	$3,145.32
194	730088	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	DGS Maintenance Shop Door D-2	ADA	$657.82	$657.82
195	730097	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	DGS Plumbing Shop D-4	California Accessibility Code	$2,246.66	$2,246.66
196	730101	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	The push side of the accessible door does not have the required maneuvering clearances.	DGS Plumbing Shop D-4	ADA	$179.73	$179.73
197	730112	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Welding Shop Door D-7	ADA	$657.82	$657.82
198	730120	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Welding Office Door D-8	California Accessibility Code	$3,145.32	$3,145.32
199	730129	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Auto Shop Door D-9	California Accessibility Code	$3,145.32	$3,145.32
200	725555	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Booking Entrance Door D-5	California Accessibility Code	$3,145.32	$3,145.32
201	725559	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Booking Entrance Door D-6	ADA	$657.82	$657.82
202	725563	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: A warning curb is not provided on a walkway where the walkway edge is more than 4" above the adjacent surface.	Accessible Route to Dorm A & B	California Accessibility Code	$345.09	$345.09
203	725568	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Dorm A & B Control Room Door D-2 & D-3	California Accessibility Code	$3,145.32	$3,145.32
204	730113	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Welding Shop Door D-7	California Accessibility Code	$657.82	$657.82
205	730126	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	An accessible route does not connect accessible building or facility entrances with all accessible spaces and elements within the building or facility. At least one accessible route shall connect accessible elements that are on the same site.	Welding Classroom to Auto Shop	ADA	$6,283.46	$6,283.46
206	725508	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Booking Entrance Door D-4	California Accessibility Code	$3,145.32	$3,145.32
207	730149	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Greenhouse Interior	ADA	$2,137.81	$2,137.81
208	730153	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Honor Facility Classroom Door D-3	ADA	$657.82	$657.82
209	730162	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Gatehouse Door D-4	California Accessibility Code	$657.82	$657.82
210	743778	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp landing is not level. The slope of the curb ramp landing exceeds the maximum allowable 1:48 (2.08%).	Curb Ramp CR-4	California Accessibility Code	$2,316.76	$2,316.76
211	720942	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to SLF Classrooms 1 & 2	California Accessibility Code	$1,140.17	$1,140.17
212	720946	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to Culinary Arts Building	ADA	$427.56	$427.56
213	720950	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a rise in excess of 30".	Ramp To Culinary Arts Building	ADA	$45,213.57	$45,213.57
214	730146	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	An accessible route does not connect accessible building or facility entrances with all accessible spaces and elements within the building or facility. At least one accessible route shall connect accessible elements that are on the same site.	From Main Facility to Greenhouse.	ADA	$6,283.46	$6,283.46
215	730150	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Honor Facility Classroom Door D-3	California Accessibility Code	$3,145.32	$3,145.32
216	730159	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Gatehouse Door D-4	California Accessibility Code	$2,246.66	$2,246.66
217	743779	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp landing is not level. The slope of the curb ramp landing exceeds the maximum allowable 1:48 (2.08%).	Curb Ramp CR-6	California Accessibility Code	$2,316.76	$2,316.76

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
218	720943	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route is less than 48" wide.	Accessible Route to SLF Classrooms 1 & 2	California Accessibility Code	$7,126.04	$7,126.04
219	720947	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Culinary Arts Building	California Accessibility Code	$4,275.63	$4,275.63
220	725607	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	RBF Door D-2	California Accessibility Code	$657.82	$657.82
221	720958	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	SFL Stair ST-2	California Accessibility Code	$316.33	$316.33
222	720970	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	Stairs have open risers.	Stair ST-3 Culinary Arts Building Inmate Side	ADA	$6,039.02	$6,039.02
223	720981	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	SLF Classroom 2 Entrance Door	California Accessibility Code	$3,145.32	$3,145.32
224	720985	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	SLF Classroom 2 Entrance Door	ADA	$0.00	$0.00
225	725556	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Booking Entrance Door D-5	ADA	$657.82	$657.82
226	720982	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Classroom 2 Entrance Door	ADA	$657.82	$657.82
227	720999	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	SLF Classroom 1 Entrance Door D-1	California Accessibility Code	$3,145.32	$3,145.32
228	721008	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Psych Building	California Accessibility Code	$712.60	$712.60
229	721015	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Psych Entrance Door D-10	ADA	$657.82	$657.82
230	725633	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	RBF Control Entry Door D-4	California Accessibility Code	$657.82	$657.82
231	725646	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$3,563.02	$3,563.02
232	725651	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Booking Release Door D-7	ADA	$657.82	$657.82
233	725655	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	RBF Medical Staff Office Door D-5	California Accessibility Code	$3,145.32	$3,145.32
234	721000	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	SLF Ramp at Classroom 1 Entrance	ADA	$0.00	$0.00
235	721010	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	SFL Psych Building Gate G-5	ADA	$2,247.38	$2,247.38
236	721054	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Psych Entrance Door D-11	California Accessibility Code	$3,145.32	$3,145.32
237	721059	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Chaplains Office	California Accessibility Code	$898.66	$898.66
238	721063	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a rise in excess of 30".	Ramp to Chaplains Office	ADA	$0.00	$0.00
239	721060	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to Chaplains Office	ADA	$285.04	$285.04
240	721064	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp is less than 48" wide.	Ramp to Chaplains Office	California Accessibility Code	$0.00	$0.00
241	721081	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Entrance Door to Vehicle Wash Shed	California Accessibility Code	$1,214.99	$1,214.99
242	721103	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route from Admin Building to Redemption Coffee	ADA	$249.41	$249.41
243	721107	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Entrance Door to Redemption Coffee	California Accessibility Code	$657.82	$657.82
244	730013	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: A warning curb is not provided on a walkway where the walkway edge is more than 4" above the adjacent surface.	Accessible Route to Honor Facility Classrooms	California Accessibility Code	$517.63	$517.63
245	730017	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Honor Facility Classrooms Stair ST-1	California Accessibility Code	$3,515.57	$3,515.57
246	725618	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	RBF Door D-3	California Accessibility Code	$3,145.32	$3,145.32
247	725643	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Minimum Security Circulation Path Gate 41	ADA	$2,247.38	$2,247.38
248	725647	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Minimum Security Circulation Path Gate 23	ADA	$2,247.38	$2,247.38
249	725656	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	RBF Medical Staff Office Door D-5	ADA	$657.82	$657.82

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
250	721076	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door has less than 80" head clearance (excluding closer).	Facilities Trades Operations Office Entrance Door	ADA	$4,673.05	$4,673.05
251	721082	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Medical Intake Trailer	California Accessibility Code	$1,348.00	$1,348.00
252	721086	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Platform Lift to Medical Trailer	ADA	$287.57	$287.57
253	721104	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the accessible route.	Redemption Coffee Service Counter	ADA	$1,308.45	$1,308.45
254	730014	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Honor Facility Classrooms	California Accessibility Code	$6,413.44	$6,413.44
255	730018	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings are not compliant.	Honor Facility Classrooms Ramp R-1	California Accessibility Code	$29,296.44	$29,296.44
256	721183	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Reentry Services Entrance Door D-3	California Accessibility Code	$657.82	$657.82
257	722589	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Route to Flagpole	ADA	$0.00	$0.00
258	721149	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Reentry Services Entrance Door D-1	ADA	$106.89	$106.89
259	730063	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Honor Facility Back Classroom Ramp R-2	California Accessibility Code	$13,088.14	$13,088.14
260	722623	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Rec Building Door D-3	California Accessibility Code	$2,246.66	$2,246.66
261	722628	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Rec Building Door D-4	California Accessibility Code	$2,246.66	$2,246.66
262	721178	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Reentry Services Entrance Door D-2	ADA	$657.82	$657.82
263	721184	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Reentry Services Entrance Door D-3	ADA	$106.89	$106.89
264	730068	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Gate 35	ADA	$2,247.38	$2,247.38
265	730075	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	DGS Electrical Shop Door D-1	ADA	$657.82	$657.82
266	730084	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	The push side of the accessible door does not have the required maneuvering clearances.	DGS Restroom RR-1	ADA	$2,246.66	$2,246.66
267	730089	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	DGS Maintenance Shop Door D-2	California Accessibility Code	$657.82	$657.82
268	730098	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	DGS Plumbing Shop D-4	California Accessibility Code	$179.73	$179.73
269	730022	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Honor Facility Classroom Door D-1	ADA	$657.82	$657.82
270	730030	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Honor Facility Classroom Door D-2	ADA	$106.89	$106.89
271	722616	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Rec Building Door D-2	ADA	$657.82	$657.82
272	722620	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Rec Building Door D-2	ADA	$179.73	$179.73
273	722624	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Rec Building Door D-3	California Accessibility Code	$1,214.99	$1,214.99
274	722629	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Rec Building Door D-4	California Accessibility Code	$1,214.99	$1,214.99
275	722638	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Dorms G, H, J, K, Typical Findings	ADA	$0.00	$0.00
276	722669	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Laundry Building Door D-1	California Accessibility Code	$657.82	$657.82
277	722678	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Laundry Building Door D-3	ADA	$657.82	$657.82
278	722640	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Dorms G, H, J, K, Typical Findings	ADA	$0.00	$0.00
279	722697	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Kitchen Office	California Accessibility Code	$9,620.16	$9,620.16
280	722701	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Kitchen Door D-1	California Accessibility Code	$657.82	$657.82
281	730064	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings are not compliant.	Honor Facility Back Classroom Ramp R-2	California Accessibility Code	$7,617.07	$7,617.07

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
282	730071	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	ADVISORY: A marked crosswalk is not provided where the accessible route crosses a vehicular way between the accessible parking aisle and the building entrance.	Gate 35 to Auto Shop & Welding Shop	ADA	$0.00	$0.00
283	730076	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	DGS Electrical Shop Door D-1	California Accessibility Code	$657.82	$657.82
284	730085	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route from DGS Electrical Shop to Pharmacy Packaging	California Accessibility Code	$6,290.65	$6,290.65
285	730110	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Welding Shop Door D-7	California Accessibility Code	$3,594.65	$3,594.65
286	722737	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Kitchen Dock Ramp R-1	California Accessibility Code	$59,491.54	$59,491.54
287	722741	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Kitchen Dock Stair ST-1	California Accessibility Code	$316.33	$316.33
288	722679	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Laundry Building Door D-3	California Accessibility Code	$657.82	$657.82
289	722698	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp run does not have a compliant detectable warning.	Gatehouse Curb Ramp CR-5	California Accessibility Code	$1,207.80	$1,207.80
290	722755	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings are not compliant.	Kitchen Cart Ramp R-2	California Accessibility Code	$35,155.72	$35,155.72
291	722763	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Dorms J & K Control Door D-1	California Accessibility Code	$3,145.32	$3,145.32
292	722782	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Dorm G, H, J & K Entrance Doors (Typical Findings)	ADA	$0.00	$0.00
293	730147	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Greenhouse Entrance Door	California Accessibility Code	$3,145.32	$3,145.32
294	730151	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Honor Facility Classroom Door D-3	ADA	$106.89	$106.89
295	743776	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp landing is not level. The slope of the curb ramp landing exceeds the maximum allowable 1:48 (2.08%).	Curb Ramp CR-2	California Accessibility Code	$2,316.76	$2,316.76
296	743780	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp landing is not level. The slope of the curb ramp landing exceeds the maximum allowable 1:48 (2.08%).	Curb Ramp CR-7	California Accessibility Code	$2,316.76	$2,316.76
297	720944	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to SLF Classrooms 1 & 2	ADA	$0.00	$0.00
298	730124	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Welding Classroom Door D-9	California Accessibility Code	$2,246.66	$2,246.66
299	722738	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp is less than 48" wide.	Kitchen Dock Ramp	California Accessibility Code	$0.00	$0.00
300	722742	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	Steps do not have uniform and compliant riser heights and/or tread depths.	Kitchen Dock Stair ST-1	ADA	$4,141.04	$4,141.04
301	722752	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Kitchen Door D-2	California Accessibility Code	$1,214.99	$1,214.99
302	722757	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings are not compliant.	Kitchen Cart Ramp R-3	California Accessibility Code	$35,155.72	$35,155.72
303	722765	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Dorms J & K Control Door D-1	ADA	$657.82	$657.82
304	722779	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Dorm G, H, J & K Entrance Doors (Typical Findings)	California Accessibility Code	$0.00	$0.00
305	722798	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible route has gaps in the surface greater than 1/2" wide.	Booking Door D-8	ADA	$285.04	$285.04
306	720972	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Stair ST-3 Culinary Arts Building Inmate Side	California Accessibility Code	$253.06	$253.06
307	720977	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to SLF Classrooms 1 & 2	ADA	$570.08	$570.08
308	720983	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	SLF Classroom 2 Entrance Door D-1	California Accessibility Code	$657.82	$657.82
309	730148	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Greenhouse Entrance Door	California Accessibility Code	$1,214.99	$1,214.99
310	730152	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Honor Facility Classroom Door D-3	ADA	$183.93	$183.93
311	730161	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Gatehouse Door D-4	ADA	$657.82	$657.82
312	743777	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Curb Ramp	1	CALIFORNIA: The curb ramp landing is not level. The slope of the curb ramp landing exceeds the maximum allowable 1:48 (2.08%).	Curb Ramp CR-3	California Accessibility Code	$2,316.76	$2,316.76
313	722826	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Booking Door D-2	ADA	$657.82	$657.82

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
314	722838	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Booking Door D-3	California Accessibility Code	$3,145.32	$3,145.32
315	746387	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Van	1	CALIFORNIA: A van space and adjacent van aisle are not provided.	Parking Lot P2	California Accessibility Code	$1,509.76	$1,509.76
316	716075	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Admin Staff Dining Courtyard	California Accessibility Code	$8,907.55	$8,907.55
317	716079	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Admin Staff Dining Courtyard Door D-8	ADA	$657.82	$657.82
318	720993	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	SFL Classrooms Gate G-4	ADA	$2,247.38	$2,247.38
319	721001	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Classroom 1 Entrance Door	ADA	$657.82	$657.82
320	721011	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Psych Building	California Accessibility Code	$712.60	$712.60
321	720945	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Culinary Arts Building	California Accessibility Code	$570.08	$570.08
322	720949	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp To Culinary Arts Building	California Accessibility Code	$7,138.98	$7,138.98
323	720953	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Accessible Route to SLF Classrooms 1 & 2	California Accessibility Code	$1,207.80	$1,207.80
324	720961	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Culinary Arts Building Door D-9	ADA	$0.00	$0.00
325	722842	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route To Booking Public Lobby	ADA	$593.12	$593.12
326	746388	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Car	1	CALIFORNIA: A car accessible stall and adjacent aisle are not provided.	Parking Lot P2	California Accessibility Code	$3,019.51	$3,019.51
327	716076	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Admin Staff Dining Courtyard	ADA	$898.66	$898.66
328	716080	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Admin Staff Dining Courtyard Door D-8	California Accessibility Code	$657.82	$657.82
329	721057	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Psych Entrance Door D-11	ADA	$183.93	$183.93
330	721061	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings do not extend 12" horizontally above the landing beyond the top and bottom of the ramp runs and in the same direction of the ramp run.	Ramp to Chaplains Office	California Accessibility Code	$1,171.86	$1,171.86
331	721002	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	SLF Classroom 1 Entrance Door	California Accessibility Code	$657.82	$657.82
332	721013	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Psych Entrance Door D-10	California Accessibility Code	$3,145.32	$3,145.32
333	721058	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Accessible Route to Chaplains Office	California Accessibility Code	$1,207.80	$1,207.80
334	721062	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Ramp to Chaplains Office	California Accessibility Code	$38,074.58	$38,074.58
335	721066	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Stairs to Chaplains Office	California Accessibility Code	$316.33	$316.33
336	721065	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp to Chaplains Office	California Accessibility Code	$5,949.15	$5,949.15
337	721069	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Chaplains Office Entrance Door	ADA	$657.82	$657.82
338	721083	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has an unstable surface.	Accessible Route to Medical Intake Trailer	California Accessibility Code	$1,797.33	$1,797.33
339	721100	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route from Admin Building to Redemption Coffee	California Accessibility Code	$2,246.66	$2,246.66
340	717759	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Accessible Route to FLS	California Accessibility Code	$1,207.80	$1,207.80
341	717764	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-Van	1	CALIFORNIA: A van space and adjacent van aisle are not provided.	Parking Lot P3	California Accessibility Code	$1,509.76	$1,509.76
342	721070	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Chaplains Office Entrance Door	California Accessibility Code	$657.82	$657.82
343	721079	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Access to Vehicle Wash Shed	ADA	$570.08	$570.08

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
344	721084	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Stairs to Medical Intake Trailer	California Accessibility Code	$442.86	$442.86
345	721102	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route from Admin Building to Redemption Coffee	ADA	$1,425.21	$1,425.21
346	717760	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has areas of vertical level changes in excess of 1/4" that are not beveled or ramped.	Accessible Route to SLF	ADA	$213.78	$213.78
347	717765	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Access to SLF Door D-1	California Accessibility Code	$2,494.12	$2,494.12
348	721106	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Entrance Door to Redemption Coffee	ADA	$657.82	$657.82
349	717845	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The threshold at the accessible door is greater than ½" in height.	SLF Door D-2	ADA	$322.08	$322.08
350	717850	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	SLF Door D-3	California Accessibility Code	$2,246.66	$2,246.66
351	717849	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	SLF Door D-3	ADA	$106.89	$106.89
352	721150	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Reentry Services Entrance Door D-1	ADA	$657.82	$657.82
353	717882	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Egress Route through SLF Kinya Dorm Courtyard	California Accessibility Code	$0.00	$0.00
354	717890	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to FLS Rec Office Access	California Accessibility Code	$1,068.91	$1,068.91
355	717894	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route is less than 48" wide.	Accessible Route to FLS Rec Door D-4 to Dock.	California Accessibility Code	$3,420.50	$3,420.50
356	717898	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	SLF Stair ST-1	California Accessibility Code	$3,515.57	$3,515.57
357	717902	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	SLF Kinya Dorm Door D-5	California Accessibility Code	$657.82	$657.82
358	717889	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Accessible Route to FLS Rec Office Access	California Accessibility Code	$1,207.80	$1,207.80
359	717897	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to FLS Rec Door D-4 to Dock	California Accessibility Code	$855.13	$855.13
360	717901	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Kinya Dorm Door D-5	ADA	$657.82	$657.82
361	721146	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Rec Hall Door D-1	California Accessibility Code	$3,145.32	$3,145.32
362	721182	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Reentry Services Entrance Door D-3	ADA	$657.82	$657.82
363	717935	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Door D-7	ADA	$657.82	$657.82
364	717928	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to Rec Area Egress Route Golden Poppy	ADA	$320.67	$320.67
365	721179	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Reentry Services Entrance Door D-2	California Accessibility Code	$657.82	$657.82
366	722587	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Route to Flagpole	California Accessibility Code	$1,207.80	$1,207.80
367	722617	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Rec Building Door D-2	California Accessibility Code	$657.82	$657.82
368	717966	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings do not extend 12" horizontally above the landing beyond the top and bottom of the ramp runs and in the same direction of the ramp run.	Ramp to Psych Building	California Accessibility Code	$1,171.86	$1,171.86
369	717971	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route at Gatehouse	California Accessibility Code	$2,137.81	$2,137.81
370	725657	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	RBF Medical Staff Office Door D-5	California Accessibility Code	$657.82	$657.82
371	725661	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$11,579.82	$11,579.82
372	725666	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	RCCC Warehouse Staff Door D-8	California Accessibility Code	$657.82	$657.82

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
373	717967	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp is less than 48" wide.	Ramp to Psych Building	California Accessibility Code	$42,833.91	$42,833.91
374	717972	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route is less than 48" wide.	Accessible Route at Gatehouse	California Accessibility Code	$2,156.79	$2,156.79
375	725662	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$4,151.83	$4,151.83
376	722588	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route is less than 48" wide.	Route to Flagpole	California Accessibility Code	$6,413.44	$6,413.44
377	722618	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Rec Building Door D-2	California Accessibility Code	$1,214.99	$1,214.99
378	722622	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Rec Building Door D-3	California Accessibility Code	$657.82	$657.82
379	722621	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Rec Building Door D-3	ADA	$657.82	$657.82
380	722626	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Rec Building Door D-4	ADA	$657.82	$657.82
381	722630	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Rec Building Door D-4	ADA	$0.00	$0.00
382	722642	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Dorms G, H, J, K, Typical Findings	California Accessibility Code	$0.00	$0.00
383	722661	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Control Point for Dorms C, D, G, & H	ADA	$356.30	$356.30
384	725694	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	RCCC Warehouse Inmate Door D-9	California Accessibility Code	$3,145.32	$3,145.32
385	725699	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Medical Housing Unit	ADA	$463.19	$463.19
386	725695	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	RCCC Warehouse Inmate Door D-9	ADA	$356.30	$356.30
387	725700	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Medical Housing Unit Door D-1	California Accessibility Code	$3,145.32	$3,145.32
388	722627	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Rec Building Door D-4	California Accessibility Code	$657.82	$657.82
389	722637	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: A warning curb is not provided on a walkway where the walkway edge is more than 4" above the adjacent surface.	Dorms G, H, J, K, Typical Findings	California Accessibility Code	$1,294.08	$1,294.08
390	722643	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Dorms G, H, J, K, Typical Findings	California Accessibility Code	$0.00	$0.00
391	722662	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Control Point for Dorms C, D, G, & H	California Accessibility Code	$890.76	$890.76
392	725715	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Medical Housing Unit Door D-2	California Accessibility Code	$3,145.32	$3,145.32
393	725731	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$1,425.21	$1,425.21
394	725735	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Dorm M Door D-4	California Accessibility Code	$657.82	$657.82
395	725716	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Medical Housing Unit Door D-2	ADA	$657.82	$657.82
396	725732	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Minimum Security Circulation Path	ADA	$2,247.38	$2,247.38
397	725736	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path at Drom M	California Accessibility Code	$5,130.75	$5,130.75
398	722667	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Laundry Building Door D-1	California Accessibility Code	$2,246.66	$2,246.66
399	722694	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	An accessible route does not connect accessible building or facility entrances with all accessible spaces and elements within the building or facility. At least one accessible route shall connect accessible elements that are on the same site.	Accessible Route to Kitchen Office	ADA	$14,378.62	$14,378.62
400	722699	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Kitchen Door D-1	California Accessibility Code	$3,145.32	$3,145.32
401	725755	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$21,199.98	$21,199.98
402	725760	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$2,137.81	$2,137.81

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
403	725764	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	195 Tunnel Walkway	California Accessibility Code	$5,661.58	$5,661.58
404	725768	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$2,494.12	$2,494.12
405	725773	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path Between Barrak D and Dorm M	California Accessibility Code	$4,560.67	$4,560.67
406	722668	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Laundry Building Door D-1	ADA	$657.82	$657.82
407	722672	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Laundry Building Door D-2	California Accessibility Code	$2,246.66	$2,246.66
408	722677	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	Laundry Building Door D-3	California Accessibility Code	$2,246.66	$2,246.66
409	722695	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route to Kitchen Office	California Accessibility Code	$16,175.95	$16,175.95
410	722700	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Kitchen Door D-1	ADA	$657.82	$657.82
411	725752	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path Entering Barracks Area	California Accessibility Code	$1,068.91	$1,068.91
412	725756	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path at Laundry Building	California Accessibility Code	$22,696.45	$22,696.45
413	725761	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	In areas along the route there are level changes of 1/2" or greater that are not ramped.	195 Tunnel Walkway	ADA	$89.87	$89.87
414	725765	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	195 Tunnel Walkway	California Accessibility Code	$6,919.71	$6,919.71
415	725770	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path Between Barracks B & C	California Accessibility Code	$2,494.12	$2,494.12
416	725774	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Minimum Security Circulation Path	ADA	$2,247.38	$2,247.38
417	722739	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a rise in excess of 30".	Kitchen Dock Ramp R-1	ADA	$0.00	$0.00
418	722740	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The exterior ramp railings are not compliant.	Kitchen Dock Ramp R-1	California Accessibility Code	$29,296.44	$29,296.44
419	722743	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	Kitchen Dock Stair ST-1	California Accessibility Code	$5,859.29	$5,859.29
420	722753	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Kitchen Door D-2	ADA	$657.82	$657.82
421	722761	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	Gate between Laundry Building and Kitchen	ADA	$4,494.76	$4,494.76
422	722766	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Dorms J & K Control Door D-1	California Accessibility Code	$657.82	$657.82
423	722780	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Dorm G, H, J & K Entrance Doors (Typical Findings)	California Accessibility Code	$359.47	$359.47
424	722744	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Kitchen Dock	California Accessibility Code	$12,470.58	$12,470.58
425	722754	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Kitchen Door D-2	California Accessibility Code	$657.82	$657.82
426	722797	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Booking Door D-8	California Accessibility Code	$3,145.32	$3,145.32
427	722801	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Booking Door D-8	California Accessibility Code	$657.82	$657.82
428	722788	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Dorm G, H, J & K Rec Yard Doors (Typical Findings)	California Accessibility Code	$0.00	$0.00
429	722800	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Booking Door D-8	ADA	$657.82	$657.82
430	722827	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Booking Door D-2	California Accessibility Code	$657.82	$657.82
431	722839	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Booking Door D-3	ADA	$657.82	$657.82

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
432	722843	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Accessible Route To Booking Public Lobby	California Accessibility Code	$3,384.87	$3,384.87
433	722823	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Booking Door D-2	California Accessibility Code	$3,145.32	$3,145.32
434	722840	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Booking Door D-3	California Accessibility Code	$657.82	$657.82
435	722844	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route To Booking Public Lobby	ADA	$178.15	$178.15
436	716074	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Admin Staff Dining Courtyard	ADA	$1,781.51	$1,781.51
437	716073	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Admin Staff Dining Courtyard	ADA	$2,137.81	$2,137.81
438	716077	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Admin Staff Dining Courtyard Door D-8	California Accessibility Code	$3,145.32	$3,145.32
439	716078	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Admin Staff Dining Courtyard Door D-8	ADA	$0.00	$0.00
440	717757	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Door D-1	ADA	$657.82	$657.82
441	717762	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The detectable warning for areas other than bus stop, reflecting pool, hazardous vehicular area, or track crossing is not compliant.	Accessible Route to FLS	California Accessibility Code	$1,207.80	$1,207.80
442	717761	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to FLS	ADA	$213.78	$213.78
443	717766	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	SLF Door D-1	California Accessibility Code	$657.82	$657.82
444	717848	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route is less than 48" wide.	Accessible Route From Door D-2 To Garden	California Accessibility Code	$21,378.13	$21,378.13
445	717847	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	SLF Door D-2	ADA	$106.89	$106.89
446	717891	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to FLS Rec Office Access	ADA	$427.56	$427.56
447	717895	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route to FLS Rec Door D-4 to Dock	ADA	$0.00	$0.00
448	717899	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	1	CALIFORNIA: The top of the stair flight and all stair treads do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	FLS Stair ST-1	California Accessibility Code	$189.80	$189.80
449	717880	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route is less than 48" wide.	Egress Route through SLF Kinya Dorm Courtyard	California Accessibility Code	$7,126.04	$7,126.04
450	717888	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Accessible Route to SLF Rec Office Access	ADA	$427.56	$427.56
451	717892	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	1	CALIFORNIA: Maneuvering clearance at the exterior side of the pull door with frontal approach is not level and clear.	SLF Door D-4	California Accessibility Code	$2,246.66	$2,246.66
452	717896	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Accessible Route from SLF Rec Door D-4 to Dock	ADA	$320.67	$320.67
453	717927	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route is less than 48" wide.	Accessible Route to Rec Area Egress Route Golden Poppy	California Accessibility Code	$7,126.04	$7,126.04
454	717932	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	SLF Door D-6	California Accessibility Code	$657.82	$657.82
455	717903	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	SLF Kinya Dorm Door D-5	California Accessibility Code	$1,214.99	$1,214.99
456	717931	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Door D-6	ADA	$657.82	$657.82
457	717936	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	SLF Door D-7	California Accessibility Code	$657.82	$657.82
458	717965	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp landings are not compliant.	Ramp to Psych Building	California Accessibility Code	$7,138.98	$7,138.98
459	717969	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	CALIFORNIA: The ramp has running slopes and/or rises in excess of 1:12.	Ramp to Psych Building	California Accessibility Code	$0.00	$0.00
460	725660	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Minimum Security Circulation Path	ADA	$71.26	$71.26
461	725665	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	RCCC Warehouse Staff Door D-8	California Accessibility Code	$3,145.32	$3,145.32
462	717954	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Door D-8	ADA	$657.82	$657.82
463	717964	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	1	The gate maneuvering clearance area is not compliant.	SFL Gate G-2	ADA	$2,247.38	$2,247.38
464	717968	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Ramp	1	The ramp has a rise in excess of 30".	Ramp to Psych Building	ADA	$0.00	$0.00

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
465	717973	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Accessible Route at Gatehouse	ADA	$285.04	$285.04
466	725659	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	RBF Law Library Door D-6	California Accessibility Code	$3,145.32	$3,145.32
467	725664	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	RCCC Warehouse Door D-7	California Accessibility Code	$3,145.32	$3,145.32
468	725696	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Medical Housing Unit	California Accessibility Code	$10,261.50	$10,261.50
469	725701	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Medical Housing Unit Door D-1	ADA	$657.82	$657.82
470	725717	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Medical Housing Unit Door D-2	California Accessibility Code	$657.82	$657.82
471	725729	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	Medical Housing Unit Door D-3	California Accessibility Code	$3,145.32	$3,145.32
472	725730	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$890.76	$890.76
473	725734	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Dorm M Door D-4	ADA	$657.82	$657.82
474	725738	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The non-fire, hinged accessible exterior door takes more than 5#s of pressure to operate.	Dorm M Door D-5	California Accessibility Code	$657.82	$657.82
475	725737	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Dorm M Door D-5	ADA	$657.82	$657.82
476	725753	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	Minimum Security Circulation Path	ADA	$463.19	$463.19
477	725762	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	The accessible route has gaps in the surface greater than 1/2" wide.	195 Tunnel Walkway	ADA	$2,156.79	$2,156.79
478	725766	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	1	CALIFORNIA: The maneuvering clearance at the entry door is not compliant.	195 Security Door	California Accessibility Code	$3,145.32	$3,145.32
479	725771	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path Between Barrak C and Dorm M	California Accessibility Code	$11,401.67	$11,401.67
480	725754	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	Minimum Security Circulation Path	California Accessibility Code	$4,988.23	$4,988.23
481	725763	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	CALIFORNIA: The exterior accessible route has slopes in excess of maximum 1:20 (5%) running slope and/or maximum 1:48 (2.08)% cross slope.	195 Tunnel Walkway	California Accessibility Code	$12,581.29	$12,581.29
482	725767	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	In areas along the route there are level changes of 1/2" or greater that are not ramped.	Accessible Route from Gate 20 Heading North	ADA	$3,206.72	$3,206.72
483	725772	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Minimum Security Circulation Path Between Barrak C and Dorm M	ADA	$35.63	$35.63
484	725775	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	1	Sidewalk has areas of vertical level changes in excess of 1/4" that are not ramped.	Minimum Security Circulation Path	ADA	$249.41	$249.41
485	713891	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Gate House Control Point Door	ADA	$179.73	$179.73
486	713906	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Gate House Control Point Interior	ADA	$359.47	$359.47
487	713990	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Multi-Purpose Mod Engraving and Sign Shop Interior	ADA	$179.73	$179.73
488	713994	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Multi-Purpose Mod Education Interior Doors	ADA	$359.47	$359.47
489	713983	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Multi-Purpose Mod Engraving and Sign Shop Interior	ADA	$359.47	$359.47
490	713991	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Multi-Purpose Mod Education Door D-3	ADA	$2,246.66	$2,246.66
491	713993	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Multi-Purpose Mod Education Interior	ADA	$1,308.45	$1,308.45
492	714610	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	2nd Floor Evidence Corridor Door	ADA	$179.73	$179.73
493	714642	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Admin Building Interior Doors	ADA	$179.73	$179.73
494	714604	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Elevator	1	The clearance between the car platform sill and the edge of the hoistway landing is greater than 1-1/4".	Admin Building Elevator E-1	ADA	$909.45	$909.45

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
495	714614	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Admin Building 2nd Floor Lobby	ADA	$718.93	$718.93
496	714609	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Admin Building Interior Doors	ADA	$1,973.47	$1,973.47
497	714607	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	2nd Floor Stair Lobby	ADA	$898.66	$898.66
498	714662	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Stairs	1	CALIFORNIA: Treads, including top and bottom treads, of the interior stair flight do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	Admin Building Egress Stair ST-2	California Accessibility Code	$1,391.85	$1,391.85
499	714695	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	2nd Floor Passage Hall Utility Room	California Accessibility Code	$526.62	$526.62
500	714712	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Ramp	1	Handrails do not extend 12" horizontally beyond the top and bottom of ramp runs above the landing surface.	2nd Floor Passage Hall Electronics and Projects Office Ramp R-1 & R-2	ADA	$1,258.13	$1,258.13
501	714719	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	CBF, SBF Public and Employee Interior Doors	ADA	$2,634.16	$2,634.16
502	714643	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Admin Building Interior Doors	ADA	$539.20	$539.20
503	714696	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Floor Passage Halls	ADA	$3,594.65	$3,594.65
504	714720	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Visitors Side CBF, SBF Accessible Attorney Booth	California Accessibility Code	$1,053.23	$1,053.23
505	714726	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Floor Surface	1	Clear floor space is not provided at the transfer point to the exercise equipment.	Admin Building Gym	ADA	$539.20	$539.20
506	714717	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Visitors Side Rooms CBF, SBF	ADA	$718.93	$718.93
507	714703	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	ADA	$359.47	$359.47
508	714711	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Ramp	1	The ramp running slope exceeds 1:12 (8.33%).	2nd Floor Passage Hall Electronics and Projects Office Ramp R-1	ADA	$11,905.50	$11,905.50
509	714718	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	CBF, SBF Public and Employee Interior Doors	ADA	$657.82	$657.82
510	725510	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Booking Interior Doors	ADA	$4,493.32	$4,493.32
511	725540	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Booking Interior Doors	ADA	$657.82	$657.82
512	725545	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Booking Interior Doors	California Accessibility Code	$2,633.08	$2,633.08
513	725553	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	Bookings Photo Room	ADA	$4,673.05	$4,673.05
514	725577	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Floor Surface	1	Fixtures and operable parts do not have adjacent 30" minimum by 48" minimum clear floor space.	Dorm A & B Interior	ADA	$718.93	$718.93
515	725594	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	RBF Door D-1	ADA	$2,246.66	$2,246.66
516	725609	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	The interior accessible route has non-compliant slopes.	RBF Interior Corridors	ADA	$6,131.04	$6,131.04
517	725635	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	RBF Control Entry Door D-4	ADA	$2,246.66	$2,246.66
518	725620	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	RBF Inmate Workers Quarters	ADA	$4,673.05	$4,673.05
519	730058	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Honor Facility Classroom Interior Door	ADA	$657.82	$657.82
520	730091	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The threshold at the accessible door is greater than ½" in height.	DGS Maintenance Shop Door D-2	ADA	$322.08	$322.08
521	730092	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	DGS Maintenance Shop Interior Doors	ADA	$539.20	$539.20
522	730125	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Welding Classroom Door D-9	ADA	$2,246.66	$2,246.66
523	730133	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Auto Shop Office Doors	ADA	$359.47	$359.47
524	730109	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	CALIFORNIA: The width of the aisle is not compliant.	Pharmacy Packaging Interior	California Accessibility Code	$3,594.65	$3,594.65
525	730117	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Welding Shop Interior Doors	ADA	$179.73	$179.73

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
526	730130	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Auto Shop Door D-9	ADA	$2,246.66	$2,246.66
527	725525	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Booking Interior	ADA	$1,078.40	$1,078.40
528	725603	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	RBF Door D-2	California Accessibility Code	$526.62	$526.62
529	725617	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	RBF Storage	ADA	$2,246.66	$2,246.66
530	720962	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Culinary Arts Building Door D-9	ADA	$179.73	$179.73
531	720966	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door does not have 80" minimum head clearance from finish floor, excluding door closer hinged bar and door stops which can be 78" minimum.	Culinary Arts Building Door D-9	ADA	$4,673.05	$4,673.05
532	720989	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Classroom 2 Building	ADA	$1,078.40	$1,078.40
533	725538	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Booking Interior Doors	ADA	$1,078.40	$1,078.40
534	725543	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Accessible Route	1	Clear widths are less than 36" minimum, including protruding objects.	Booking Property Room	ADA	$179.73	$179.73
535	725574	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Dorm A & B Control Room	ADA	$2,156.79	$2,156.79
536	720963	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	The interior accessible route has non-compliant slopes.	Culinary Arts Building Door D-9	ADA	$183.92	$183.92
537	725604	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	RBF Interior Routes	ADA	$1,308.45	$1,308.45
538	721004	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Classroom 1 Interior Door	ADA	$179.73	$179.73
539	721051	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Psych Building Interior Doors	ADA	$179.73	$179.73
540	721072	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Chaplains Office Entrance Door	ADA	$179.73	$179.73
541	721071	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Chaplains Office Entrance Door	California Accessibility Code	$526.62	$526.62
542	725630	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	RBF Exit Common Area	ADA	$2,246.66	$2,246.66
543	730029	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Honor Facility Classroom Corridor	ADA	$359.47	$359.47
544	730042	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Honor Facility Classroom 4 Office	ADA	$359.47	$359.47
545	730079	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	DGS Electrical Shop Interior Doors	ADA	$359.47	$359.47
546	730026	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Honor Facility Classroom 4 Interior Doors	ADA	$179.73	$179.73
547	722632	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Rec Building Visitor Station 2 Door	ADA	$657.82	$657.82
548	722633	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Rec Building Visitor Station 2 Door	ADA	$2,246.66	$2,246.66
549	722706	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Kitchen Security Scanner Corridor	ADA	$359.47	$359.47
550	722710	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Kitchen Interior Doors	ADA	$1,315.64	$1,315.64
551	730106	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Pharmacy Packaging Entrance Door D-6	ADA	$179.73	$179.73
552	730114	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The threshold at the accessible door is greater than ½" in height.	Welding Shop Door D-7	ADA	$322.08	$322.08
553	722702	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	CALIFORNIA: The width of the aisle is not compliant.	Kitchen Security Scanner	California Accessibility Code	$2,875.72	$2,875.72
554	722711	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Kitchen Interior Doors	ADA	$1,317.08	$1,317.08
555	730103	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	DGS Plumbing Shop Interior Door	ADA	$179.73	$179.73

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
556	730119	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Welding Shop Interior	ADA	$1,308.45	$1,308.45
557	730132	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Auto Shop Office Doors	California Accessibility Code	$1,053.23	$1,053.23
558	722829	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Booking Interior Doors	ADA	$1,973.47	$1,973.47
559	720964	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Culinary Arts Building Interior	ADA	$1,078.40	$1,078.40
560	722803	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Booking Interior Doors	ADA	$359.47	$359.47
561	722834	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Booking Interior Doors	ADA	$2,246.66	$2,246.66
562	722837	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Fixtures and operable parts do not have adjacent 30" minimum by 48" minimum clear floor space.	Booking Lobby	ADA	$179.73	$179.73
563	720987	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Classroom 2 Interior Door	ADA	$359.47	$359.47
564	716072	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	2nd Floor Admin Building Near Equipment Room	ADA	$898.66	$898.66
565	716117	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	1st Floor Satellite Kitchen JKF & KBF Door D-1 & D-2	ADA	$4,493.32	$4,493.32
566	721048	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Psych Building Interior Doors	ADA	$1,315.64	$1,315.64
567	721052	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Psych Building Interior Doors	ADA	$4,493.32	$4,493.32
568	716114	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	Security Area Visitor's Side Interior Doors CBF, SBF, JKF, KBF	California Accessibility Code	$1,579.85	$1,579.85
569	716118	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	1st Floor Satellite Kitchen JKF & KBF Door D-1 & D-2	ADA	$4,493.32	$4,493.32
570	716152	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	In areas along the interior route there are level changes between 1/4" and 1/2" which are not beveled.	CBF Pods Video Conference Booth	ADA	$306.55	$306.55
571	716173	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Stairs	1	CALIFORNIA: Handrails are not compliant or are not provided.	CBF & SBF 2nd Floor Classroom Egress Stairs	California Accessibility Code	$29,296.44	$29,296.44
572	720984	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door does not have 80" minimum head clearance from finish floor, excluding door closer hinged bar and door stops which can be 78" minimum.	Classroom 2 Entrance Door	ADA	$4,673.05	$4,673.05
573	721018	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Psych Entrance Door D-10	ADA	$179.73	$179.73
574	716136	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	Control Point Door CBF	ADA	$4,673.05	$4,673.05
575	716153	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	1	Clear space is not provided at the control or operating mechanism.	CBF Pods Video Conference Booth	ADA	$2,156.79	$2,156.79
576	716158	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	CBF Interior Doors	ADA	$657.82	$657.82
577	716174	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Stairs	1	CALIFORNIA: Treads, including top and bottom treads, of the interior stair flight do not have a stripe which provides visual contrast of dark-on-light or light-on-dark distinguished from the remainder of the surface.	CBF & SBF 2nd Floor Classroom Egress Stairs	California Accessibility Code	$569.39	$569.39
578	716177	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	CBF & SBF 2nd Floor Inmate Side Visitors Attorney Rooms	ADA	$4,673.05	$4,673.05
579	716216	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	KBF Control Point Access 801	ADA	$2,875.72	$2,875.72
580	721049	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Psych Building Interior Doors	ADA	$1,317.08	$1,317.08
581	721053	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Psych Building Interior Doors	ADA	$2,246.66	$2,246.66
582	716228	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Exterior Access Route	Elevator	1	The clearance between the car platform sill and the edge of the hoistway landing is greater than 1-1/4".	KBF & JKF Security Controlled Elevator	ADA	$909.45	$909.45
583	716232	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	KBF & JKF Attorney Room A3 Accessible	ADA	$658.54	$658.54
584	721074	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door does not have 80" minimum head clearance from finish floor, excluding door closer hinged bar and door stops which can be 78" minimum.	Chaplains Office Entrance Door	ADA	$4,673.05	$4,673.05
585	721109	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Entrance Door to Redemption Coffee	ADA	$2,246.66	$2,246.66

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
586	717809	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	SLF Interior Doors Facility Wide	ADA	$718.93	$718.93
587	717791	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Interior Doors	ADA	$1,315.64	$1,315.64
588	717861	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	SLF Inmate Side Visitor's Room	ADA	$4,673.05	$4,673.05
589	717844	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	SLF Interior Doors	ADA	$2,246.66	$2,246.66
590	717859	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	SLF Visitor Inmate Side Legal Room	ADA	$4,673.05	$4,673.05
591	721154	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Reentry Services Building Interior Doors	ADA	$1,078.40	$1,078.40
592	721158	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Reentry Services Building Classroom 2	ADA	$898.66	$898.66
593	721151	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Reentry Services Entrance Door D-1	ADA	$2,246.66	$2,246.66
594	722592	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	A direct accessible route is not provided from the assembly seating area to a performance area.	Rec Building	ADA	$38,462.81	$38,462.81
595	722597	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	Rec Building Interior Doors	ADA	$4,673.05	$4,673.05
596	722601	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Rec Building Interior Doors	ADA	$2,246.66	$2,246.66
597	722635	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Rec Building Interior Doors	ADA	$2,246.66	$2,246.66
598	725707	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Medical Housing Unit	ADA	$1,078.40	$1,078.40
599	725711	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	RCCC Medical Housing Unit	ADA	$2,246.66	$2,246.66
600	722681	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Honor Facility Laundry Office	ADA	$179.73	$179.73
601	722703	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Kitchen Interior Doors	ADA	$657.82	$657.82
602	722708	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Kitchen Interior Doors	ADA	$2,246.66	$2,246.66
603	722712	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Kitchen Interior Doors	ADA	$179.73	$179.73
604	722705	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Kitchen Interior Doors	ADA	$658.54	$658.54
605	722748	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	Kitchen Interior Doors	ADA	$179.73	$179.73
606	722784	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Dorm G, H, J & K Entrance Doors (Typical Findings)	ADA	$0.00	$0.00
607	722804	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Booking Interior	ADA	$359.47	$359.47
608	722821	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	Booking Interior Doors	ADA	$1,975.62	$1,975.62
609	722831	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	Booking Interior	ADA	$718.93	$718.93
610	722818	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	Booking Interior Doors	ADA	$359.47	$359.47
611	716082	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Floor Surface	1	Gaps in the walking surface are over 1/2" wide, or elongated gaps are not perpendicular to the path of travel.	Passage Hallway CBF, SBF, JKF, KBF	ADA	$71.26	$71.26
612	716112	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Security Area Visitor's Side Interior Doors CBF, SBF, JKF, KBF	ADA	$1,315.64	$1,315.64
613	716134	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The push side of the accessible door does not have the required maneuvering clearances.	1st Floor Dental Room Door	ADA	$179.73	$179.73
614	716156	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	CBF Interior Doors	California Accessibility Code	$1,579.85	$1,579.85
615	716159	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	CBF Interior Doors	ADA	$658.54	$658.54
616	716179	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	CBF & SBF 2nd Floor Inmate Side Visitors Attorney Rooms	California Accessibility Code	$1,053.23	$1,053.23
617	716165	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	1	CALIFORNIA: The width of the aisle is not compliant.	CBF Interior Spaces	California Accessibility Code	$179.73	$179.73

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
618	716172	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	CBF 2nd Floor Classroom	ADA	$898.66	$898.66
619	716184	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	JKF Control Point Access	ADA	$2,156.79	$2,156.79
620	716231	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	KBF & JKF Attorney Room A3 Accessible	ADA	$657.82	$657.82
621	717785	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	SLF Lobby	ADA	$898.66	$898.66
622	717793	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	SLF Interior Doors	ADA	$32,711.36	$32,711.36
623	717792	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The opening force required to open the accessible, hinged, non-fire door is more than 5 pounds.	SLF Interior Doors	ADA	$1,317.08	$1,317.08
624	717839	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	CALIFORNIA: The hardware at the accessible door is not compliant.	SLF Interior Doors	California Accessibility Code	$4,212.94	$4,212.94
625	717843	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	SLF Sutter Hall Corridor	ADA	$1,308.45	$1,308.45
626	717851	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	SLF Intake Holding Cell Doors	ADA	$9,346.10	$9,346.10
627	717862	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The pull side of the accessible door does not have the required maneuvering clearances.	SLF Inmate Side Visitor's Room	ADA	$2,246.66	$2,246.66
628	717945	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	SLF Golden Poppy And Camellia Dorms	ADA	$898.66	$898.66
629	717958	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	SLF Ramona Hallway	ADA	$1,797.33	$1,797.33
630	725692	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Protruding Object	1	Protruding objects in the 27" to 80" range above finished floor protrude more than 4" into the circulation path along the interior accessible route.	RCCC Warehouse	ADA	$359.47	$359.47
631	725710	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	1	The door has less than 32" clear width.	Medical Housing Unit Staff Restroom RR-1	ADA	$4,673.05	$4,673.05
632	730158	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Fishbowl Medical Kites Box	ADA	$898.66	$898.66
633	722664	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Service Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Control Point for Dorms C, D, G, & H	State of California	$3,235.19	$3,235.19
634	716081	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Site Furnishings	Picnic Table	2	The picnic table does not allow a clear space for forward wheelchair approach with knee and toe clearance.	Facility Wide Picnic Tables	ADA	$37,384.41	$37,384.41
635	725615	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Service Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	RBF Control	State of California	$2,156.79	$2,156.79
636	725626	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The dining or work surface is not compliant.	RBF Inmate Library Room	State of California	$1,427.08	$1,427.08
637	725542	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Service Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Booking Service Counter	State of California	$3,235.19	$3,235.19
638	725579	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Service Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Dorm A & B Interior	State of California	$2,156.79	$2,156.79
639	725624	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The dining or work surface is not compliant.	RBF Inmate Workers Quarters	State of California	$2,336.53	$2,336.53
640	730059	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	The work surface height is not compliant. Knee and toe clearances are not provided.	Honor Facility Classroom 3	ADA	$2,588.15	$2,588.15
641	721157	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The work surface is not compliant.	Reentry Services Building Classrooms	State of California	$2,854.16	$2,854.16

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
642	721006	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The work surface is not compliant.	Classroom 1 Building	State of California	$2,854.16	$2,854.16
643	720988	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The work surface is not compliant.	Classroom 2 Building	State of California	$2,854.16	$2,854.16
644	716141	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Common Areas	Dining And Work Surface	2	CALIFORNIA: The dining or work surface is not compliant.	2nd Floor CBF & SBF Classrooms	State of California	$2,854.16	$2,854.16
645	716149	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The dining or work surface is not compliant.	CBF Pod Cells	State of California	$4,281.23	$4,281.23
646	717865	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Common Areas	Dining And Work Surface	2	CALIFORNIA: The work surface is not compliant.	SLF Kinya Dorm	State of California	$1,427.08	$1,427.08
647	717920	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	SLF Kinya Dorm Restroom	ADA	$1,226.21	$1,226.21
648	725728	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	Medical Housing Unit Inmate Restroom	ADA	$3,678.63	$3,678.63
649	725751	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	M Dorm Restroom RR-3	ADA	$3,065.52	$3,065.52
650	722777	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Service Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Facility Wide Pass-Through Counters (Typical Finding_	State of California	$9,705.57	$9,705.57
651	722835	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Booking Lobby	State of California	$3,235.19	$3,235.19
652	716150	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Common Areas	Dining And Work Surface	2	CALIFORNIA: The dining or work surface is not compliant.	CBF Pods	State of California	$1,427.08	$1,427.08
653	716121	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Dining And Work Surface	2	CALIFORNIA: The dining or work surface is not compliant.	1st Floor Satellite Kitchen JKF & KBF	State of California	$2,336.53	$2,336.53
654	716139	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Site Furnishings	Picnic Table	2	The picnic table does not allow a clear space for forward wheelchair approach with knee and toe clearance.	CBF Outdoor Rec	ADA	$2,336.53	$2,336.53
655	716234	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Dining And Work Surface	2	CALIFORNIA: The work surface is not compliant.	KBF & JKF Classroom	State of California	$1,427.08	$1,427.08
656	717852	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Service Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	SLF Intake Service Counter	State of California	$3,235.19	$3,235.19
657	717950	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	SLF Circulation	State of California	$2,156.79	$2,156.79
658	725702	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Medical Housing Unit	State of California	$3,235.19	$3,235.19
659	713858	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Common Areas	Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Gate House Exterior Service Window	State of California	$3,235.19	$3,235.19
660	713913	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	2	The gate does not have a smooth surface within 10" of the ground.	Gates Facility Wide.	ADA	$575.14	$575.14
661	713963	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	2	CALIFORNIA: The stair handrail extensions are not compliant.	Stair ST-3	California Accessibility Code	$585.93	$585.93
662	714594	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Admin Building Door D-3	ADA	$4,673.05	$4,673.05
663	714598	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Reach Range	2	Operable parts or items requiring an obstructed side reach motion are higher than 48" maximum where the obstruction depth is 10" maximum, or higher than 46" maximum where the obstruction depth is between 10" and 24" and/or lower than 15" minimum height above finish floor.	Admin Building Door D-4	ADA	$1,797.33	$1,797.33
664	714602	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Admin Building Door D-4	ADA	$287.57	$287.57

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
665	714580	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Reach Range	2	Operable parts or items requiring an obstructed side reach motion are higher than 48" maximum where the obstruction depth is 10" maximum, or higher than 46" maximum where the obstruction depth is between 10" and 24" and/or lower than 15" minimum height above finish floor.	Admin Building Door D-1	ADA	$898.66	$898.66
666	714584	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Reach Range	2	Operable parts or items requiring an obstructed side reach motion are higher than 48" maximum where the obstruction depth is 10" maximum, or higher than 46" maximum where the obstruction depth is between 10" and 24" and/or lower than 15" minimum height above finish floor.	Admin Building Door D-2	ADA	$898.66	$898.66
667	714588	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Admin Building Door D-2	ADA	$287.57	$287.57
668	714581	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Admin Building Door D-1	ADA	$575.14	$575.14
669	714585	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Admin Building Door D-2	ADA	$4,673.05	$4,673.05
670	714579	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	CALIFORNIA: The accessible entrance does not have signage with the International Symbol of Accessibility, in the existing building where not all entrances are accessible.	Admin Building Door D-1	California Accessibility Code	$98.85	$98.85
671	714591	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Reach Range	2	Operable parts or items requiring an obstructed side reach motion are higher than 48" maximum where the obstruction depth is 10" maximum, or higher than 46" maximum where the obstruction depth is between 10" and 24" and/or lower than 15" minimum height above finish floor.	Admin Building Door D-3	ADA	$1,797.33	$1,797.33
672	714595	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	CALIFORNIA: The non-accessible entrance does not have signage indicating the location of the nearest accessible entrance, in the existing building where not all entrances are accessible.	Admin Building Door D-3	California Accessibility Code	$98.85	$98.85
673	714599	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Admin Building Door D-4	ADA	$4,673.05	$4,673.05
674	725557	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Booking Entrance Door D-5	ADA	$4,673.05	$4,673.05
675	725619	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	RBF Doors D-2 & D-3	ADA	$9,346.10	$9,346.10
676	730027	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Honor Facility Classroom Door D-2	ADA	$4,673.05	$4,673.05
677	730077	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	DGS Electrical Shop	ADA	$359.47	$359.47
678	730096	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	CALIFORNIA: The non-accessible entrance does not have signage indicating the location of the nearest accessible entrance, in the existing building where not all entrances are accessible.	DGS Maintenance Shop Door D-3	California Accessibility Code	$98.85	$98.85
679	725560	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Booking Entrance Door D-6	ADA	$4,673.05	$4,673.05
680	720959	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	2	CALIFORNIA: The stair handrail extensions are not compliant.	SFL Stair ST-2	California Accessibility Code	$1,171.86	$1,171.86
681	720971	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	2	CALIFORNIA: The stair handrail extensions are not compliant.	Stair ST-3 Culinary Arts Building Inmate Side	California Accessibility Code	$1,171.86	$1,171.86
682	720976	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	2	The gate does not have a smooth surface within 10" of the ground.	Gate G-3, G-4 & G-5 to Classrooms & Culinary Arts Building	ADA	$862.72	$862.72
683	725608	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	RBF Door D-2	ADA	$359.47	$359.47
684	725642	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	2	The gate does not have a smooth surface within 10" of the ground.	Minimum Security Circulation Path Gates	ADA	$862.72	$862.72
685	721016	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Psych Entrance Door D-10	ADA	$359.47	$359.47
686	721067	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	2	CALIFORNIA: The stair handrail extensions are not compliant.	Stairs to Chaplains Office	California Accessibility Code	$585.93	$585.93
687	721055	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Psych Entrance Door D-11	ADA	$4,673.05	$4,673.05
688	721068	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Chaplains Office Entrance Door	ADA	$4,673.05	$4,673.05
689	721075	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Facilities Trades Operations Office Entrance Door	ADA	$4,673.05	$4,673.05
690	721085	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Stairs	2	CALIFORNIA: The stair handrail extensions are not compliant.	Stairs to Medical Intake Trailer	California Accessibility Code	$1,171.86	$1,171.86
691	730021	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Honor Facility Classroom Door D-1	ADA	$4,673.05	$4,673.05
692	725634	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	RBF Control Entry Door D-4	ADA	$4,673.05	$4,673.05

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
693	725652	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Booking Release Door D-7	ADA	$4,673.05	$4,673.05
694	721108	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Entrance Door to Redemption Coffee	ADA	$4,673.05	$4,673.05
695	722590	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Exterior Accessible Route	2	Clear ground space is not provided at the operable part.	Route to Flagpole	ADA	$712.60	$712.60
696	722659	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	2	The gate does not have a smooth surface within 10" of the ground.	Minimum Security Area Gates (Typical for all gates)	ADA	$0.00	$0.00
697	722673	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Laundry Building Door D-2	ADA	$4,673.05	$4,673.05
698	722670	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Laundry Building Door D-1	ADA	$4,673.05	$4,673.05
699	730090	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	DGS Maintenance Shop Door D-2	ADA	$359.47	$359.47
700	730123	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Reach Range	2	Items requiring an obstructed forward reach motion are higher than 48" maximum height where the depth of the obstruction is 20" maximum, or greater than 44" maximum height where the depth of the obstruction is 20" to 25" maximum, or lower than minimum 15" height above finish floor.	Welding Shop at Door D-8	ADA	$718.93	$718.93
701	730160	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Gatehouse Door D-4	ADA	$4,673.05	$4,673.05
702	730099	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	DGS Plumbing Shop D-4	ADA	$4,673.05	$4,673.05
703	730111	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Welding Shop Door D-7	ADA	$4,673.05	$4,673.05
704	722783	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Dorm G, H, J & K Entrance Doors (Typical Findings)	ADA	$0.00	$0.00
705	722799	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Booking Door D-8	ADA	$4,673.05	$4,673.05
706	722824	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Booking Door D-2	ADA	$359.47	$359.47
707	722841	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Booking Door D-3	ADA	$4,673.05	$4,673.05
708	721017	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Psych Entrance Door D-10	ADA	$4,673.05	$4,673.05
709	720974	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance-Door	2	CALIFORNIA: The accessible entrance does not have signage with the International Symbol of Accessibility, in the existing building where not all entrances are accessible.	Culinary Arts Inmate Door D-10	California Accessibility Code	$98.85	$98.85
710	721105	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Protruding Object	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Redemption Coffee Service Counter	State of California	$3,235.19	$3,235.19
711	717893	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	SLF Door D-4	ADA	$4,673.05	$4,673.05
712	717952	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	SLF Door D-8	ADA	$359.47	$359.47
713	717963	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	2	The gate does not have a smooth surface within 10" of the ground.	SFL Gate G-2	ADA	$287.57	$287.57
714	722767	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The bottom of the entry door vision light is higher than 43".	Dorms J & K Control Door D-1	ADA	$4,673.05	$4,673.05
715	717767	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	SLF Door D-1	ADA	$287.57	$287.57
716	717883	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Gate	2	The gate does not have a smooth surface within 10" of the ground.	SFL Gate G-1	ADA	$287.57	$287.57
717	717904	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	SLF Kinya Dorm Door D-5	ADA	$359.47	$359.47
718	717937	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Entrance to Building	Building Entrance - Door	2	The surface of the door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	SLF Door D-7	ADA	$359.47	$359.47
719	725697	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Service Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Medical Housing Unit	State of California	$3,235.19	$3,235.19
720	713877	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	Gate House Unisex Restroom RR-2	ADA	$980.97	$980.97
721	713866	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	Gate House Unisex Restroom RR-1	ADA	$980.97	$980.97

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
722	713887	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Common Areas	Vending Machine	2	The vending machines have operable parts which are not within reach range.	Gate House Vending Machine	ADA	$5,848.50	$5,848.50
723	713895	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	Gate House Control Point Unisex Restroom RR-3	ADA	$980.97	$980.97
724	713908	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Gate House Control Point Doors	ADA	$9,346.10	$9,346.10
725	714608	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Admin Building Interior Doors	ADA	$46,730.51	$46,730.51
726	714640	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	2nd Floor Admin Building Women's Restroom RR-2	ADA	$980.97	$980.97
727	714657	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Common Areas	Counter	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	2nd Floor Admin Counter	State of California	$3,235.19	$3,235.19
728	714641	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Admin Building Interior Doors	ADA	$1,078.40	$1,078.40
729	714655	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	2nd Floor Admin Briefing Room	ADA	$898.66	$898.66
730	714704	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	ADA	$245.24	$245.24
731	714648	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	2nd Floor Admin ISU Office Unisex Restroom RR-3	ADA	$245.24	$245.24
732	714725	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	JKF & KBF Attorney Room 3	ADA	$4,673.05	$4,673.05
733	714746	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$980.97	$980.97
734	714693	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	2	The existing elevator signage is not mounted at a compliant height.	Admin Building Elevator E-2	ADA	$395.41	$395.41
735	714697	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	2nd Floor Passage Hall Electronics and Projects Office	ADA	$1,294.08	$1,294.08
736	714656	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	2nd Floor Admin Canteen	ADA	$1,294.08	$1,294.08
737	714698	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	2nd Floor Passage Hall Electronics and Projects Office	ADA	$359.47	$359.47
738	714729	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	2	The bottom of the door vision light is higher than 43" and less than 66".	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$4,673.05	$4,673.05
739	714763	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$3,065.52	$3,065.52
740	725576	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Dorm A, B, C, & D Interior	ADA	$2,875.72	$2,875.72
741	725541	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Booking Interior	ADA	$897.23	$897.23
742	725547	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Booking Interior Inmate Side	ADA	$898.66	$898.66
743	725601	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	RBF Cells	ADA	$898.66	$898.66
744	725640	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed forward reach motion are higher than 48" maximum or lower than 15" minimum height above finish floor.	RBF Control Room	ADA	$898.66	$898.66
745	725595	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	RBF Door D-1	ADA	$4,673.05	$4,673.05
746	725611	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	RBF Interior East & West Wing Showers	ADA	$2,452.42	$2,452.42
747	725616	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	RBF Medical Office	ADA	$1,294.08	$1,294.08
748	725628	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Gate	2	The gate does not have a smooth surface within 10" of the ground.	RBF Inmate Library Room	ADA	$287.57	$287.57
749	714784	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	1st Floor Admin Inmate Unisex Restroom RR-6	ADA	$1,532.76	$1,532.76

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
750	714794	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	1st Floor Admin Building Staff Dining	ADA	$718.93	$718.93
751	730024	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Honor Facility Classroom 4	ADA	$1,078.40	$1,078.40
752	730057	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Honor Facility Classrooms Interior Corridor Doors	ADA	$9,346.10	$9,346.10
753	730061	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Honor Facility Classroom 3	ADA	$359.47	$359.47
754	730105	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Pharmacy Packaging Entrance Door D-6	ADA	$359.47	$359.47
755	730116	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Welding Shop Interior	ADA	$1,078.40	$1,078.40
756	730154	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Honor Facility Classroom Door D-3	ADA	$359.47	$359.47
757	730481	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Kitchen	Sink	2	Exposed pipes lack insulation and/or sharp or abrasive surfaces are present under the sink.	Facility Wide Sinks	ADA	$1,168.26	$1,168.26
758	725551	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Booking Holding Tank	ADA	$359.47	$359.47
759	720990	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Classroom 2 Building	ADA	$718.93	$718.93
760	721050	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Psych Building Interior Doors	ADA	$359.47	$359.47
761	721156	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Reentry Services Building Interior Doors	ADA	$32,711.36	$32,711.36
762	722598	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Rec Building	ADA	$359.47	$359.47
763	722595	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	2	The picnic table does not allow a clear space for forward wheelchair approach with knee and toe clearance.	Rec Building	ADA	$9,346.10	$9,346.10
764	722599	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Rec Building Interior Doors	ADA	$359.47	$359.47
765	722646	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Dorms G, H, J, K, Typical Findings	ADA	$718.93	$718.93
766	722682	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	2	CALIFORNIA: The service counter does not have 36" long section that is 34" maximum above finished floor that is oriented for a parallel approach, or the service counter does not have a 36" long section that is 34" maximum above the finished floor, with knee and toe clearance oriented for a forward approach.	Honor Facility Laundry Changing Room	State of California	$3,235.19	$3,235.19
767	730080	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	DGS Electrical Shop Interior	ADA	$359.47	$359.47
768	730095	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	DGS Maintenance Shop Interior Door	ADA	$4,673.05	$4,673.05
769	730118	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Welding Shop Interior	ADA	$1,294.08	$1,294.08
770	722683	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed forward reach motion are higher than 48" maximum or lower than 15" minimum height above finish floor.	Honor Facility Laundry Office	ADA	$359.47	$359.47
771	722707	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed forward reach motion are higher than 48" maximum or lower than 15" minimum height above finish floor.	Kitchen Security Scanner Corridor	ADA	$718.93	$718.93
772	722769	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an obstructed side reach motion are higher than 48" maximum where the obstruction depth is 10" maximum, or higher than 46" maximum where the obstruction depth is between 10" and 24" and/or lower than 15" minimum height above finish	Dorm J & K Control Room	ADA	$718.93	$718.93
773	730107	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Pharmacy Packaging Interior	ADA	$359.47	$359.47

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
774	722746	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an obstructed side reach motion are higher than 48" maximum where the obstruction depth is 10" maximum, or higher than 46" maximum where the obstruction depth is between 10" and 24" and/or lower than 15" minimum height above finish	Kitchen Interior	ADA	$718.93	$718.93
775	722819	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Booking Interior Doors	ADA	$718.93	$718.93
776	730156	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Honor Facility Back Classroom Interior.	ADA	$359.47	$359.47
777	722820	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Booking Interior Doors	ADA	$1,797.33	$1,797.33
778	722830	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Booking Break Room	ADA	$1,294.08	$1,294.08
779	722833	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Booking Interior Doors	ADA	$14,019.15	$14,019.15
780	721021	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Psych Building	ADA	$179.73	$179.73
781	720965	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Culinary Arts Building Interior	ADA	$1,078.40	$1,078.40
782	716109	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Security Area Visitor's Side Interior Doors CBF, SBF, JKF, KBF	ADA	$56,076.62	$56,076.62
783	716113	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Security Area Visitor's Side Interior Doors CBF, SBF, JKF, KBF	ADA	$1,437.86	$1,437.86
784	716157	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	CBF Interior Doors	ADA	$4,673.05	$4,673.05
785	716168	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	CBF 2nd Floor Classroom	ADA	$1,294.08	$1,294.08
786	721007	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Classroom 1 Building	ADA	$718.93	$718.93
787	716190	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	2	The restroom circulation path is not free of objects protruding more than 4" from wall in the space between 27" and 80" height above finish floor.	JKF Control Bottom Tier Staff Unisex Restroom RR-3	ADA	$359.47	$359.47
788	716202	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	JKF 448 Medical Staff Unisex Restroom RR-4	ADA	$1,532.76	$1,532.76
789	716220	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	KBF Control Point Access 801 Unisex Restroom RR-5	ADA	$1,532.76	$1,532.76
790	716178	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed forward reach motion are higher than 48" maximum or lower than 15" minimum height above finish floor.	CBF & SBF 2nd Floor Inmate Visitors Side	ADA	$898.66	$898.66
791	716187	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	JKF Control Bottom Tier Staff Unisex Restroom RR-1	ADA	$1,532.76	$1,532.76
792	716238	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	KBF & JKF Classroom 2nd Floor Inmate Restroom	ADA	$1,532.76	$1,532.76
793	716268	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	KBF & JKF Outdoor Rec Restrooms	ADA	$3,065.52	$3,065.52
794	721088	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Medical Trailer Interior Controls	ADA	$718.93	$718.93
795	717819	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	2	The swinging door does not have a smooth surface within 10" of the ground measured vertically on the push side extending the full width of the door.	SLF Property Room Restroom RR-4	ADA	$718.93	$718.93
796	717828	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	2	The swinging door does not have a smooth surface within 10" of the ground measured vertically on the push side extending the full width of the door.	SLF Women's Multi Accommodations Restroom RR-6	ADA	$718.93	$718.93
797	717841	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	SLF Interior Doors	ADA	$2,516.26	$2,516.26
798	721155	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Reentry Services Building	ADA	$1,294.08	$1,294.08
799	717943	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	SLF Golden Poppy And Camellia Dorms	ADA	$2,588.15	$2,588.15

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
800	717923	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an obstructed side reach motion are higher than 48" maximum where the obstruction depth is 10" maximum, or higher than 46" maximum where the obstruction depth is between 10" and 24" and/or lower than 15" minimum height above finish	SLF Kinya Dorm	ADA	$898.66	$898.66
801	722600	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Rec Building Interior Doors	ADA	$14,019.15	$14,019.15
802	725704	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	Medical Housing Unit	ADA	$4,673.05	$4,673.05
803	722675	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Honor Facility Barbershop	ADA	$1,294.08	$1,294.08
804	722709	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The surface of the swinging door within 10 inches of the finish floor or ground for the full width of the door on the push side is not smooth.	Kitchen Interior Doors	ADA	$359.47	$359.47
805	722749	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Gate	2	The gate does not have a smooth surface within 10" of the ground measured vertically on the push side extending the full width of the gate.	Kitchen Interior Gate	ADA	$575.14	$575.14
806	722836	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Vending Machine	2	The vending machines have operable parts which are not within reach range.	Booking Lobby	ADA	$5,848.50	$5,848.50
807	716111	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Security Area Visitor's Side Interior Doors CBF, SBF, JKF, KBF	ADA	$1,078.40	$1,078.40
808	716115	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Medical and Dental Exam Room Sinks CBF, SBF, JKF, KBF	ADA	$2,588.15	$2,588.15
809	716133	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	1st Floor Satellite Kitchen JKF & KBF	ADA	$898.66	$898.66
810	716143	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed forward reach motion are higher than 48" maximum or lower than 15" minimum height above finish floor.	CBF Pods	ADA	$1,797.33	$1,797.33
811	716116	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	Medical Exam Room CBF, SBF, JKF, KBF	ADA	$718.93	$718.93
812	716196	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	JKF Control Point	ADA	$1,294.08	$1,294.08
813	716235	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	KBF & JKF Classroom	ADA	$359.47	$359.47
814	716217	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	KBF Control Point 801	ADA	$1,294.08	$1,294.08
815	716222	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	2	The restroom circulation path is not free of objects protruding more than 4" from wall in the space between 27" and 80" height above finish floor.	KBF Control Point Access 801 Unisex Restroom RR-5	ADA	$359.47	$359.47
816	716230	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	2	The bottom of the door vision light is higher than 43" and less than 66".	KBF & JKF Attorney Room A3 Accessible	ADA	$4,673.05	$4,673.05
817	717808	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	SLF Interior Spaces Facility Wide	ADA	$359.47	$359.47
818	717821	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	SLF Nurses Office	ADA	$1,294.08	$1,294.08
819	717842	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	SLF Teacher Office	ADA	$1,294.08	$1,294.08
820	717913	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Protruding Object	2	The restroom circulation path is not free of objects protruding more than 4" from wall in the space between 27" and 80" height above finish floor.	SLF Kinya Dorm Restroom	ADA	$1,078.40	$1,078.40
821	717912	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Unisex	2	The slope of the floor surface is greater than 2% cross or 5% running	SLF Kinya Dorm Restroom	ADA	$1,532.76	$1,532.76
822	717959	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Reach Range	2	Items requiring an unobstructed side reach motion are higher than 48" maximum and/or lower than 15" minimum height above finish floor.	SLF Women's Chow Hall	ADA	$898.66	$898.66
823	725706	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Sink	2	The sink rim is higher than 34", and does not have knee and toe clearance (does not apply to mop basins, utility sinks, or bar sinks).	Medical Housing Unit	ADA	$2,588.15	$2,588.15
824	720975	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Portable Restroom	Portable Restroom	3	An ADA portable restroom is not provided.	Culinary Arts Building	ADA	$5,391.98	$5,391.98
825	714723	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	Visitors Side CBF, Stations	California Accessibility Code	$13,479.96	$13,479.96
826	725554	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Bookings Inmate Urinal and Lavatory RR-4	ADA	$21,567.93	$21,567.93

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
827	725585	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Dorm A, B, C & D Restrooms	California Accessibility Code	$9,834.98	$9,834.98
828	725589	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Dorm A, B, C & D Restrooms	ADA	$1,437.86	$1,437.86
829	725581	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Dorm A, B, C & D Restrooms	California Accessibility Code	$5,176.30	$5,176.30
830	725586	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Dorm A, B, C & D Restrooms	ADA	$4,529.27	$4,529.27
831	725548	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Judicial Facilities	Holding Cell	3	At least one of each type of holding cell must contain mobility features.	Booking Holding Tanks 1-3	California Accessibility Code	$215,679.29	$215,679.29
832	725582	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	The urinal dimensions are not compliant.	Dorm A, B, C & D Restrooms	ADA	$6,723.44	$6,723.44
833	725587	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	Dorm A, B, C & D Restrooms	ADA	$5,104.41	$5,104.41
834	725591	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	Booking Attorney Side Visiting Rooms 1-3	California Accessibility Code	$13,479.96	$13,479.96
835	725584	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Dorm A, B, C & D Restrooms	California Accessibility Code	$1,150,289.54	$1,150,289.54
836	725588	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The roll-in shower stall is not compliant.	Dorm A, B, C & D Restrooms	California Accessibility Code	$862,717.16	$862,717.16
837	725593	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	RBF / Booking Visiting Rooms	California Accessibility Code	$26,959.91	$26,959.91
838	725597	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Detention/Correctional Facilities	Detention Cell	3	Less than 3% of the detention cells are mobility cells.	RBF Housing Cells	ADA	$2,156,792.90	$2,156,792.90
839	725621	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	RBF Inmate Workers Quarters	ADA	$21,567.93	$21,567.93
840	728931	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Detention/Correctional Facilities	Detention Cell	3	CALIFORNIA: Less than 2% of the detention cells are communication cells.	Facility Wide All Detention Areas	California Accessibility Code	$33,430.29	$33,430.29
841	722594	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	Rec Building	California Accessibility Code	$4,503.38	$4,503.38
842	730056	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	Honor Facility Classroom Drinking Fountain DF-1	California Accessibility Code	$4,503.38	$4,503.38
843	722650	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	Dorms G, H, J, K, Typical Findings	ADA	$5,104.41	$5,104.41
844	722647	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Dorms G, H, J, K, Typical Findings	California Accessibility Code	$5,176.30	$5,176.30
845	722651	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Dorms G, H, J, K, Typical Findings	ADA	$4,529.27	$4,529.27
846	722692	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	Honor Facility Laundry	California Accessibility Code	$4,503.38	$4,503.38
847	722729	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Kitchen Men's Inmate Restroom RR-2	ADA	$2,246.66	$2,246.66
848	722733	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	Kitchen Men's Inmate Restroom RR-2	ADA	$1,276.10	$1,276.10
849	722751	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	3	CALIFORNIA: A compliant dining table is not provided.	Kitchen Interior Dining Area	California Accessibility Code	$7,135.39	$7,135.39
850	720968	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Kitchen	Sink	3	CALIFORNIA: The sink does not have the required clear floor space of minimum 30" by minimum 48" for a forward approach with knee and toe clearance.	Culinary Arts Building Interior	California Accessibility Code	$5,391.98	$5,391.98
851	716127	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	California Accessibility Code	$2,458.74	$2,458.74
852	716140	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	CBF Outdoor Rec	ADA	$21,567.93	$21,567.93
853	716229	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	KBF & JKF Visitor Stations	California Accessibility Code	$26,959.91	$26,959.91
854	716256	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	KBF & JKF 100 Pod Lower Level	California Accessibility Code	$9,006.77	$9,006.77
855	717783	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	SLF Lobby Drinking Fountain DF-1	California Accessibility Code	$4,503.38	$4,503.38
856	717790	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	SLF Professional Interview Rooms Visitor and Inmate Sides	California Accessibility Code	$13,479.96	$13,479.96
857	717832	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	SLF Women's Multi Accommodations Restroom RR-6	ADA	$116.83	$116.83
858	717833	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	SLF Women's Multi Accommodations Restroom RR-6	ADA	$359.47	$359.47

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
859	717837	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The drinking fountain is not located completely within alcoves, positioned completely between wing walls, or otherwise positioned so as not to encroach into pedestrian ways.	SLF Sutter Hall Drinking Fountain	California Accessibility Code	$6,755.08	$6,755.08
860	717836	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	CALIFORNIA: A transfer shower stall is provided instead of a standard roll-in shower or alternate roll-in shower stall.	SLF Women's Multi Accommodations Restroom RR-6	California Accessibility Code	$12,906.61	$12,906.61
861	717906	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	SLF Kinya Dorm Drinking Fountain	California Accessibility Code	$4,503.38	$4,503.38
862	717905	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Drinking Fountain/Water Cooler	3	CALIFORNIA: The drinking fountain is not located completely within alcoves, positioned completely between wing walls, or otherwise positioned so as not to encroach into pedestrian ways.	SLF Kinya Dorm Drinking Fountain	California Accessibility Code	$6,755.08	$6,755.08
863	717910	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	The ambulatory stall door is not compliant.	SLF Kinya Dorm Restroom	ADA	$898.66	$898.66
864	717914	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	SLF Kinya Dorm Restroom	ADA	$116.83	$116.83
865	717925	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Common Areas	Picnic Table	3	CALIFORNIA: A compliant picnic table is not provided.	SLF Both Outdoor Rec Areas	California Accessibility Code	$4,673.05	$4,673.05
866	717939	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	SLF Golden Poppy Dorm Restroom RR-1	California Accessibility Code	$1,294.08	$1,294.08
867	717919	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The roll-in shower stall is not compliant.	SLF Kinya Dorm Restroom	California Accessibility Code	$4,044.71	$4,044.71
868	717938	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The water closet in a wheelchair stall in a multi-stall restroom does not have the required clearance.	SLF Golden Poppy Dorm Restroom RR-1	ADA	$2,458.74	$2,458.74
869	717946	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Golden Poppy Dorm Restroom RR-2	ADA	$21,567.93	$21,567.93
870	737127	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Locker and Dressing Rooms	Bench	3	CALIFORNIA - The bench is not compliant in the locker room or dressing room.	Medical Housing Unit Inmate Restroom RR-2	California Accessibility Code	$809.52	$809.52
871	717957	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Detention/Correctional Facilities	Detention Cell	3	Less than 3% of the detention cells are mobility cells.	SLF Ramona Cells	ADA	$1,725,434.32	$1,725,434.32
872	722648	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Urinal	3	The urinal dimensions are not compliant.	Dorms G, H, J, K, Typical Findings	ADA	$6,723.44	$6,723.44
873	722652	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The roll-in shower stall is not compliant.	Dorms G, H, J, K, Typical Findings	California Accessibility Code	$862,717.16	$862,717.16
874	722631	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	Rec Building Visitor Stations 1 & 2	California Accessibility Code	$26,959.91	$26,959.91
875	722649	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Dorms G, H, J, K, Typical Findings	California Accessibility Code	$1,150,289.54	$1,150,289.54
876	725720	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Medical Housing Unit Inmate Restroom RR-2	ADA	$359.47	$359.47
877	725724	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	The urinal dimensions are not compliant.	Medical Housing Unit Inmate Restroom RR-2	ADA	$1,680.86	$1,680.86
878	725740	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	M Dorm Restroom RR-3	California Accessibility Code	$1,294.08	$1,294.08
879	725743	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	M Dorm Restroom RR-3	California Accessibility Code	$1,977.06	$1,977.06
880	722735	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Kitchen Men's Inmate Restroom RR-2	California Accessibility Code	$1,294.08	$1,294.08
881	722732	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Kitchen Men's Inmate Restroom RR-2	California Accessibility Code	$2,458.74	$2,458.74
882	722736	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Kitchen Men's Inmate Restroom	California Accessibility Code	$718.93	$718.93
883	722785	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Dining And Work Surface	3	CALIFORNIA: A compliant dining table is not provided.	Dorm G, H, J & K Interior (Typical Findings)	California Accessibility Code	$2,854.16	$2,854.16
884	716147	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	CALIFORNIA: A transfer shower stall is provided instead of a standard roll-in shower or alternate roll-in shower stall.	CBF Pod Showers	California Accessibility Code	$12,906.61	$12,906.61
885	716151	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Detention/Correctional Facilities	Detention Cell	3	The toilet facilities within the cell are not accessible.	CBF Pods	ADA	$6,470,378.69	$6,470,378.69
886	716164	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Dining	Dining And Work Surface	3	CALIFORNIA: A compliant dining table is not provided.	CBF Interview Room	California Accessibility Code	$1,427.08	$1,427.08
887	716176	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	CBF & SBF 2nd Floor Inmate Visitors Side	California Accessibility Code	$26,959.91	$26,959.91
888	716247	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: The roll-in shower stall is not compliant.	KBF 100 Pod Lower Accessible Restroom RR-7	California Accessibility Code	$4,044.71	$4,044.71
889	716266	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Detention/Correctional Facilities	Detention Cell	3	The toilet facilities within the cell are not accessible.	JKF 100 Pod Holding Tank 1	ADA	$21,567.93	$21,567.93
890	717788	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Judicial Facilities	Visitation Areas	3	At least 5% but no fewer than 1 cubical or counter must be accessible on both the visitor and detainee sides.	SLF Visitor's Room on both sides.	California Accessibility Code	$13,479.96	$13,479.96

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
891	717831	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	SLF Women's Multi Accommodations Restroom RR-6	California Accessibility Code	$1,294.08	$1,294.08
892	717835	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	The wheelchair stall with a floor mounted water closet, in a multi-stall restroom, is less than 60" wide and 59" deep.	SLF Women's Multi Accommodations Restroom RR-6	ADA	$2,458.74	$2,458.74
893	717864	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Dining And Work Surface	3	CALIFORNIA: A compliant dining table is not provided.	SLF Women's Chow Hall	California Accessibility Code	$5,708.31	$5,708.31
894	717834	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	SLF Women's Multi Accommodations Restroom RR-6	California Accessibility Code	$359.47	$359.47
895	717838	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	SLF Sutter Hall Drinking Fountain	California Accessibility Code	$4,503.38	$4,503.38
896	717908	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	The ambulatory stall size is not compliant, or an ambulatory stall is not provided.	SLF Kinya Dorm Restroom	ADA	$2,458.74	$2,458.74
897	717918	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	SLF Kinya Dorm Restroom	California Accessibility Code	$2,458.74	$2,458.74
898	717941	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Transfer Shower Stall	3	CALIFORNIA: A transfer shower stall is provided instead of a standard roll-in shower or alternate roll-in shower stall.	SLF Golden Poppy Dorm Restroom RR-1	California Accessibility Code	$12,906.61	$12,906.61
899	717907	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	SLF Kinya Dorm Restroom	California Accessibility Code	$1,294.08	$1,294.08
900	717917	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a wheelchair stall in a multi-stall restroom does not have the required clearance.	SLF Kinya Dorm Restroom	ADA	$2,458.74	$2,458.74
901	725713	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Detention/Correctional Facilities	Detention Cell	3	Less than 3% of the detention cells are mobility cells.	Medical Housing Unit Holding Cells	ADA	$2,156,792.90	$2,156,792.90
902	725721	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Medical Housing Unit Inmate Restroom RR-2	California Accessibility Code	$1,977.06	$1,977.06
903	725718	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Medical Housing Unit Inmate Restroom RR-2	California Accessibility Code	$1,294.08	$1,294.08
904	725726	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: Grab bars are not provided or are not compliant in the roll-in shower stall.	Medical Housing Unit Inmate Restroom RR-2	California Accessibility Code	$2,246.66	$2,246.66
905	725742	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	M Dorm Restroom RR-3	ADA	$359.47	$359.47
906	725741	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	M Dorm Restroom RR-3	ADA	$116.83	$116.83
907	725749	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: Grab bars are not provided or are not compliant in the roll-in shower stall.	M Dorm Restroom RR-3	California Accessibility Code	$2,246.66	$2,246.66
908	725746	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	The urinal dimensions are not compliant.	M Dorm Restroom RR-3	ADA	$1,680.86	$1,680.86
909	730122	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Clear Space	3	Clear space is not provided at the operable part.	Welding Shop at Door D-8	ADA	$718.93	$718.93
910	722663	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Exterior Access Route	Clear Space	3	Clear space is not provided at the operable part.	Control Point for Dorms C, D, G, & H	ADA	$890.76	$890.76
911	713865	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Gate House Unisex Restroom RR-1	ADA	$657.82	$657.82
912	713869	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Gate House Unisex Restroom RR-1	California Accessibility Code	$503.25	$503.25
913	713873	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Gate House Unisex Restroom RR-1	California Accessibility Code	$359.47	$359.47
914	713881	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Gate House Unisex Restroom RR-2	California Accessibility Code	$503.25	$503.25
915	713885	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Gate House Unisex Restroom RR-2	ADA	$359.47	$359.47
916	713893	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Gate House Control Point Unisex Restroom RR-3	ADA	$657.82	$657.82
917	713864	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Gate House Unisex Restroom RR-1	ADA	$657.82	$657.82
918	713868	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	Gate House Unisex Restroom RR-1	California Accessibility Code	$5,391.98	$5,391.98
919	713872	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	Gate House Unisex Restroom RR-1	California Accessibility Code	$503.25	$503.25
920	713876	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Gate House Unisex Restroom RR-2	ADA	$657.82	$657.82
921	713880	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Gate House Unisex Restroom RR-2	ADA	$116.83	$116.83
922	713884	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Gate House Unisex Restroom RR-2	California Accessibility Code	$359.47	$359.47
923	713892	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The push side of the door does not have the required maneuvering clearances.	Gate House Control Point Unisex Restroom RR-3	ADA	$179.73	$179.73

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
924	713896	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	Gate House Control Point Unisex Restroom RR-3	ADA	$179.73	$179.73
925	713861	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Gate House Door D-1	ADA	$296.56	$296.56
926	713870	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Gate House Unisex Restroom RR-1	ADA	$638.41	$638.41
927	713874	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	Gate House Unisex Restroom RR-2	ADA	$98.85	$98.85
928	713878	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	Gate House Unisex Restroom RR-2	ADA	$2,458.74	$2,458.74
929	713882	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Gate House Unisex Restroom RR-2	ADA	$638.41	$638.41
930	713886	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Gate House Unisex Restroom RR-1	ADA	$116.83	$116.83
931	713890	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Gate House Control Point Unisex Restroom RR-3	California Accessibility Code	$197.71	$197.71
932	713894	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Gate House Control Point Unisex Restroom RR-3	ADA	$657.82	$657.82
933	713898	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	Gate House Control Point Unisex Restroom RR-3	ADA	$1,276.10	$1,276.10
934	713862	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Gate House Unisex Restroom RR-1	California Accessibility Code	$197.71	$197.71
935	713867	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	Gate House Unisex Restroom RR-1	ADA	$2,458.74	$2,458.74
936	713871	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Gate House Unisex Restroom RR-1	ADA	$638.41	$638.41
937	713875	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Gate House Unisex Restroom RR-2	ADA	$657.82	$657.82
938	713879	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	Gate House Unisex Restroom RR-2	California Accessibility Code	$5,391.98	$5,391.98
939	713883	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Gate House Unisex Restroom RR-2	ADA	$638.41	$638.41
940	713897	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Gate House Control Point Unisex Restroom RR-3	ADA	$1,132.32	$1,132.32
941	713901	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	Gate House Control Point Unisex Restroom RR-3	California Accessibility Code	$503.25	$503.25
942	713905	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Gate House Control Point Unisex Restroom RR-3	ADA	$2,246.66	$2,246.66
943	713902	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	Clear floor space is not provided.	Gate House Control Point Unisex Restroom RR-3	ADA	$359.47	$359.47
944	713899	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Gate House Control Point Unisex Restroom RR-3	California Accessibility Code	$503.25	$503.25
945	713903	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	Gate House Control Point Unisex Restroom RR-3	California Accessibility Code	$5,391.98	$5,391.98
946	713900	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Gate House Control Point Unisex Restroom RR-3	California Accessibility Code	$359.47	$359.47
947	713904	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Gate House Control Point Unisex Restroom RR-3	ADA	$359.47	$359.47
948	713981	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Multi-Purpose Mod Engraving and Sign Shop Unisex Restroom RR-1	California Accessibility Code	$197.71	$197.71
949	713986	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Multi-Purpose Mod Engraving and Sign Shop Unisex Restroom RR-1	California Accessibility Code	$718.93	$718.93
950	713999	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	Multi-Purpose Mod JPS & Education Unisex Restroom RR-2	ADA	$2,458.74	$2,458.74
951	713984	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Multi-Purpose Mod Engraving and Sign Shop Unisex Restroom RR-1	California Accessibility Code	$503.25	$503.25
952	713988	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Multi-Purpose Mod Engraving and Sign Shop Unisex Restroom RR-1	ADA	$116.83	$116.83
953	713997	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Multi-Purpose Mod JPS & Education Unisex Restroom RR-2	California Accessibility Code	$503.25	$503.25
954	714606	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Admin Building Throughout Facility	ADA	$593.12	$593.12
955	713987	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Multi-Purpose Mod Engraving and Sign Shop Unisex Restroom RR-1	ADA	$359.47	$359.47
956	713996	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Multi-Purpose Mod JPS & Education Unisex Restroom RR-2	ADA	$179.73	$179.73

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
957	714000	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Multi-Purpose Mod JPS & Education Unisex Restroom RR-2	ADA	$359.47	$359.47
958	714002	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Multi-Purpose Mod JPS & Education Interior	ADA	$197.71	$197.71
959	713985	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	Multi-Purpose Mod Engraving and Sign Shop Unisex Restroom RR-1	ADA	$2,458.74	$2,458.74
960	713989	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Multi-Purpose Mod Engraving and Sign Shop Interior	ADA	$296.56	$296.56
961	713998	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Multi-Purpose Mod JPS & Education Unisex Restroom RR-2	California Accessibility Code	$1,078.40	$1,078.40
962	714616	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	2nd Floor Admin Building Men's Restroom RR-1	ADA	$657.82	$657.82
963	714620	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	2nd Floor Admin Building Men's Restroom RR-1	ADA	$359.47	$359.47
964	714625	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Toilet Stall	3	CALIFORNIA: The wheelchair stall with out-swinging door does not have the required dimensions.	2nd Floor Admin Building Men's Restroom RR-1	California Accessibility Code	$1,977.06	$1,977.06
965	714630	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	2nd Floor Admin Building Women's Restroom RR-2	ADA	$657.82	$657.82
966	714634	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	2nd Floor Admin Building Women's Restroom RR-2	ADA	$359.47	$359.47
967	714638	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Toilet Stall	3	CALIFORNIA: The wheelchair stall with out-swinging door does not have the required dimensions.	2nd Floor Admin Building Women's Restroom RR-2	California Accessibility Code	$1,977.06	$1,977.06
968	714622	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Toilet Stall	3	The wheelchair stall door is not self closing.	2nd Floor Admin Building Men's Restroom RR-1	ADA	$526.26	$526.26
969	714627	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Urinal	3	The urinal dimensions are not compliant.	2nd Floor Admin Building Men's Restroom RR-1	ADA	$1,680.86	$1,680.86
970	714636	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	2nd Floor Admin Building Women's Restroom RR-2	California Accessibility Code	$526.62	$526.62
971	714605	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Elevator	3	Visible and audible signal fixtures indicating which car is answering the call and the car's direction of travel are not compliant.	Admin Building Elevator E-1	ADA	$1,977.06	$1,977.06
972	714603	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Elevator	3	CALIFORNIA: A tactile, raised star minimum 2" high is not provided to the left of the floor designation on both jambs at the main elevator entry level OR existing stars are not compliant.	Admin Building Elevator E-1	California Accessibility Code	$503.25	$503.25
973	714644	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	2nd Floor Admin ISU Office Unisex Restroom RR-3	California Accessibility Code	$197.71	$197.71
974	714649	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	2nd Floor Admin ISU Office Unisex Restroom RR-3	California Accessibility Code	$1,977.06	$1,977.06
975	714653	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	2nd Floor Admin ISU Office Unisex Restroom RR-3	ADA	$359.47	$359.47
976	714664	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	2nd Floor Admin Building Men's Restroom RR-4	ADA	$657.82	$657.82
977	714668	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	2nd Floor Admin Building Men's Restroom RR-4	California Accessibility Code	$2,458.74	$2,458.74
978	714672	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	2nd Floor Admin Building Men's Restroom RR-4	California Accessibility Code	$359.47	$359.47
979	714676	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	2nd Floor Admin Building Women's Restroom RR-5	ADA	$98.85	$98.85
980	714615	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	2nd Floor Admin Building Men's Restroom RR-1	ADA	$98.85	$98.85
981	714619	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	2nd Floor Admin Building Men's Restroom RR-1	California Accessibility Code	$359.47	$359.47
982	714623	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Toilet Stall	3	The hardware at the wheelchair stall door is not compliant.	2nd Floor Admin Building Men's Restroom RR-1	ADA	$526.26	$526.26
983	714629	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	2nd Floor Admin Building Women's Restroom RR-2	ADA	$98.85	$98.85
984	714633	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	2nd Floor Admin Building Women's Restroom RR-2	California Accessibility Code	$359.47	$359.47
985	714637	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Toilet Stall	3	The wheelchair stall door is not compliant.	2nd Floor Admin Building Women's Restroom RR-2	ADA	$898.66	$898.66
986	714646	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Coat Hook	3	The coat hook is not within an allowable reach range.	2nd Floor Admin ISU Office Unisex Restroom RR-3	ADA	$206.69	$206.69
987	714650	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	2nd Floor Admin ISU Office Unisex Restroom RR-3	California Accessibility Code	$179.73	$179.73

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
988	714651	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	2nd Floor Admin ISU Office Unisex Restroom RR-3	ADA	$638.41	$638.41
989	714670	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	2nd Floor Admin Building Men's Restroom RR-4	California Accessibility Code	$503.25	$503.25
990	714674	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	2nd Floor Admin Building Men's Restroom RR-4	ADA	$359.47	$359.47
991	714678	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The hardware at the accessible door requires tight grasping, pinching or twisting of the wrist to operate	2nd Floor Admin Building Women's Restroom RR-5	ADA	$526.62	$526.62
992	714680	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Coat Hook	3	The coat hook is not within an allowable reach range.	2nd Floor Admin Building Women's Restroom RR-5	ADA	$206.69	$206.69
993	714684	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	2nd Floor Admin Building Women's Restroom RR-5	ADA	$638.41	$638.41
994	714688	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	2nd Floor Admin Building Women's Restroom RR-5	California Accessibility Code	$1,294.08	$1,294.08
995	714700	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	California Accessibility Code	$197.71	$197.71
996	714708	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	ADA	$116.83	$116.83
997	714654	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The hardware at the accessible door requires tight grasping, pinching or twisting of the wrist to operate	2nd Floor Admin ISU Office Unisex Restroom RR-3	ADA	$526.62	$526.62
998	714661	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	Admin Building Men's Restroom RR-4	ADA	$98.85	$98.85
999	714665	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The hardware at the accessible door requires tight grasping, pinching or twisting of the wrist to operate	2nd Floor Admin Building Men's Restroom RR-4	ADA	$526.62	$526.62
1000	714669	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	2nd Floor Admin Building Men's Restroom RR-4	California Accessibility Code	$179.73	$179.73
1001	714673	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	2nd Floor Admin Building Men's Restroom RR-4	California Accessibility Code	$898.66	$898.66
1002	714677	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	2nd Floor Admin Building Women's Restroom RR-5	ADA	$657.82	$657.82
1003	714681	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	2nd Floor Admin Building Women's Restroom RR-5	California Accessibility Code	$2,458.74	$2,458.74
1004	714685	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	2nd Floor Admin Building Women's Restroom RR-5	California Accessibility Code	$359.47	$359.47
1005	714617	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	2nd Floor Admin Building Men's Restroom RR-1	ADA	$657.82	$657.82
1006	714621	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	2nd Floor Admin Building Men's Restroom RR-1	ADA	$116.83	$116.83
1007	714626	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	2nd Floor Admin Building Men's Restroom RR-1	ADA	$638.41	$638.41
1008	714631	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	2nd Floor Admin Building Women's Restroom RR-2	ADA	$657.82	$657.82
1009	714635	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	Pipes are not insulated.	2nd Floor Admin Building Women's Restroom RR-2	ADA	$116.83	$116.83
1010	714639	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	2nd Floor Admin Building Women's Restroom RR-2	ADA	$638.41	$638.41
1011	714652	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	2nd Floor Admin ISU Office Unisex Restroom RR-3	California Accessibility Code	$359.47	$359.47
1012	714689	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	2nd Floor Admin Building Women's Restroom RR-5	ADA	$116.83	$116.83
1013	714705	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	California Accessibility Code	$2,458.74	$2,458.74
1014	714709	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	ADA	$359.47	$359.47
1015	714730	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$657.82	$657.82
1016	714734	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Locker	3	The locker area does not have accessible lockers.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$7,122.59	$7,122.59
1017	714738	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The existing shower stall soap dish location is not compliant.	1st Floor Admin Building Men's Locker Room / Restroom	California Accessibility Code	$359.47	$359.47
1018	714742	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	1st Floor Admin Building Men's Locker Room / Restroom	California Accessibility Code	$718.93	$718.93
1019	714750	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$98.85	$98.85

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1020	714755	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Locker and Dressing Rooms	Bench	3	CALIFORNIA - The bench is not compliant in the locker room or dressing room.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$809.52	$809.52
1021	714759	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The existing shower stall soap dish location is not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$359.47	$359.47
1022	714682	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	2nd Floor Admin Building Women's Restroom RR-5	California Accessibility Code	$179.73	$179.73
1023	714686	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	2nd Floor Admin Building Women's Restroom RR-5	California Accessibility Code	$898.66	$898.66
1024	714702	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Coat Hook	3	The coat hook is not within an allowable reach range.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	ADA	$206.69	$206.69
1025	714706	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	California Accessibility Code	$1,977.06	$1,977.06
1026	714710	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	California Accessibility Code	$359.47	$359.47
1027	714667	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Coat Hook	3	The coat hook is not within an allowable reach range.	2nd Floor Admin Building Men's Restroom RR-4	ADA	$206.69	$206.69
1028	714671	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	2nd Floor Admin Building Men's Restroom RR-4	ADA	$638.41	$638.41
1029	714675	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	2nd Floor Admin Building Men's Restroom RR-4	ADA	$116.83	$116.83
1030	714683	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	2nd Floor Admin Building Women's Restroom RR-5	California Accessibility Code	$503.25	$503.25
1031	714687	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	2nd Floor Admin Building Women's Restroom RR-5	ADA	$359.47	$359.47
1032	714694	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Elevator	3	Visible and audible signal fixtures indicating which car is answering the call and the car's direction of travel are not compliant.	Admin Building Elevator E-2	ADA	$1,977.06	$1,977.06
1033	714731	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$657.82	$657.82
1034	714735	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: The controls, faucets, and shower spray unit are not compliant.	1st Floor Admin Building Men's Locker Room / Restroom	California Accessibility Code	$1,168.98	$1,168.98
1035	714739	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	1st Floor Admin Building Men's Locker Room / Restroom	California Accessibility Code	$5,391.98	$5,391.98
1036	714743	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Urinal	3	The urinal dimensions are not compliant.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$1,680.86	$1,680.86
1037	714747	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	1st Floor Admin Building Men's Locker Room / Restroom	California Accessibility Code	$503.25	$503.25
1038	714751	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$657.82	$657.82
1039	714756	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Locker	3	The locker area does not have accessible lockers.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$5,935.49	$5,935.49
1040	714760	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: The controls, faucets, and shower spray unit are not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$1,168.98	$1,168.98
1041	714727	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	1st Floor Admin Building Men's Locker Room / Restroom	California Accessibility Code	$198.42	$198.42
1042	714732	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$2,246.66	$2,246.66
1043	714736	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: A shower seat is not provided or is not compliant.	1st Floor Admin Building Men's Locker Room / Restroom	California Accessibility Code	$1,086.48	$1,086.48
1044	714740	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$116.83	$116.83
1045	714744	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Ambulatory Stall	3	The ambulatory stall size is not compliant, or an ambulatory stall is not provided.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$2,458.74	$2,458.74
1046	714748	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$638.41	$638.41
1047	714752	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$395.41	$395.41
1048	714757	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: A shower seat is not provided or is not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$1,086.48	$1,086.48
1049	714761	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The hardware at the wheelchair stall door is not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$526.26	$526.26
1050	714707	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	California Accessibility Code	$503.25	$503.25
1051	714733	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Locker and Dressing Rooms	Bench	3	CALIFORNIA - The bench is not compliant in the locker room or dressing room.	1st Floor Admin Building Men's Locker Room / Restroom	California Accessibility Code	$809.52	$809.52
1052	714737	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	The roll-in shower stall is not compliant.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$8,538.02	$8,538.02

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1053	714741	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$359.47	$359.47
1054	714745	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Toilet Stall	3	The wheelchair stall door is not compliant.	1st Floor Admin Building Men's Locker Room / Restroom	ADA	$898.66	$898.66
1055	714754	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$657.82	$657.82
1056	714758	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	The roll-in shower stall is not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$8,538.02	$8,538.02
1057	714762	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$179.73	$179.73
1058	714766	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$359.47	$359.47
1059	714767	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$898.66	$898.66
1060	714771	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$638.41	$638.41
1061	725509	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Bookings Building Unisex Restroom RR-2	California Accessibility Code	$197.71	$197.71
1062	725518	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Bookings Building Unisex Restroom RR-2	ADA	$562.56	$562.56
1063	725522	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Bookings Building Unisex Restroom RR-2	ADA	$359.47	$359.47
1064	725526	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Signage	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	Bookings Building Women's Restroom RR-3	California Accessibility Code	$197.71	$197.71
1065	725531	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Bookings Building Women's Restroom RR-3	ADA	$1,132.32	$1,132.32
1066	714764	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$5,391.98	$5,391.98
1067	714768	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The wheelchair stall door is not self closing.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$526.26	$526.26
1068	714772	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The toilet stall door is not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$1,977.06	$1,977.06
1069	725515	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Bookings Building Unisex Restroom RR-2	California Accessibility Code	$179.73	$179.73
1070	725519	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Bookings Building Unisex Restroom RR-2	ADA	$638.41	$638.41
1071	725523	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Bookings Building Unisex Restroom RR-2	California Accessibility Code	$1,294.08	$1,294.08
1072	725532	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Bookings Building Women's Restroom RR-3	ADA	$638.41	$638.41
1073	725535	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Bookings Building Women's Restroom RR-3	ADA	$359.47	$359.47
1074	725571	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Dorm A & B Control Unisex Restroom RR-1 & RR-2	ADA	$4,040.39	$4,040.39
1075	725536	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Bookings Building Women's Restroom RR-3	California Accessibility Code	$1,294.08	$1,294.08
1076	725572	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Dorm A & B Control Unisex Restroom RR-1 & RR-2	ADA	$43,135.86	$43,135.86
1077	725580	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The drinking fountain is not located completely within alcoves, positioned completely between wing walls, or otherwise positioned so as not to encroach into pedestrian ways.	Dorm A, B, C & D Interior Drinking Fountain	California Accessibility Code	$27,020.30	$27,020.30
1078	725590	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Coat Hook	3	The coat hook is not within an allowable reach range.	Dorm A, B, C & D Restrooms	ADA	$826.77	$826.77
1079	725602	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Door	3	Means of egress signage is not provided.	RBF Interior Egress	ADA	$790.82	$790.82
1080	714780	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	1st Floor Admin Inmate Unisex Restroom RR-6	ADA	$657.82	$657.82
1081	714788	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	1st Floor Admin Inmate Unisex Restroom RR-6	ADA	$116.83	$116.83
1082	714792	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The minimum number of drinking fountains is not provided.	1st Floor Admin Building Staff Dining	California Accessibility Code	$4,503.38	$4,503.38
1083	730023	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Honor Facility Classroom 4	ADA	$197.71	$197.71
1084	725637	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	RBF Control Unisex Restroom RR-1	California Accessibility Code	$197.71	$197.71

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1085	714776	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	3	The restroom does not have compliant signage at the door with the International Symbol of Accessibility, raised characters, and Braille.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$98.85	$98.85
1086	714781	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	1st Floor Admin Inmate Unisex Restroom RR-6	ADA	$657.82	$657.82
1087	714785	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	The urinal dimensions are not compliant.	1st Floor Admin Inmate Unisex Restroom RR-6	ADA	$1,680.86	$1,680.86
1088	714789	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	1st Floor Admin Inmate Unisex Restroom RR-6	ADA	$359.47	$359.47
1089	730036	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Honor Facility Classroom Inmate Restroom RR-1	ADA	$562.56	$562.56
1090	730040	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Honor Facility Classroom Inmate Restroom RR-1	California Accessibility Code	$1,294.08	$1,294.08
1091	730045	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Honor Facility Classroom Staff Restroom RR-2	ADA	$657.82	$657.82
1092	730049	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Honor Facility Classroom Staff Restroom RR-2	ADA	$638.41	$638.41
1093	730053	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Honor Facility Classroom Staff Restroom RR-2	California Accessibility Code	$718.93	$718.93
1094	730032	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	Honor Facility Classroom Inmate Restroom RR-1	California Accessibility Code	$198.42	$198.42
1095	730037	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Honor Facility Classroom Inmate Restroom RR-1	ADA	$638.41	$638.41
1096	730041	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Honor Facility Classroom Inmate Restroom RR-1	ADA	$116.83	$116.83
1097	730046	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Honor Facility Classroom Staff Restroom RR-2	ADA	$179.73	$179.73
1098	730050	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Honor Facility Classroom Staff Restroom RR-2	California Accessibility Code	$1,977.06	$1,977.06
1099	730054	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Honor Facility Classroom Staff Restroom RR-2	ADA	$359.47	$359.47
1100	714765	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$116.83	$116.83
1101	714769	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The hardware at the wheelchair stall door is not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$526.26	$526.26
1102	725512	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Bookings Building Unisex Restroom RR-2	ADA	$657.82	$657.82
1103	725516	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Bookings Building Unisex Restroom RR-2	California Accessibility Code	$2,458.74	$2,458.74
1104	725520	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Bookings Building Unisex Restroom RR-2	ADA	$638.41	$638.41
1105	725524	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Bookings Building Unisex Restroom RR-2	ADA	$116.83	$116.83
1106	725529	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Bookings Building Women's Restroom RR-3	California Accessibility Code	$179.73	$179.73
1107	725533	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Bookings Building Women's Restroom RR-3	ADA	$638.41	$638.41
1108	730081	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	DGS Restroom RR-1	ADA	$2,020.20	$2,020.20
1109	730082	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	DGS Restroom RR-1	ADA	$21,567.93	$21,567.93
1110	730137	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	Welding Shop Restroom RR-2	ADA	$1,276.10	$1,276.10
1111	730141	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	The lavatory faucet hardware is not compliant.	Welding Shop Restroom RR-2	ADA	$997.52	$997.52
1112	725537	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Bookings Building Women's Restroom RR-3	ADA	$116.83	$116.83
1113	725573	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	Dorm A & B Control Unisex Restroom RR-1 & RR-2	California Accessibility Code	$1,053.23	$1,053.23
1114	730134	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Welding Shop Restroom RR-2	ADA	$2,020.20	$2,020.20
1115	730138	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Welding Shop Restroom RR-2	California Accessibility Code	$503.25	$503.25
1116	714770	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$1,977.06	$1,977.06
1117	725513	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Bookings Building Unisex Restroom RR-2	ADA	$657.82	$657.82

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1118	725517	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Bookings Building Unisex Restroom RR-2	ADA	$1,132.32	$1,132.32
1119	725521	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Bookings Building Unisex Restroom RR-2	California Accessibility Code	$718.93	$718.93
1120	725530	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Bookings Building Women's Restroom RR-3	California Accessibility Code	$2,458.74	$2,458.74
1121	725534	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Bookings Building Women's Restroom RR-3	California Accessibility Code	$718.93	$718.93
1122	730145	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Portable Restroom	3	An ADA portable restroom is not provided.	Greenhouse Portable Restroom	ADA	$5,391.98	$5,391.98
1123	725612	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Shower	3	The shower does not have sidewalls or grab bars.	RBF Interior East & West Wing Showers	ADA	$10,783.96	$10,783.96
1124	725570	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Dorm A & B Control Unisex Restroom RR-1 & RR-2	California Accessibility Code	$395.41	$395.41
1125	721019	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Psych Building	ADA	$197.71	$197.71
1126	721025	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	Psych Building Women's Restroom RR-1	California Accessibility Code	$526.62	$526.62
1127	721029	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Psych Building Women's Restroom RR-1	California Accessibility Code	$503.25	$503.25
1128	721033	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Psych Building Women's Restroom RR-1	ADA	$116.83	$116.83
1129	725629	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	RBF Interior	ADA	$98.85	$98.85
1130	725638	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	RBF Control Unisex Restroom	ADA	$21,567.93	$21,567.93
1131	714773	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$657.82	$657.82
1132	721026	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Psych Building Women's Restroom RR-1	California Accessibility Code	$1,977.06	$1,977.06
1133	721030	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Psych Building Women's Restroom RR-1	California Accessibility Code	$718.93	$718.93
1134	721034	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Floor Space	3	The required turning space within the restroom is not provided.	Psych Building Women's Restroom RR-1	ADA	$179.73	$179.73
1135	721038	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Psych Building Men's Restroom RR-2	California Accessibility Code	$1,977.06	$1,977.06
1136	721042	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Psych Building Men's Restroom RR-2	ADA	$638.41	$638.41
1137	721046	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Psych Building Men's Restroom RR-2	California Accessibility Code	$718.93	$718.93
1138	721039	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Psych Building Women's Restroom RR-1	ADA	$638.41	$638.41
1139	721043	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Psych Building Men's Restroom RR-2	ADA	$1,132.32	$1,132.32
1140	721047	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Psych Building Men's Restroom RR-2	ADA	$116.83	$116.83
1141	721089	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Medical Trailer Unisex Restroom	California Accessibility Code	$197.71	$197.71
1142	721094	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Medical Trailer Unisex Restroom	ADA	$562.56	$562.56
1143	721098	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Medical Trailer Unisex Restroom	ADA	$116.83	$116.83
1144	714777	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	1st Floor Admin Building Women's Locker Room / Restroom	ADA	$657.82	$657.82
1145	714782	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	1st Floor Admin Inmate Unisex Restroom RR-6	California Accessibility Code	$2,458.74	$2,458.74
1146	714786	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	CALIFORNIA - Flush control is not compliant.	1st Floor Admin Inmate Unisex Restroom RR-6	California Accessibility Code	$999.31	$999.31
1147	728455	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$359.47	$359.47
1148	725613	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: A shower seat is not provided or is not compliant.	RBF Interior East & West Wing Showers	California Accessibility Code	$2,172.97	$2,172.97
1149	725639	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width	RBF Control Unisex Restroom	ADA	$2,020.20	$2,020.20
1150	721113	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Redemption Coffee Unisex Restroom RR-1	California Accessibility Code	$197.71	$197.71

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1151	721118	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Coat Hook	3	The coat hook is not within an allowable reach range.	Redemption Coffee Unisex Restroom RR-1	ADA	$206.69	$206.69
1152	721122	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Redemption Coffee Unisex Restroom RR-1	ADA	$562.56	$562.56
1153	721126	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Redemption Coffee Unisex Restroom RR-1	California Accessibility Code	$359.47	$359.47
1154	721131	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Redemption Coffee Unisex Restroom RR-2	ADA	$657.82	$657.82
1155	721135	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Redemption Coffee Unisex Restroom RR-2	California Accessibility Code	$2,458.74	$2,458.74
1156	721139	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Redemption Coffee Unisex Restroom RR-2	ADA	$638.41	$638.41
1157	721143	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Redemption Coffee Unisex Restroom RR-2	California Accessibility Code	$1,294.08	$1,294.08
1158	721091	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Medical Trailer Unisex Restroom	ADA	$2,246.66	$2,246.66
1159	721095	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Medical Trailer Unisex Restroom	ADA	$638.41	$638.41
1160	721099	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Medical Trailer Unisex Restroom	California Accessibility Code	$1,294.08	$1,294.08
1161	721115	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Redemption Coffee Unisex Restroom RR-1	ADA	$657.82	$657.82
1162	714774	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$526.62	$526.62
1163	714778	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	1st Floor Admin Inmate Unisex Restroom RR-6	California Accessibility Code	$197.71	$197.71
1164	714783	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	1st Floor Admin Inmate Unisex Restroom RR-6	ADA	$1,276.10	$1,276.10
1165	714787	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	1st Floor Admin Inmate Unisex Restroom RR-6	California Accessibility Code	$5,391.98	$5,391.98
1166	714791	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The hardware at the accessible door requires tight grasping, pinching or twisting of the wrist to operate	1st Floor Admin Inmate Unisex Restroom RR-6	ADA	$526.62	$526.62
1167	721152	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Reentry Services Building	ADA	$296.56	$296.56
1168	721160	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Reentry Services Inmate Unisex Restroom RR-1	ADA	$21,567.93	$21,567.93
1169	721165	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Reentry Services Staff Unisex Restroom RR-2	ADA	$2,246.66	$2,246.66
1170	721169	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Reentry Services Staff Unisex Restroom RR-2	ADA	$1,132.32	$1,132.32
1171	721173	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Reentry Services Staff Unisex Restroom RR-2	ADA	$359.47	$359.47
1172	721177	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Coat Hook	3	The coat hook is not within an allowable reach range.	Reentry Services Staff Unisex Restroom RR-2	ADA	$206.69	$206.69
1173	721119	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Redemption Coffee Unisex Restroom RR-1	California Accessibility Code	$1,977.06	$1,977.06
1174	721123	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Redemption Coffee Unisex Restroom RR-1	California Accessibility Code	$503.25	$503.25
1175	721127	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Redemption Coffee Unisex Restroom RR-1	ADA	$359.47	$359.47
1176	721132	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Redemption Coffee Unisex Restroom RR-2	ADA	$657.82	$657.82
1177	721136	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Redemption Coffee Unisex Restroom RR-2	ADA	$1,132.32	$1,132.32
1178	721140	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Redemption Coffee Unisex Restroom RR-2	ADA	$638.41	$638.41
1179	721144	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Redemption Coffee Unisex Restroom RR-2	ADA	$116.83	$116.83
1180	730034	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Honor Facility Classroom Inmate Restroom RR-1	ADA	$657.82	$657.82
1181	730038	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Honor Facility Classroom Inmate Restroom RR-1	ADA	$638.41	$638.41
1182	730047	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Honor Facility Classroom Staff Restroom RR-2	ADA	$1,132.32	$1,132.32
1183	730051	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Honor Facility Classroom Staff Restroom RR-2	California Accessibility Code	$503.25	$503.25

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1184	730055	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	Honor Facility Classroom Staff Restroom RR-2	California Accessibility Code	$526.62	$526.62
1185	722602	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Rec Building Unisex Restroom RR-3	California Accessibility Code	$197.71	$197.71
1186	722607	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Rec Building Unisex Restroom RR-3	ADA	$2,246.66	$2,246.66
1187	722611	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Rec Building Unisex Restroom RR-3	ADA	$638.41	$638.41
1188	722615	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Rec Building Unisex Restroom 1	California Accessibility Code	$1,294.08	$1,294.08
1189	721161	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Reentry Services Staff Unisex Restroom RR-2	California Accessibility Code	$197.71	$197.71
1190	721170	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Reentry Services Staff Unisex Restroom RR-2	ADA	$638.41	$638.41
1191	721174	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	Reentry Services Staff Unisex Restroom RR-2	California Accessibility Code	$5,391.98	$5,391.98
1192	730035	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Honor Facility Classroom Inmate Restroom RR-1	ADA	$1,132.32	$1,132.32
1193	730039	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Honor Facility Classroom Inmate Restroom RR-1	California Accessibility Code	$1,977.06	$1,977.06
1194	730043	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Signage	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Honor Facility Classroom Staff Restroom RR-2	California Accessibility Code	$197.71	$197.71
1195	730048	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Honor Facility Classroom Staff Restroom RR-2	ADA	$638.41	$638.41
1196	730052	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Honor Facility Classroom Staff Restroom RR-2	ADA	$116.83	$116.83
1197	722604	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	Rec Building Unisex Restroom RR-3	California Accessibility Code	$526.62	$526.62
1198	722608	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Rec Building Unisex Restroom RR-3	California Accessibility Code	$1,977.06	$1,977.06
1199	722612	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Rec Building Unisex Restroom RR-3	ADA	$638.41	$638.41
1200	722687	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Honor Facility Laundry Inmate Restroom RR-1	ADA	$2,020.20	$2,020.20
1201	722715	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Kitchen Staff Break-room Restroom RR-1	ADA	$657.82	$657.82
1202	730131	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Auto Shop Interior	ADA	$197.71	$197.71
1203	730135	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The wheelchair stall with in-swinging door does not have the required dimensions.	Welding Shop Restroom RR-2	California Accessibility Code	$1,977.06	$1,977.06
1204	730139	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Welding Shop Restroom RR-2	California Accessibility Code	$1,294.08	$1,294.08
1205	722720	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Kitchen Staff Breakroom Restroom RR-1	ADA	$638.41	$638.41
1206	722724	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Kitchen Staff Breakroom Restroom RR-1	ADA	$359.47	$359.47
1207	722745	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Kitchen	Sink	3	CALIFORNIA: The sink does not have the required clear floor space of minimum 30" by minimum 48" for a forward approach with knee and toe clearance.	Kitchen Interior Sink	California Accessibility Code	$16,175.95	$16,175.95
1208	722688	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Honor Facility Laundry Staff Restroom RR-2	California Accessibility Code	$197.71	$197.71
1209	722693	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Honor Facility Laundry	ADA	$296.56	$296.56
1210	722716	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Kitchen Staff Breakroom Restroom RR-1	ADA	$657.82	$657.82
1211	722773	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	Dorm J & K Control Staff Restroom RR-1	California Accessibility Code	$526.62	$526.62
1212	722786	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Dorm G, H, J & K Interior (Typical Findings)	ADA	$395.41	$395.41
1213	730143	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Welding Shop Restroom RR-2	California Accessibility Code	$718.93	$718.93
1214	730128	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Portable Restroom	3	An ADA portable restroom is not provided.	Auto Shop Portable Restrooms	ADA	$5,391.98	$5,391.98
1215	722721	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Kitchen Staff Breakroom Restroom RR-1	ADA	$1,132.32	$1,132.32
1216	722725	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Kitchen Staff Breakroom Restroom RR-1	California Accessibility Code	$718.93	$718.93

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1217	722730	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Kitchen Men's Inmate Restroom RR-2	ADA	$657.82	$657.82
1218	722734	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Urinal	3	The urinal dimensions are not compliant.	Kitchen Men's Inmate Restroom RR-2	ADA	$1,680.86	$1,680.86
1219	722770	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	Pipes are not insulated.	Dorm J & K Control Room	ADA	$116.83	$116.83
1220	722774	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Dorm J & K Control Staff Restroom RR-1	ADA	$2,020.20	$2,020.20
1221	722791	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Dorm G, H, J & K Restrooms (Typical Findings)	ADA	$467.31	$467.31
1222	722795	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Dorm G, H, J & K Restrooms (Typical Findings)	ADA	$4,529.27	$4,529.27
1223	722790	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Dorm G, H, J & K Restrooms (Typical Findings)	California Accessibility Code	$5,176.30	$5,176.30
1224	722794	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	Dorm G, H, J & K Restrooms (Typical Findings)	ADA	$5,104.41	$5,104.41
1225	722807	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Booking Interior Unisex Restroom 1	ADA	$2,020.20	$2,020.20
1226	722811	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Booking Interior Unisex Restroom 1	California Accessibility Code	$1,294.08	$1,294.08
1227	722815	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	The urinal dimensions are not compliant.	Booking Interior Unisex Restroom 1	ADA	$1,680.86	$1,680.86
1228	730136	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Welding Shop Restroom RR-2	ADA	$1,132.32	$1,132.32
1229	730140	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Welding Shop Restroom RR-2	ADA	$116.83	$116.83
1230	730144	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Welding Shop Restroom RR-2	ADA	$359.47	$359.47
1231	722808	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Booking Interior Unisex Restroom 1	ADA	$657.82	$657.82
1232	722812	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Booking Interior Unisex Restroom 1	ADA	$116.83	$116.83
1233	722816	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	CALIFORNIA - Flush control is not compliant.	Booking Interior Unisex Restroom 1	California Accessibility Code	$999.31	$999.31
1234	716083	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	California Accessibility Code	$197.71	$197.71
1235	721027	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Psych Building Women's Restroom RR-1	ADA	$1,132.32	$1,132.32
1236	720969	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Culinary Arts Building	ADA	$197.71	$197.71
1237	716085	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$657.82	$657.82
1238	716089	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	California Accessibility Code	$2,458.74	$2,458.74
1239	716088	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$2,458.74	$2,458.74
1240	716092	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	California Accessibility Code	$503.25	$503.25
1241	716096	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	Pipes are not insulated.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$116.83	$116.83
1242	716100	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The hardware at the wheelchair stall door is not compliant.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$526.26	$526.26
1243	716122	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	California Accessibility Code	$197.71	$197.71
1244	721031	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	Psych Building Women's Restroom RR-1	California Accessibility Code	$503.25	$503.25
1245	721035	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	Psych Building Men's Restroom RR-2	California Accessibility Code	$198.42	$198.42
1246	721040	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Psych Building Women's Restroom RR-1	ADA	$638.41	$638.41
1247	721044	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Psych Building Men's Restroom RR-2	California Accessibility Code	$503.25	$503.25
1248	716093	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	California Accessibility Code	$503.25	$503.25
1249	716097	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	California Accessibility Code	$359.47	$359.47

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1250	716101	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	1st Floor Passage Hallway CBF Inmate Unisex Restroom RR-2	California Accessibility Code	$197.71	$197.71
1251	716106	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	1st Floor Passage Hallway CBF Inmate Unisex Restroom RR-2	ADA	$1,132.32	$1,132.32
1252	716124	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	ADA	$657.82	$657.82
1253	716131	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	California Accessibility Code	$1,294.08	$1,294.08
1254	716161	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	1st Floor CBF Medical Restroom	ADA	$2,020.20	$2,020.20
1255	721023	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	Psych Building Women's Restroom RR-1	California Accessibility Code	$197.71	$197.71
1256	721028	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Psych Building Women's Restroom RR-1	ADA	$562.56	$562.56
1257	716128	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	ADA	$562.56	$562.56
1258	716132	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	California Accessibility Code	$359.47	$359.47
1259	716162	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	CBF Medical Restroom	ADA	$21,567.93	$21,567.93
1260	716170	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The hardware at the accessible door requires tight grasping, pinching or twisting of the wrist to operate	CBF 2nd Floor Classroom Restroom	ADA	$526.62	$526.62
1261	716185	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	JKF Control Bottom Tier Staff Unisex Restroom RR-3	California Accessibility Code	$197.71	$197.71
1262	716194	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	JKF Control Bottom Tier Staff Unisex Restroom RR-3	California Accessibility Code	$359.47	$359.47
1263	716206	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	JKF 448 Medical Staff Unisex Restroom RR-4	California Accessibility Code	$5,391.98	$5,391.98
1264	716214	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	KBF Holding Tank 2 Accessible	California Accessibility Code	$1,294.08	$1,294.08
1265	716191	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	JKF Control Bottom Tier Staff Unisex Restroom RR-3	California Accessibility Code	$5,391.98	$5,391.98
1266	716203	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	JKF 448 Medical Staff Unisex Restroom RR-4	ADA	$2,458.74	$2,458.74
1267	716207	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	JKF 448 Medical Staff Unisex Restroom RR-4	ADA	$359.47	$359.47
1268	716211	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	KBF Holding Tank 2 Accessible	ADA	$2,458.74	$2,458.74
1269	716221	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	KBF Control Point Access 801 Unisex Restroom RR-5	California Accessibility Code	$503.25	$503.25
1270	721032	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	Psych Building Women's Restroom RR-1	California Accessibility Code	$5,391.98	$5,391.98
1271	721037	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	Psych Building Men's Restroom RR-2	California Accessibility Code	$526.62	$526.62
1272	721041	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Psych Building Men's Restroom RR-2	ADA	$638.41	$638.41
1273	721045	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	Psych Building Men's Restroom RR-2	California Accessibility Code	$503.25	$503.25
1274	716224	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	KBF Control Point Access 801 Unisex Restroom RR-5	California Accessibility Code	$718.93	$718.93
1275	716236	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	KBF & JKF Classroom Inmate Restroom RR-6	California Accessibility Code	$198.42	$198.42
1276	716241	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	KBF & JKF Classroom Inmate Restroom RR-6	ADA	$562.56	$562.56
1277	716245	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	KBF 100 Pod Lower Accessible Restroom RR-7	California Accessibility Code	$1,294.08	$1,294.08
1278	716264	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	JKF 100 Pod Lower Accessible Restroom RR-8	ADA	$562.56	$562.56
1279	721092	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Medical Trailer Unisex Restroom	California Accessibility Code	$1,977.06	$1,977.06
1280	721096	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Medical Trailer Unisex Restroom	ADA	$638.41	$638.41
1281	716242	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	KBF & JKF Classroom Inmate Restroom RR-6	California Accessibility Code	$1,294.08	$1,294.08
1282	716246	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	KBF 100 Pod Lower Accessible Restroom RR-7	ADA	$359.47	$359.47

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1283	716261	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The existing shower stall soap dish location is not compliant.	JKF 100 Pod Lower Accessible Restroom RR-8	California Accessibility Code	$359.47	$359.47
1284	717768	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	SLF Unisex Restroom RR-1	California Accessibility Code	$197.71	$197.71
1285	717773	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Unisex Restroom RR-1	ADA	$21,567.93	$21,567.93
1286	717778	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Unisex Restroom RR-2	ADA	$657.82	$657.82
1287	717782	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	3	CALIFORNIA: The drinking fountain is not located completely within alcoves, positioned completely between wing walls, or otherwise positioned so as not to encroach into pedestrian ways.	SLF Lobby Drinking Fountain DF-1	California Accessibility Code	$6,755.08	$6,755.08
1288	721093	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Medical Trailer Unisex Restroom	California Accessibility Code	$2,458.74	$2,458.74
1289	721097	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Medical Trailer Unisex Restroom	California Accessibility Code	$1,078.40	$1,078.40
1290	716269	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	KBF & JKF Outdoor Rec Restrooms	ADA	$4,917.49	$4,917.49
1291	716273	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	SBF Inner and Outer Door Corridor	ADA	$98.85	$98.85
1292	717770	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width	SLF Unisex Restroom RR-1	ADA	$2,020.20	$2,020.20
1293	717774	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	SLF Unisex Restroom RR-1	California Accessibility Code	$1,053.23	$1,053.23
1294	717779	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	SLF Unisex Restroom RR-2	ADA	$657.82	$657.82
1295	721116	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Redemption Coffee Unisex Restroom RR-1	ADA	$657.82	$657.82
1296	721120	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Redemption Coffee Unisex Restroom RR-1	California Accessibility Code	$2,458.74	$2,458.74
1297	721124	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Redemption Coffee Unisex Restroom RR-1	ADA	$638.41	$638.41
1298	721128	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Redemption Coffee Unisex Restroom RR-1	ADA	$116.83	$116.83
1299	721133	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	Redemption Coffee Unisex Restroom RR-2	ADA	$2,246.66	$2,246.66
1300	721137	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Redemption Coffee Unisex Restroom RR-2	ADA	$562.56	$562.56
1301	721141	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Redemption Coffee Unisex Restroom RR-2	California Accessibility Code	$718.93	$718.93
1302	717797	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	SLF Control Room Unisex Restroom RR-3	California Accessibility Code	$197.71	$197.71
1303	717814	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width	SLF Property Room Restroom RR-4	ADA	$2,020.20	$2,020.20
1304	717823	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Property Room Restroom RR-4	ADA	$21,567.93	$21,567.93
1305	717815	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Property Room Restroom RR-4	ADA	$657.82	$657.82
1306	717820	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Property Room Restroom RR-4	ADA	$21,567.93	$21,567.93
1307	717824	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	SLF Women's Multi Accommodations Restroom RR-6	California Accessibility Code	$197.71	$197.71
1308	717829	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width	SLF Women's Multi Accommodations Restroom RR-6	ADA	$2,020.20	$2,020.20
1309	721121	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Redemption Coffee Unisex Restroom RR-1	ADA	$1,132.32	$1,132.32
1310	721125	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Redemption Coffee Unisex Restroom RR-1	ADA	$638.41	$638.41
1311	721129	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Redemption Coffee Unisex Restroom RR-2	California Accessibility Code	$197.71	$197.71
1312	721134	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Redemption Coffee Unisex Restroom RR-2	California Accessibility Code	$1,977.06	$1,977.06
1313	721138	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Redemption Coffee Unisex Restroom RR-2	California Accessibility Code	$503.25	$503.25
1314	721142	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Redemption Coffee Unisex Restroom RR-2	ADA	$359.47	$359.47

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1315	717855	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Women's Staff Restroom RR-7	ADA	$21,567.93	$21,567.93
1316	717866	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Kitchen	Sink	3	CALIFORNIA: The sink does not have the required clear floor space of minimum 30" by minimum 48" for a forward approach with knee and toe clearance.	SLF Women's Chow Hall	California Accessibility Code	$5,391.98	$5,391.98
1317	717873	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Rec Office Unisex Restroom RR-10	ADA	$21,567.93	$21,567.93
1318	717878	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	SLF Rec Office Unisex Restroom RR-10	ADA	$359.47	$359.47
1319	717853	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	SLF Women's Staff Restroom RR-7	California Accessibility Code	$197.71	$197.71
1320	717871	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	SLF Rec Office Unisex Restroom RR-10	California Accessibility Code	$197.71	$197.71
1321	717876	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	SLF Rec Office Unisex Restroom RR-10	California Accessibility Code	$359.47	$359.47
1322	721145	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Common Areas	Dining And Work Surface	3	CALIFORNIA: A compliant dining table is not provided.	Redemption Coffee Outdoor Seating	California Accessibility Code	$2,336.53	$2,336.53
1323	721163	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Reentry Services Staff Unisex Restroom RR-2	ADA	$657.82	$657.82
1324	721167	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Reentry Services Staff Unisex Restroom RR-2	California Accessibility Code	$1,977.06	$1,977.06
1325	721171	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Reentry Services Staff Unisex Restroom RR-2	ADA	$638.41	$638.41
1326	721175	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	Reentry Services Staff Unisex Restroom RR-2	California Accessibility Code	$1,294.08	$1,294.08
1327	717911	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Door	3	The hardware at the Ambulatory stall door is not compliant.	SLF Kinya Dorm Restroom	ADA	$526.26	$526.26
1328	717916	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Door	3	The hardware at the wheelchair stall door is not compliant.	SLF Kinya Dorm Restroom	ADA	$526.26	$526.26
1329	721159	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Reentry Services Inmate Unisex Restroom RR-1	California Accessibility Code	$197.71	$197.71
1330	721164	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Reentry Services Staff Unisex Restroom RR-2	ADA	$657.82	$657.82
1331	721168	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Reentry Services Staff Unisex Restroom RR-2	California Accessibility Code	$2,458.74	$2,458.74
1332	721172	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Reentry Services Staff Unisex Restroom RR-2	California Accessibility Code	$718.93	$718.93
1333	721176	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Reentry Services Staff Unisex Restroom RR-2	ADA	$116.83	$116.83
1334	722596	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Rec Building	ADA	$296.56	$296.56
1335	722605	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	Rec Building Unisex Restroom RR-3	ADA	$657.82	$657.82
1336	722609	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	Rec Building Unisex Restroom RR-3	California Accessibility Code	$2,458.74	$2,458.74
1337	722613	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	Rec Building Unisex Restroom RR-3	ADA	$1,125.13	$1,125.13
1338	725667	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	RCCC Warehouse Staff Unisex Restroom RR-1	California Accessibility Code	$197.71	$197.71
1339	722606	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Rec Building Unisex Restroom RR-3	ADA	$657.82	$657.82
1340	722610	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	Rec Building Unisex Restroom RR-3	ADA	$1,132.32	$1,132.32
1341	722614	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	CALIFORNIA - Flush control is not compliant.	Rec Building Unisex Restroom 1	California Accessibility Code	$999.31	$999.31
1342	725670	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	RCCC Warehouse Staff Unisex Restroom RR-1	ADA	$1,276.10	$1,276.10
1343	725674	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	The lavatory is mounted higher than 34" to the higher of the rim or counter.	RCCC Warehouse Staff Unisex Restroom RR-1	ADA	$1,294.08	$1,294.08
1344	725678	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	RCCC Warehouse Staff Unisex Restroom RR-1	ADA	$359.47	$359.47
1345	725682	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	RCCC Warehouse Inmate Men's Restroom RR-2	ADA	$657.82	$657.82
1346	725686	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	The urinal dimensions are not compliant.	RCCC Warehouse Inmate Men's Restroom RR-2	ADA	$1,680.86	$1,680.86

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1347	725690	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	RCCC Warehouse Inmate Men's Restroom	ADA	$359.47	$359.47
1348	725671	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	The urinal dimensions are not compliant.	RCCC Warehouse Staff Unisex Restroom RR-1	ADA	$1,680.86	$1,680.86
1349	725675	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	RCCC Warehouse Staff Unisex Restroom RR-1	ADA	$116.83	$116.83
1350	725679	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width	RCCC Warehouse Inmate Men's Restroom RR-2	ADA	$2,020.20	$2,020.20
1351	725683	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	RCCC Warehouse Inmate Men's Restroom RR-2	California Accessibility Code	$2,458.74	$2,458.74
1352	725687	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	RCCC Warehouse Inmate Men's Restroom RR-2	California Accessibility Code	$5,391.98	$5,391.98
1353	725719	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	Medical Housing Unit Inmate Restroom RR-2	ADA	$116.83	$116.83
1354	725723	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	Medical Housing Unit Inmate Restroom RR-2	ADA	$638.41	$638.41
1355	725727	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: A shower seat is not provided or is not compliant.	Medical Housing Unit Inmate Restroom RR-2	California Accessibility Code	$1,086.48	$1,086.48
1356	725708	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Medical Housing Unit Staff Restroom RR-1	ADA	$21,567.93	$21,567.93
1357	722684	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Honor Facility Laundry Inmate Restroom RR-1	California Accessibility Code	$197.71	$197.71
1358	722690	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Honor Facility Laundry Staff Restroom RR-2	ADA	$21,567.93	$21,567.93
1359	722686	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Honor Facility Laundry Inmate Restroom RR-1	ADA	$21,567.93	$21,567.93
1360	722691	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	Honor Facility Laundry Staff Restroom RR-2	ADA	$2,020.20	$2,020.20
1361	725744	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	M Dorm Restroom RR-3	ADA	$638.41	$638.41
1362	727698	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	2nd Floor Admin Building Women's Restroom RR-2	California Accessibility Code	$898.66	$898.66
1363	722718	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	Kitchen Staff Breakroom Restroom RR-1	California Accessibility Code	$526.62	$526.62
1364	722722	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The toilet paper dispenser is not compliant.	Kitchen Staff Breakroom Restroom RR-1	California Accessibility Code	$503.25	$503.25
1365	722726	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Floor Space	3	The required turning space within the restroom is not provided.	Kitchen Staff Breakroom Restroom RR-1	ADA	$2,516.26	$2,516.26
1366	722731	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	Kitchen Men's Inmate Restroom RR-2	ADA	$657.82	$657.82
1367	722713	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Kitchen Staff Breakroom Restroom RR-1	California Accessibility Code	$197.71	$197.71
1368	722719	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Kitchen Staff Breakroom Restroom RR-1	California Accessibility Code	$1,977.06	$1,977.06
1369	722723	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	Pipes are not insulated.	Kitchen Staff Breakroom Restroom RR-1	ADA	$116.83	$116.83
1370	722727	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Unisex	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	Kitchen Men's Inmate Restroom RR-2	California Accessibility Code	$198.42	$198.42
1371	722775	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Dorm J & K Control Staff Restroom RR-1	ADA	$21,567.93	$21,567.93
1372	722762	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Dorms C, D, G, & H	ADA	$1,186.24	$1,186.24
1373	722772	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Dorm J & K Control Staff Restroom RR-1	California Accessibility Code	$197.71	$197.71
1374	722793	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA- The water closet does not have the required clear floor space.	Dorm G, H, J & K Restrooms (Typical Findings)	California Accessibility Code	$7,908.24	$7,908.24
1375	722805	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Booking Interior Unisex Restroom 1	California Accessibility Code	$197.71	$197.71
1376	722814	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	Booking Interior Unisex Restroom 1	California Accessibility Code	$718.93	$718.93
1377	722792	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Urinal	3	The urinal dimensions are not compliant.	Dorm G, H, J & K Restrooms (Typical Findings)	ADA	$6,723.44	$6,723.44
1378	722796	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The roll-in shower stall is not compliant.	Dorm G, H, J & K Restrooms (Typical Findings)	California Accessibility Code	$16,178.82	$16,178.82
1379	722809	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The roll-in shower stall is not compliant.	Booking Interior Unisex Restroom 1	California Accessibility Code	$5,032.52	$5,032.52

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1380	722813	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	Booking Interior Unisex Restroom 1	ADA	$359.47	$359.47
1381	722817	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	A wheelchair stall is not provided in a multi-user restroom.	Booking Interior Unisex Restroom 1	ADA	$4,942.65	$4,942.65
1382	722828	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	Booking Interior	ADA	$889.68	$889.68
1383	716086	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$657.82	$657.82
1384	716090	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$638.41	$638.41
1385	716094	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$359.47	$359.47
1386	716098	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	CALIFORNIA - Flush control is not compliant.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	California Accessibility Code	$999.31	$999.31
1387	716103	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	1st Floor Passage Hallway CBF Inmate Unisex Restroom RR-2	ADA	$657.82	$657.82
1388	716107	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	1st Floor Passage Hallway CBF Inmate Unisex Restroom RR-2	California Accessibility Code	$1,294.08	$1,294.08
1389	716091	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$638.41	$638.41
1390	716095	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	The lavatory is mounted higher than 34" to the higher of the rim or counter.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$1,294.08	$1,294.08
1391	716099	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Coat Hook	3	The coat hook is not within an allowable reach range.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	ADA	$206.69	$206.69
1392	716104	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	1st Floor Passage Hallway CBF Inmate Unisex Restroom RR-2	ADA	$657.82	$657.82
1393	716108	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	1st Floor Passage Hallway CBF Inmate Unisex Restroom RR-2	California Accessibility Code	$359.47	$359.47
1394	716120	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Kitchen	Sink	3	CALIFORNIA: The sink does not have the required clear floor space of minimum 30" by minimum 48" for a forward approach with knee and toe clearance.	1st Floor Satellite Kitchen JKF & KBF	California Accessibility Code	$5,391.98	$5,391.98
1395	716125	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	ADA	$657.82	$657.82
1396	716129	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The toilet paper dispenser is not compliant.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	California Accessibility Code	$503.25	$503.25
1397	716138	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	Control Point Space CBF	ADA	$21,567.93	$21,567.93
1398	716126	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	ADA	$2,458.74	$2,458.74
1399	716130	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	1st Floor Satellite Kitchen JKF & KBF Unisex Restroom RR-2	ADA	$638.41	$638.41
1400	716155	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	3	CALIFORNIA: An elevator is required but not provided.	CBF Access to Classroom & Visitor Area	California Accessibility Code	$431,358.58	$431,358.58
1401	716171	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	CBF 2nd Floor Classroom Restroom	ADA	$21,567.93	$21,567.93
1402	716188	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	JKF Control Bottom Tier Staff Unisex Restroom RR-3	ADA	$2,458.74	$2,458.74
1403	716192	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	JKF Control Bottom Tier Staff Unisex Restroom RR-3	ADA	$116.83	$116.83
1404	716160	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	1st Floor CBF Medical Restroom	California Accessibility Code	$197.71	$197.71
1405	716189	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	JKF Control Bottom Tier Staff Unisex Restroom RR-3	California Accessibility Code	$503.25	$503.25
1406	716193	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	JKF Control Bottom Tier Staff Unisex Restroom RR-3	ADA	$359.47	$359.47
1407	716200	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	JKF 448 Medical Staff Unisex Restroom RR-4	California Accessibility Code	$197.71	$197.71
1408	716205	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	JKF 448 Medical Staff Unisex Restroom RR-4	California Accessibility Code	$1,294.08	$1,294.08
1409	716213	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	KBF Holding Tank 2 Accessible	ADA	$562.56	$562.56
1410	716218	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	KBF Control Point Access 801 Unisex Restroom RR-5	California Accessibility Code	$197.71	$197.71
1411	716223	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The centerline of the lavatory is less than 18" from the side wall or partition wall.	KBF Control Point Access 801 Unisex Restroom RR-5	California Accessibility Code	$5,391.98	$5,391.98

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1412	716240	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	KBF & JKF Classroom Inmate Restroom RR-6	ADA	$638.41	$638.41
1413	716204	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: The disposal unit at the water closet is not compliant.	JKF 448 Medical Staff Unisex Restroom RR-4	California Accessibility Code	$503.25	$503.25
1414	716208	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Reach Range	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	JKF 448 Medical Staff Unisex Restroom RR-4	California Accessibility Code	$359.47	$359.47
1415	716212	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	KBF Holding Tank 2 Accessible	ADA	$638.41	$638.41
1416	716226	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	KBF Control Point Access 801 Unisex Restroom RR-5	ADA	$359.47	$359.47
1417	716239	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The water closet in a single user / unisex restroom does not have the required clearance.	KBF & JKF Classroom Inmate Restroom RR-6	ADA	$2,458.74	$2,458.74
1418	716244	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	KBF 100 Pod Lower Accessible Restroom RR-7	ADA	$562.56	$562.56
1419	716248	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: The existing shower stall soap dish location is not compliant.	KBF 100 Pod Lower Accessible Restroom RR-7	California Accessibility Code	$359.47	$359.47
1420	716258	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: The roll-in shower stall is not compliant.	JKF 100 Pod Lower Accessible Restroom RR-8	California Accessibility Code	$4,044.71	$4,044.71
1421	716263	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	CALIFORNIA: The centerline of the toilet in the wheelchair stall or single-user restroom is not 17" minimum to 18" maximum from the sidewall.	JKF 100 Pod Lower Accessible Restroom RR-8	California Accessibility Code	$2,458.74	$2,458.74
1422	716267	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	KBF & JKF Outdoor Rec Restrooms	ADA	$2,552.20	$2,552.20
1423	716271	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	KBF & JKF Outdoor Rec Restrooms	California Accessibility Code	$2,588.15	$2,588.15
1424	716243	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	KBF 100 Pod Lower Accessible Restroom RR-7	ADA	$638.41	$638.41
1425	716257	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	JKF 100 Pod Lower Accessible Restroom RR-8	California Accessibility Code	$1,294.08	$1,294.08
1426	716262	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	JKF 100 Pod Lower Accessible Restroom RR-8	ADA	$638.41	$638.41
1427	716270	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Water Closet	3	The flush control is located on the closed side and/or is not within reach range.	KBF & JKF Outdoor Rec Restrooms	ADA	$1,125.13	$1,125.13
1428	717772	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	SLF Unisex Restroom RR-1	ADA	$657.82	$657.82
1429	717777	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width	SLF Unisex Restroom RR-2	ADA	$2,020.20	$2,020.20
1430	717781	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The hardware at the accessible door is not compliant.	SLF Unisex Restroom RR-2	California Accessibility Code	$1,053.23	$1,053.23
1431	717813	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The pull side of the accessible door does not have the required maneuvering clearances.	SLF Property Room Restroom RR-4	ADA	$359.47	$359.47
1432	717817	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	SLF Property Room Restroom RR-4	California Accessibility Code	$197.71	$197.71
1433	717822	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	SLF Nurses Office Restroom RR-5	California Accessibility Code	$197.71	$197.71
1434	717771	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Unisex Restroom RR-1	ADA	$657.82	$657.82
1435	717775	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	SLF Unisex Restroom RR-2	California Accessibility Code	$197.71	$197.71
1436	717780	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Unisex Restroom RR-2	ADA	$21,567.93	$21,567.93
1437	717784	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	3	Means of egress signage is not provided.	SLF Facility Wide	ADA	$790.82	$790.82
1438	717802	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Control Room Unisex Restroom RR-3	ADA	$21,567.93	$21,567.93
1439	717816	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	SLF Property Room Restroom RR-4	ADA	$657.82	$657.82
1440	717827	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The force required to open the interior, hinged, non-fire door is more than 5 pounds.	SLF Women's Multi Accommodations Restroom RR-6	ADA	$657.82	$657.82
1441	717858	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Women's Staff Restroom RR-8	ADA	$21,567.93	$21,567.93
1442	717826	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The accessible door with door closer has a sweep period of less than 5 seconds from 90 degrees to a position 12 degrees from latch.	SLF Women's Multi Accommodations Restroom RR-6	ADA	$657.82	$657.82
1443	717856	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	SLF Women's Staff Restroom RR-8	California Accessibility Code	$197.71	$197.71
1444	717867	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	CALIFORNIA: The women's restroom does not have compliant signage at the door.	SLF Women's Chow Hall Restroom RR-9	California Accessibility Code	$197.71	$197.71

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1445	717874	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	SLF Rec Office Unisex Restroom RR-10	California Accessibility Code	$1,294.08	$1,294.08
1446	717869	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	The entire restroom is not compliant due to limited room dimensions.	SLF Women's Chow Hall Restroom RR-9	ADA	$21,567.93	$21,567.93
1447	717875	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	SLF Rec Office Unisex Restroom RR-10	California Accessibility Code	$179.73	$179.73
1448	717921	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Roll-In Shower Stall	3	CALIFORNIA: A shower seat is not provided or is not compliant.	SLF Kinya Dorm Restroom	California Accessibility Code	$1,086.48	$1,086.48
1449	725669	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Toilet Stall	3	A wheelchair stall is not provided in a multi-user restroom.	RCCC Warehouse Staff Unisex Restroom RR-1	ADA	$4,942.65	$4,942.65
1450	717940	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom-Mirror	3	The mirror is mounted higher than 40" above finish floor to the bottom of the reflective surface, where it is installed above a lavatory or counter.	SLF Golden Poppy Dorm Restroom RR-1	ADA	$359.47	$359.47
1451	725668	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The door has less than 32" clear width.	RCCC Warehouse Staff Unisex Restroom RR-1	ADA	$2,020.20	$2,020.20
1452	725672	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	The clear floor space at the urinal is less than minimum 30" by minimum 48".	RCCC Warehouse Staff Unisex Restroom RR-1	ADA	$1,977.06	$1,977.06
1453	725676	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Controls And Dispensers	3	CALIFORNIA: Dispensers in restrooms are not located maximum 40" AFF.	RCCC Warehouse Staff Unisex Restroom RR-1	California Accessibility Code	$1,078.40	$1,078.40
1454	725680	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The men's restroom does not have compliant signage at the door.	RCCC Warehouse Inmate Men's Restroom RR-2	California Accessibility Code	$198.42	$198.42
1455	725684	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	RCCC Warehouse Inmate Men's Restroom RR-2	ADA	$1,132.32	$1,132.32
1456	725688	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	CALIFORNIA: The lavatory does not have the required knee and toe clearance.	RCCC Warehouse Inmate Men's Restroom RR-2	California Accessibility Code	$1,294.08	$1,294.08
1457	725673	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Urinal	3	CALIFORNIA - Flush control is not compliant.	RCCC Warehouse Staff Unisex Restroom RR-1	California Accessibility Code	$999.31	$999.31
1458	725677	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The height of the water closet is not 17" minimum to 19" maximum above finished floor.	RCCC Warehouse Staff Unisex Restroom RR-1	ADA	$1,132.32	$1,132.32
1459	725681	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Door	3	The push side of the door does not have the required maneuvering clearances.	RCCC Warehouse Inmate Men's Restroom RR-2	ADA	$2,246.66	$2,246.66
1460	725685	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The grab bars at the water closet are not compliant.	RCCC Warehouse Inmate Men's Restroom RR-2	ADA	$1,276.10	$1,276.10
1461	725689	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Lavatory	3	Pipes are not insulated.	RCCC Warehouse Inmate Men's Restroom	ADA	$116.83	$116.83
1462	725709	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom	3	CALIFORNIA: The unisex restroom does not have compliant signage at the door.	Medical Housing Unit Staff Restroom RR-1	California Accessibility Code	$197.71	$197.71
1463	725714	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Interior Access Route	3	Means of egress signage is not provided.	Medical Housing Unit	ADA	$98.85	$98.85
1464	725722	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The side grab bar at the water closet is not compliant.	Medical Housing Unit Inmate Restroom RR-2	ADA	$638.41	$638.41
1465	725745	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Water Closet	3	The rear grab bar at the water closet is not compliant.	M Dorm Restroom RR-3	ADA	$638.41	$638.41
1466	725750	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Restroom	Restroom/Bathroom - Roll - In Shower Stall	3	CALIFORNIA: A shower seat is not provided or is not compliant.	M Dorm Restroom RR-3	California Accessibility Code	$1,086.48	$1,086.48
1467	717942	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Interior Access Route	Telephone	4	The highest operable part of the accessible public telephone is not compliant.	SLF Golden Poppy And Camellia Dorms	ADA	$1,437.86	$1,437.86
1468	722655	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - EXTERIOR	Interior Access Route	Telephone	4	The highest operable part of the accessible public telephone is not compliant.	Dorms G, H, J, K, Typical Findings	ADA	$2,875.72	$2,875.72
1469	725578	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Telephone	4	The highest operable part of the accessible public telephone is not compliant.	Dorm A, B, C, & D Interior	ADA	$2,875.72	$2,875.72
1470	725739	Rio Cosumnes Correctional Center	MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Telephone	4	The highest operable part of the accessible public telephone is not compliant.	Dorm M Interior	ADA	$718.93	$718.93
1471	713824	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Accessible Parking	Parking Space-General	4	CALIFORNIA: The parking facility does not have facility entrance/ accessible parking signage indicating that accessible parking violators will be towed, or the existing signage is not compliant.	Facility Driveway Entrance Sign	California Accessibility Code	$503.25	$503.25
1472	713911	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Intercom Controls	California Accessibility Code	$1,797.33	$1,797.33
1473	721077	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Amenity Not Evaluated	Amenity Not Evaluated	4	The amenity cannot be accessed and, therefore, cannot be evaluated.	Facilities Trades Operations Office	ADA	$0.00	$0.00
1474	722781	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Dorm G, H, J & K Intercom (Typical Findings)	California Accessibility Code	$3,594.65	$3,594.65
1475	717955	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - EXTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	SFL Intercoms	California Accessibility Code	$2,695.99	$2,695.99
1476	713888	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Drinking Fountain/Water Cooler	4	A clear space is not positioned at the lower level drinking fountain for a forward approach and centered on the unit.	Gate House Drinking Fountain DF-1	ADA	$6,755.08	$6,755.08
1477	713907	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Gate House Control Point Interior	California Accessibility Code	$7,189.31	$7,189.31

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1478	714618	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	2nd Floor Admin Building Men's Restroom RR-1	California Accessibility Code	$898.66	$898.66
1479	714632	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	2nd Floor Admin Building Women's Restroom RR-2	California Accessibility Code	$898.66	$898.66
1480	714647	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	2nd Floor Admin ISU Office Unisex Restroom RR-3	California Accessibility Code	$898.66	$898.66
1481	714666	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	2nd Floor Admin Building Men's Restroom RR-4	California Accessibility Code	$898.66	$898.66
1482	714613	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Admin Building Interior Switches and Controls	California Accessibility Code	$22,466.59	$22,466.59
1483	714701	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	2nd Floor Passage Hall Electronics and Projects Office Unisex Restroom	California Accessibility Code	$1,797.33	$1,797.33
1484	714721	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	CBF, SBF Intercom and Light Switch Controls	California Accessibility Code	$3,594.65	$3,594.65
1485	714663	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Signage	4	CALIFORNIA: The enclosed exit stairway in the building two stories or greater does not have compliant floor level signage at each	Admin Building Egress Stairs Facility Wide	California Accessibility Code	$700.96	$700.96
1486	714679	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	2nd Floor Admin Building Women's Restroom RR-5	California Accessibility Code	$898.66	$898.66
1487	714749	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	1st Floor Admin Building Men's Locker Room / Restroom	California Accessibility Code	$898.66	$898.66
1488	725514	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Bookings Building Unisex Restroom RR-2	California Accessibility Code	$1,797.33	$1,797.33
1489	725528	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Bookings Building Women's Restroom RR-3	California Accessibility Code	$1,797.33	$1,797.33
1490	714775	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	1st Floor Admin Building Women's Locker Room / Restroom	California Accessibility Code	$2,695.99	$2,695.99
1491	730078	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	DGS Electrical Shop	California Accessibility Code	$3,594.65	$3,594.65
1492	730108	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Pharmacy Packaging Interior	California Accessibility Code	$898.66	$898.66
1493	730142	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Welding Shop Restroom RR-2	California Accessibility Code	$898.66	$898.66
1494	725596	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	RBF Interior East Wing Controls	California Accessibility Code	$8,986.64	$8,986.64
1495	720967	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Culinary Arts Building Interior	California Accessibility Code	$2,695.99	$2,695.99
1496	720986	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Classroom 2 Building	California Accessibility Code	$13,479.96	$13,479.96
1497	721003	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Classroom 1 Building	California Accessibility Code	$13,479.96	$13,479.96
1498	721020	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Psych Building	California Accessibility Code	$13,479.96	$13,479.96
1499	714790	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	1st Floor Admin Inmate Unisex Restroom RR-6	California Accessibility Code	$898.66	$898.66
1500	730025	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Honor Facility Classroom 4	California Accessibility Code	$1,797.33	$1,797.33
1501	721147	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Rec Storage Interior Controls	California Accessibility Code	$7,189.31	$7,189.31
1502	721153	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Reentry Services Building	California Accessibility Code	$16,175.95	$16,175.95
1503	722619	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Common Areas	Controls And Dispensers	4	Controls and/or dispensers are not within an allowable reach range.	Exterior Intercoms Facility Wide	ADA	$26,959.91	$26,959.91
1504	721166	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Reentry Services Staff Unisex Restroom RR-2	California Accessibility Code	$898.66	$898.66
1505	730093	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	DGS Maintenance Shop Interior	California Accessibility Code	$1,797.33	$1,797.33
1506	730102	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	DGS Plumbing Shop Interior	California Accessibility Code	$1,797.33	$1,797.33
1507	722674	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Honor Facility Barbershop	California Accessibility Code	$1,797.33	$1,797.33
1508	730060	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Honor Facility Classroom 3	California Accessibility Code	$898.66	$898.66
1509	730155	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Honor Facility Back Classroom Interior.	California Accessibility Code	$11,682.63	$11,682.63
1510	730115	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Welding Shop Interior	California Accessibility Code	$4,493.32	$4,493.32
1511	722802	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Booking Interior	California Accessibility Code	$6,290.65	$6,290.65

No.	Id	Facility	Building	Assembly	Type	Barrier Priority	Detail	Location Description	ADA	Total	Total w/ Markup
1512	716105	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	1st Floor Passage Hallway CBF Inmate Unisex Restroom RR-2	California Accessibility Code	$898.66	$898.66
1513	716110	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Security Area Visitor's Side Interior Doors CBF, SBF, JKF, KBF	California Accessibility Code	$4,493.32	$4,493.32
1514	716135	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Interior Intercoms CBF, SBF, JKF, KBF	California Accessibility Code	$898.66	$898.66
1515	716210	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	KBF Holding Tank 2 Accessible	California Accessibility Code	$898.66	$898.66
1516	716195	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	JKF Control Bottom Tier Staff Unisex Restroom RR-3	California Accessibility Code	$898.66	$898.66
1517	716252	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	KBF Pods	California Accessibility Code	$5,391.98	$5,391.98
1518	721073	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Chaplains Office	California Accessibility Code	$10,783.96	$10,783.96
1519	721087	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Medical Trailer Interior Controls	California Accessibility Code	$11,682.63	$11,682.63
1520	716225	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	KBF Control Point Access 801 Unisex Restroom RR-5	California Accessibility Code	$898.66	$898.66
1521	716233	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	KBF & JKF Attorney Room A3 Accessible	California Accessibility Code	$1,797.33	$1,797.33
1522	716265	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	JKF 100 Pod Lower Level	California Accessibility Code	$5,391.98	$5,391.98
1523	717786	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Telephone	4	The highest operable part of the accessible public telephone is not compliant.	SLF Lobby	ADA	$718.93	$718.93
1524	717799	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	SLF Interior Controls Facility Wide	California Accessibility Code	$17,973.27	$17,973.27
1525	721111	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Redemption Coffee Controls	California Accessibility Code	$898.66	$898.66
1526	721117	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Redemption Coffee Unisex Restroom RR-1	California Accessibility Code	$898.66	$898.66
1527	722591	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Rec Building Interior Controls	California Accessibility Code	$8,087.97	$8,087.97
1528	725658	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	RBF Medical Staff Office	California Accessibility Code	$5,391.98	$5,391.98
1529	725703	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Medical Housing Unit	California Accessibility Code	$5,391.98	$5,391.98
1530	725691	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	RCCC Warehouse Inmate Men's Restroom	California Accessibility Code	$898.66	$898.66
1531	722671	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Honor Facility Classroom	California Accessibility Code	$1,797.33	$1,797.33
1532	722680	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Honor Facility Laundry	California Accessibility Code	$6,290.65	$6,290.65
1533	722771	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Dorm J & K Control Room	California Accessibility Code	$2,695.99	$2,695.99
1534	722789	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Telephone	4	The highest operable part of the accessible public telephone is not compliant.	Dorm G, H, J & K Interior (Typical Findings)	ADA	$2,875.72	$2,875.72
1535	722810	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Booking Interior Unisex Restroom 1	California Accessibility Code	$1,797.33	$1,797.33
1536	722832	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	Booking Interior Intercoms	California Accessibility Code	$6,290.65	$6,290.65
1537	716087	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	1st Floor Passage Hallway CBF Staff Unisex Restroom RR-1	California Accessibility Code	$898.66	$898.66
1538	716175	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Stairs	4	CALIFORNIA: The enclosed exit stairway in the building two stories or greater does not have compliant floor level signage at each	CBF & SBF 2nd Floor Classroom Exit Stairs	California Accessibility Code	$467.31	$467.31
1539	716209	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	JKF 448 Medical Staff Unisex Restroom RR-4	California Accessibility Code	$898.66	$898.66
1540	716227	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	KBF & JKF Interior Controls	California Accessibility Code	$1,797.33	$1,797.33
1541	717830	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	SLF Women's Multi Accommodations Restroom RR-6	California Accessibility Code	$898.66	$898.66
1542	717879	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	SLF Rec Office Unisex Restroom RR-10	California Accessibility Code	$898.66	$898.66
1543	717922	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Telephone	4	Clear floor space is not provided at the accessible public telephone	SLF Kinya Dorm	ADA	$718.93	$718.93
1544	725693	Rio Cosumnes Correctional Center	NON MAYS LAWSUIT BARRIERS - INTERIOR	Interior Access Route	Controls And Dispensers	4	CALIFORNIA: The location of electrical controls and outlets are not compliant.	RCCC Warehouse	California Accessibility Code	$5,391.98	$5,391.98